



Mortuary - Waiting

Room Code	MOR-W
Briefed Area	9.00 m ²
Ceiling Height	2.7 m
Occupancy	4-5 visitors; 1-2 staff
Hours of Operation	8am to 5pm, daily (may vary depending on services requirements)

Description | The Mortuary - Waiting provides an area for relatives and others to await the viewing of a body and to have private discussions with social workers. The area should be comfortable and non-clinical in appearance with furnishings and artwork that are culturally appropriate. Natural light is desirable. The Mortuary - Waiting will be located adjacent to the Mortuary - Viewing Room. A body may be viewed through the window from within the Mortuary - Waiting, with access provided between the two rooms to view a body directly.

Electrical	PROTECTION: body protected	☐
	PROTECTION: cardiac protected	☐
Lighting	LIGHTING: general	☒
	LIGHTING: colour corrected	☐
	LIGHTING: dimmable	☐
	LIGHTING: indirect	☐
Nurse Call and Duress	NURSE CALL SYSTEM: buttons / handset	☐

HVAC	AIRCONDITIONING: general	☒
	AIRCONDITIONING: HEPA filtered	☐
	AIRCONDITIONING: positive pressure	☐
	AIRCONDITIONING: negative pressure	☐
	VENTILATION: exhaust	☐
	VENTILATION: natural	☐

Additional Considerations



Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-013.01	DOOR: hinged, 1 leaf, 900 clear opening, solid, standard vision panel	[DWGL-005] to corridor, lockable
AFDPR-001.01	DOOR PROTECTION: kickplate, to 300H	[DWPR-003] to room side
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection
AFDPR-056.03	DOOR FRAME PROTECTION: full wrap, to 1200H	[DWPR-010] optional, provision and extent dependent on frame material/finish and movement of beds and mobile equipment in adjacent area
DOHI-003.01	DOOR: hinged, 1 leaf, 900 clear opening, solid	[DWSC-003] to viewing room; lockable
AFDPR-001.01	DOOR PROTECTION: kickplate, to 300H	[DWPR-003] to corridor side
AFDPR-001.01	DOOR PROTECTION: kickplate, to 300H	[DWPR-003] to room side
WIFX-006.01	WINDOW: fixed, internal, single glazed, sill at 750H	[DWOB-005]



Finishes

CODE	DESCRIPTION	COMMENT
FLCP-006	FLOOR FINISH: carpet tiles	[FLCP-006]
FLSK-026	SKIRTING: vinyl, feather edge	[FLSK-009] aluminum skirting is also acceptable
WLFI-001	WALL FINISH: paint	[WLWA-004]
CLFS-011	CEILING: flush set, suspended	[CLFS-006]
CLFI-002	CEILING FINISH: paint, clinical areas	[CLFS-006]
CLCN-031	CORNICE: square set	[CLCN-008]



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIDI-241	DISPENSER: alcohol-based hand rub, wall mounted	2	1	[FIDI-001]
FQBS-116	CHAIR: visitor, waiting areas	3	3	[FQBS-032]
FQBS-352	LOUNGE: 2 seat	3	1	[FQBS-043]
FQGE-002	ARTWORK: wall mounted	3	1	[FQGE-002]
FQTA-101	TABLE: rectangular, 450H, 900L x 600W	3	1	[FQTA-034]
FQWS-051	BIN: general waste, 20L	3	1	[FQCW-016]



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-101	GPO: single, wall mounted	1	2	[ELGP-109]
ELSW-001	SWITCH: light	1	1	[ELBO-015]
ITSE-061	BUTTON: security, duress, fixed, wall mounted	1	1	[ITSE-006]

For guidance on how to use the Room Data Sheet, please visit the [AusHFG website](#).