

# **Standard Components - Room Data Sheet**

Room Name Neonatal Bay - General Care Room Number: NBGC

Last modified 01/03/2016

Briefed Area Remarks 5.00

Acoustics Sound attenuation level high, Acoustic privacy is required to perimeter walls.

Description or Special Requirements

A single bay for the care of well babies away from their mother's bed area which may include treatments

such as phototherapy. A staff handwash basin should be provided for each four Neonatal Bays - General Care. An external outlook is required. Acoustics: Sound attenuation level - high; Acoustic privacy is required

to perimeter wallsBody Protected electrical area

## **Room Fabrics**

| AusHFG code | Description            | Material     | Finish                  | Specification                 | Comments           |
|-------------|------------------------|--------------|-------------------------|-------------------------------|--------------------|
| 1000        | Floor finish           | Vinyl        | Standard slip resistant | Seamless, coved               |                    |
| 3000        | Wall finish            | Paint        | Acrylic, washable       |                               |                    |
| 4020        | Wall protection        | Composite    | Prefinished PVC         | Crash rail at 900 AFFL        | Equal to 'Acrovyn' |
| 5010        | Ceiling - Plasterboard | Plasterboard | Paint, washable         | Flush set, suspended          |                    |
| 7001        | Windows                |              |                         |                               | Essential          |
| 6010        | Cornice                | Plasterboard | Paint                   | 90mm to match ceiling finish  |                    |
| 2000        | Skirting               | Vinyl        | Prefinished             | Floor vinyl coved, 150<br>mmH |                    |

#### **Fittings and Furniture**

| AusHFG code | Description              | Group | Qty | Comments                        |
|-------------|--------------------------|-------|-----|---------------------------------|
| FF-1465     | Bracket - suction bottle | 2     | 1   | shared between 4 bays           |
| FF-150      | Air flowmeter            | 3     | 1   | shared between 4 bays           |
| FF-16250    | Oxygen flowmeter         | 3     | 1   | optional, shared between 4 bays |
| FF-22000    | Suction bottle           | 3     | 1   | shared between 4 bays           |
| FF-480      | Bassinet                 | 3     | 1   |                                 |

# Fixtures, Equipment and associated Services

## **Service Requirements**

| AusHFG code | Description               | Comments          |
|-------------|---------------------------|-------------------|
| S-9040      | Body protected            |                   |
| S-5000      | Airconditioning           |                   |
| S-6001      | General: colour corrected |                   |
| S-6005      | Dimmable                  | for image viewing |

## Services

| AusHFG code | Description | Group | Qty | Comments                            |
|-------------|-------------|-------|-----|-------------------------------------|
| S-9000      | GPO: Single | 1     |     | Bedhead low level, for electric bed |







# **Standard Components - Room Data Sheet**

**Room Number: NBGC** 

Room Name Neonatal Bay - General Care

| AusHFG code | Description               | Group | Qty | Comments                   |
|-------------|---------------------------|-------|-----|----------------------------|
| S-9015      | GPO: Cleaner              | 1     | 1   |                            |
| S-9040      | Body protected            | 1     | 1   |                            |
| S-5000      | Airconditioning           | 1     | 1   |                            |
| S-6001      | General: colour corrected | 1     | 1   |                            |
| S-6005      | Dimmable                  | 1     | 1   | for image viewing          |
| S-8010      | Staff/ Nurse assist call  | 1     | 1   | + indicator button & light |
| S-8080      | Emergency call            | 1     | 1   | + indicator button & light |
| S-7000      | Oxygen (O2)               | 1     | 1   |                            |
| S-7020      | Medical Air (MA)          | 1     | 1   |                            |
| S-7040      | Suction                   | 1     | 1   |                            |
| S-11000     | Wall panel                | 2     | 1   | patient services panels    |



