



Office - Write-up, 5m2

Room Code	OFF-WI-5
Briefed Area	5.00 m ²
Ceiling Height	2.7 m
Occupancy	2 staff
Hours of Operation	Up to 24 hours (dependent on unit operating hours)

Description | The Write-up Bay provides a write-up bench for use by members of the patient care team. In this space the User may review and write-up patient records, enter patient data on computer and make telephone calls.

Electrical	PROTECTION: body protected	<input type="checkbox"/>	HVAC	AIRCONDITIONING: general	<input checked="" type="checkbox"/>
	PROTECTION: cardiac protected	<input type="checkbox"/>		AIRCONDITIONING: HEPA filtered	<input type="checkbox"/>
Lighting	LIGHTING: general	<input checked="" type="checkbox"/>	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	
	LIGHTING: colour corrected	<input type="checkbox"/>	AIRCONDITIONING: negative pressure	<input type="checkbox"/>	
	LIGHTING: dimmable	<input type="checkbox"/>	VENTILATION: exhaust	<input type="checkbox"/>	
	LIGHTING: indirect	<input type="checkbox"/>	VENTILATION: natural	<input type="checkbox"/>	
Nurse Call and Duress	NURSE CALL SYSTEM: buttons / handset	<input type="checkbox"/>			

Additional Considerations |

- If located within the Operating Unit it may also include an optional area for porters to wait until paged or called by staff.
- The Write-up space must not impede the corridor.



Finishes

CODE	DESCRIPTION	COMMENT
FLVY-101	FLOOR FINISH: vinyl, seamless, standard slip resistance	[FLVY-007]
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, covered	[FLSK-010]
WLFI-001	WALL FINISH: paint	[WLWA-004]
CLTI-022.02	CEILING: drop-in tiles, acoustic, prefinished, 600 x 1200	[CLTI-002]
CLBK-011	BULKHEAD: flush set	[CLGE-001] Between above bench joinery and ceiling
CLCN-041	CORNICE: wall trim fixing, prefinished	[CLCN-009]
WLPR-006.01	WALL PROTECTION: corner guards, to 900 AFFL	[WLPR-010] Align heights of corner guards with other corridor elements



Joinery

CODE	DESCRIPTION	GROUP	QTY	COMMENT
JOBE-031	BENCH: 600D, laminate	1	1	[FIJO-020] standing or seating height, refer RLS or project specific requirements
JOSH-101	SHELF UNIT: wall mounted, adjustable shelves	1	4	[FIJO-152] Above bench, number to suit layout. Refer to RLS or project specific requirements



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIBM-019	WHITEBOARD: fixed, magnetic	②	1	[FIBM-019] Between bench and overbench joinery
FQBS-171	CHAIR: office, ergonomic	③	2	[FQBS-018] For standing height bench, use ergonomic high chair for standing height
FQWS-051	BIN: general waste, 20L	③	1	[FQCW-016]
ITNE-071	TELEPHONE: handset, desktop	③	2	[ITNE-049]
ITNE-101	COMPUTER: single display screen, central processing unit (CPU), keyboard and mouse, desktop	③	2	[ITNE-007] Consider location of harddrive, if below bench add bracket



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-201.01	GPO: double, wall mounted, horizontal	①	4	[ELGP-208] 2 per workspace
ELSW-001	SWITCH: light	①	2	[ELBO-015] Pelmet lighting
ITCL-101	ANNUNCIATOR: nurse call	①	1	[ITCL-001] Located in corridor adjacent, number to suit design
ITIN-026	OUTLET: data, double RJ45, wall mounted	①	2	[ITIN-026] Number of outlets per faceplate as per ICT policy. 1 per workspace
LIFX-108	LIGHT: task, integral to joinery	①	2	[LIFX-008] For above bench joinery

For guidance on how to use the Room Data Sheet, please visit the [AusHFG website](#).