



## Parenting Room

<b>Room Code</b>	PAR
<b>Briefed Area</b>	9.00 m <sup>2</sup>
<b>Ceiling Height</b>	2.7 m
<b>Occupancy</b>	1-2 persons intermittently
<b>Hours of Operation</b>	Up to 24 hours (dependent on unit operating hours)

**Description** | The Parenting Room provides an enclosed, lockable room with the amenities required for parents to feed and change babies including a changing table, waste bin, sink, and arm chair. Access and clearance for prams is required.

**Electrical** | PROTECTION: body protected   
PROTECTION: cardiac protected

**Lighting** | LIGHTING: general   
LIGHTING: colour corrected   
LIGHTING: dimmable   
LIGHTING: indirect

**Nurse Call and Duress** | NURSE CALL SYSTEM: buttons / handset

**HVAC** | AIRCONDITIONING: general   
AIRCONDITIONING: HEPA filtered   
AIRCONDITIONING: positive pressure   
AIRCONDITIONING: negative pressure   
VENTILATION: exhaust   
VENTILATION: natural

### Additional Considerations

- The Parenting Room should be located to have ready access to other public amenities sanitary facilities and is often collocated with waiting areas.
- Inclusion of a small fridge within the room may be considered if the room is located to serve a staff area; provision will be dependent on operational policies.
- This Standard Component shows a wall mounted drop-down change table. Custom joinery for baby changing facilities may be considered and provision is to be determined at project level.
- Mobile duress coverage is to be assessed and planned at a department level and coverage is to suit local security and WHS policies and operational service requirements.



## Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-002.01	DOOR: hinged, 1 leaf, 850 clear opening, solid	[DWSC-001] with privacy latch, emergency release required if inward opening door
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to room side



## Finishes

CODE	DESCRIPTION	COMMENT
FLVY-111	FLOOR FINISH: vinyl, seamless, non-slip	[FLVY-003] minimum slip rating R10/ pendulum P3 or agreed equivalent; tiles are also acceptable

CODE	DESCRIPTION	COMMENT
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, covered	[FLSK-010] tiles acceptable if tiled floor is provided
WLFI-001	WALL FINISH: paint	[WLWA-004]
WLFI-011.04	WALL FINISH: vinyl, to 1500 AFFL	[WLWA-020]
WLFI-101	SPLASHBACK: vinyl	[WLWA-007] to bench with sink
CLTI-022.02	CEILING: drop-in tiles, acoustic, prefinished, 600 x 1200	[CLTI-002]
CLCN-041	CORNICE: wall trim fixing, prefinished	[CLCN-009]



## Joinery

CODE	DESCRIPTION	GROUP	QTY	COMMENT
JOBE-041	BENCH: 650D, laminate	①	1	[FIJO-232] solid surface material is also acceptable
JOBE-221	BENCH SUPPORT: end panel	①	1	[FIJO-213]
JOGE-037	SHROUD: under bench, removable, accessible	①	1	[FIJO-228] to bench to conceal plumbing for sink



## Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIDI-231	DISPENSER: paper towel, wall mounted	②	1	[FIDI-025] to sink
FIDI-256	DISPENSER: soap, wall mounted	②	1	[FIDI-030] to sink
FIHR-026	HOOK: coat, wall mounted	①	2	[FIHR-026]
FQBS-261	ARMCHAIR: visitor, waiting areas	③	1	[FQBS-010] to be suitable for breastfeeding
FQGE-361	CHANGE TABLE: baby, wall mounted	①	1	[FQBS-035]
FQTA-401	TABLE: round, 450H, 500 diameter	③	1	[FQTA-049]
FQWS-051	BIN: general waste, 20L	③	1	[FQCW-016]
FQWS-053	BIN: general waste, 50L	③	1	[FQCW-019] for nappies, dedicated sanitary waste stream may be required depending on local waste management policies, size to suit operation policies regarding frequency of waste removal
HYBA-302	SINK: single bowl, accessible	①	1	[HYBA-051] depth to meet accessibility requirements when combined with joinery shroud; provision of an integrated solid surface sink in a solid surface bench is also acceptable
HYTP-152	TAPWARE: sink, mixer, fixture mounted, accessible	①	1	[HYTP-040]



## Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-201	GPO: double, wall mounted	①	1	[ELGP-208]
ELSW-021	SWITCH: light, dimmer	①	1	[ELBO-012]
HYDR-201	DIRECT CONNECTION: wastewater, general	①	1	to sink
HYTP-451	DIRECT CONNECTION: water, cold	①	1	to sink tapware
HYTP-453	DIRECT CONNECTION: water, warm	①	1	to sink tapware

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ITSE-061	BUTTON: security, duress, fixed, wall mounted	①	1	[ITSE-006]

For guidance on how to use the Room Data Sheet, please visit the [AusHFG website](#).