



Patient Bay - Specimen Collection

Room Code	PBSC
Briefed Area	9.00 m ²
Ceiling Height	2.7 m
Occupancy	1 patient; 1 visitor; 1 staff
Hours of Operation	8am to 6pm, daily (may vary depending on service requirements)

Description | A Patient Bay used for the collection of specimens to be transferred to a laboratory for testing.

Electrical	PROTECTION: body protected	☒	HVAC	AIRCONDITIONING: general	☒
	PROTECTION: cardiac protected	☐		AIRCONDITIONING: HEPA filtered	☐
Lighting	LIGHTING: general	☐		AIRCONDITIONING: positive pressure	☐
	LIGHTING: colour corrected	☒		AIRCONDITIONING: negative pressure	☐
	LIGHTING: dimmable	☐		VENTILATION: exhaust	☐
	LIGHTING: indirect	☐		VENTILATION: natural	☐
Nurse Call and Duress	NURSE CALL SYSTEM: buttons / handset	☐			

Additional Considerations

- Ready access to a handwashing basin is required.
- Ready access may be required to a pneumatic tube bay that is in a staff supervised area.
- Recliner must be able to lay flat to support the patient in the event of an adverse reaction (e.g. fainting).
- A desk may be provided in lieu of Workstation on Wheels depending on operational model.
- An operational model for responding to calls from staff/patients will be needed to support the inclusion of a nurse call system and is to be determined based on service requirements.
- A risk assessment should be undertaken to inform staff safety requirements with adjoining cubicles which may require adjustments to the design and/or operational strategies, such as the use of mobile duress systems.
- Refer to the Pathology HPU for paediatric requirements.



Finishes

CODE	DESCRIPTION	COMMENT
FLVY-101	FLOOR FINISH: vinyl, seamless, standard slip resistance	[FLVY-007]
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010]
WLFI-001	WALL FINISH: paint	[WLWA-004]
WLFI-011.04	WALL FINISH: vinyl, to 1500 AFFL	[WLWA-020]
CLTI-022.02	CEILING: drop-in tiles, acoustic, prefinished, 600 x 1200	[CLTI-002]
CLCN-041	CORNICE: wall trim fixing, prefinished	[CLCN-009]
WLPR-006	WALL PROTECTION: corner guards	[WLPR-006]



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIDI-106	DISPENSER: PPE, disposable gloves, wall mounted	2	1	[FIDI-014]

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIDI-241	DISPENSER: alcohol-based hand rub, wall mounted	②	1	[FIDI-001]
FIHR-026	HOOK: coat, wall mounted	①	2	[FIHR-026] optional, prioritize lower hook for wheelchair users if only one hook provided
FIHR-111	BRACKET: sharps bin, wall mounted	②	1	[FIHR-016] on trolley
FIHR-151	PANEL: storage baskets, wall mounted	②	1	[FIHR-033]
FIRT-051.01	TRACK: curtain, privacy, straight	①	1	[FIRT-031]
FQBS-101	CHAIR: visitor, clinical areas	③	1	[FQBS-028] optional
FQBS-202	STOOL: clinical areas, mobile	③	1	[FQBS-051]
FQGE-101	CURTAIN: privacy screen	③	1	[FQGE-010]
FQGE-112	BASKET: storage, for wall mounted panel, small	③	1	[FQSN-007] extent and type of storage to be based on service requirements and local infection control policies
FQWS-003	BIN: sharps, clinical, medium	③	1	[FQCW-044] on trolley; may be wall mounted or mobile
FQWS-051	BIN: general waste, 20L	③	1	[FQCW-016]
ITNE-111	COMPUTER: workstation on wheels (WOW), medical grade, all-in-one computer, keyboard and mouse, on cart	③	1	[ITNE-008+MMGE-164] a desk may be provided depending on operational model
ITNE-316	PRINTER: labels, small, desktop	③	1	[FQGE-056] optional, on WOW
LIFX-113	LIGHT: examination, single articulated arm, 1 light head, ceiling mounted	①	1	[LIFX-027] optional
MMBE-094	CHAIR: patient, recliner, clinical, phlebotomy, electric	③	1	[MMBE-094] height adjustable and able to lie flat, electric examination couch may also be provided
MMTR-087	TROLLEY: phlebotomy, 600W x 490D x 900H nom	③	1	[MMGE-189] with drop down shelf



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-101	GPO: single, wall mounted	①	1	[ELGP-109] to chair
ELGP-106	GPO: single, ceiling mounted	①	1	[ELGP-101] optional, to exam light
ELGP-201	GPO: double, wall mounted	①	1	[ELGP-208]
ELPR-071	RCD: residual current device, wall mounted	①	1	[ELPR-006]
ELSW-001	SWITCH: light	①	1	[ELBO-015] optional, to exam light
ITCL-181	BUTTON: nurse call, staff assist, with cancel, wall mounted	①	1	[ITCL-008]
ITCL-191	BUTTON: nurse call, emergency, with cancel, wall mounted	①	1	[ITCL-004]
ITIN-026	OUTLET: data, double RJ45, wall mounted	①	1	[ITIN-026]
ITSE-061	BUTTON: security, duress, fixed, wall mounted	①	1	[ITSE-006]

For guidance on how to use the Room Data Sheet, please visit the [AushFG website](https://www.aushfg.org.au).