

### **Standard Components - Room Data Sheet**

Room Name Patient Bay - Holding, 9m2 Room Number: PBTR-H-9

Last modified 01/03/2016

Briefed Area Remarks

9.00

Occupancy

1 patient; 1 - 2 staff intermittently

Hours of Operation Acoustics

√ 24 Hours

Description / Special Requirements

A Patient Bed Bay used for holding of patients prior to procedures, observation of patients following procedures or for assessment and treatment of patients with non acute conditions. The Patient Bay will have close access to a staff handwashing basin. The Patient Bay may be reduced to a minimum of 6m2 to accommodate a recliner chair instead of a patient bed. Requirement for services including medical gases and power will be dependent on the use of the bay. Body protected electrical area.

#### **Room Fabrics**

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	Significant change in colour to be avoided.
3000	Wall finish	Paint	Acrylic, washable		
2692	Wall protection			Bed protection wall panel	
5010	Ceiling - Plasterboard	Plasterboard	Paint, washable	Flush set, suspended	Acoustic tiles acceptable.
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

### **Fittings and Furniture**

AusHFG code	Description	Group	Qty	Comments
FF-12900	Wire panel - for storage-bins	1	1	Optional. Depends on functionality, infection control and cleaning policies.
FF-1465	Bracket - suction bottle	2	1	required if suction outlet provided
FF-150	Air flowmeter	3	1	optional, required if air outlet provided
FF-16250	Oxygen flowmeter	3	1	required if oxygen outlet provided
FF-21755	Storage bins	3	3	on louvred panel, optional
FF-21950	Suction adapter	3	1	required if suction outlet provided
FF-22000	Suction bottle	3	1	required if suction outlet provided
FF-2650	Chair - visitor, patient	3	1	optional
FF-4600	Curtain track - bed screen	1	1	
FF-5250	Curtain - privacy screen	3	1	
FF-6152	Dispenser - disposable glove	2	1	Optional.
FF-5830	Dispenser - antiseptic hand rub	2	1	
FF-24405	Whiteboard - magnetic	2	1	Optional. Clinical use.







# **Standard Components - Room Data Sheet**

Room Name Patient Bay - Holding, 9m2 Room Number: PBTR-H-9

AusHFG code	Description	Group	Qty	Comments
FF-5580	Storage bins - stainless steel wire mesh	1	'	For wired panels, optional. Depends on functionality, infection control and cleaning policies.

## Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Тар	Dns	Gas	Comments
FE-31700	Light - examination, ceiling	1	1	<b>V</b>								spatial provision required
FE-5622	Bed - inpatient, electric + standard patient mattress	3	1	<b>√</b>								Or electric recliner chair. Spatial provision for bed may only be required depending on service.

### **Service Requirements**

AusHFG code	Description	Comments
S-9040	Body protected	
S-5000	Airconditioning	
S-1412	Special examination downlight	
S-6001	General: colour corrected	

### **Services**

AusHFG code	Description	Group	Qty	Comments
S-9000	GPO: Single	1	3	Bedhead low level, for electric bed
S-9010	GPO: Emergency power, single (V)	1	3	monitor
S-9001	GPO: Double	1	1	
S-9040	Body protected	1	1	
S-1006	Voice / Data outlet: double	1	1	1 outlet for telephone
S-5000	Airconditioning	1	1	
S-1412	Special examination downlight	1	1	
S-6001	General: colour corrected	1	1	
S-8000	Patient/ Staff call	1	1	+ indicator button & light
S-8005	Patient call handset	1	1	call button & light switch on the handset
S-8080	Emergency call	1	1	+ indicator button & light
S-1951	Staff assist call	1	1	+ indicator button & light
S-7000	Oxygen (O2)	1	1	
S-7020	Medical Air (MA)	1	1	
S-7040	Suction	1	1	







# **Standard Components - Room Data Sheet**

Room Name Patient Bay - Holding, 9m2 Room Number: PBTR-H-9

AusHFG code	Description	Group	Qty	Comments
S-11000	Wall panel	2	1	patient services panels



