



Patient Bay - Renal Dialysis, Bed

Room Code	PBTR-RD-B
Briefed Area	9.00 m ²
Ceiling Height	2.7 m
Occupancy	1 patient; 1 visitor; 1-2 staff intermittently
Hours of Operation	7am to 9pm, daily (may vary depending on service requirements)

Description | The Patient Bay - Renal Dialysis is for patients receiving haemodialysis therapy. Treatments for each patient may take from 3 to 6 hours, occurring up to 3 days per week.

Electrical | PROTECTION: body protected ☒
PROTECTION: cardiac protected ☐

Lighting | LIGHTING: general ☐
LIGHTING: colour corrected ☒
LIGHTING: dimmable ☐
LIGHTING: indirect ☐

Nurse Call and Duress | NURSE CALL SYSTEM: buttons / handset ☒

HVAC | AIRCONDITIONING: general ☒
AIRCONDITIONING: HEPA filtered ☐
AIRCONDITIONING: positive pressure ☐
AIRCONDITIONING: negative pressure ☐
VENTILATION: exhaust ☐
VENTILATION: natural ☐

Additional Considerations |

- A staff handwashing basin will be provided for each 4 bays and the Patient Bay will have, wherever possible, clear line of sight to a staff station.
- Access to natural light and views is required.
- Furniture and furnishings should provide a high level of patient comfort and amenity.



Doors and Windows

CODE	DESCRIPTION	COMMENT
WIFX-161.01	WINDOW: fixed, external, double glazed, sill at 1500H	[DWWH-005] access to natural light and external outlook essential
AHWCV-001	WINDOW COVERING: blind, roller, single	[DWWD-004]



Finishes

CODE	DESCRIPTION	COMMENT
FLVY-101	FLOOR FINISH: vinyl, seamless, standard slip resistance	[FLVY-007] floor finish must be minimum slip rating R10 / pendulum P3 or agreed equivalent; a higher slip rating may be required depending on local WHS policies
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010]
WLFI-001	WALL FINISH: paint	[WLWA-004]
WLFI-011.04	WALL FINISH: vinyl, to 1500 AFFL	[WLWA-020] optional, to side walls if provided
CLTI-022.02	CEILING: drop-in tiles, acoustic, prefinished, 600 x 1200	[CLTI-002]
CLCN-041	CORNICE: wall trim fixing, prefinished	[CLCN-009]

CODE	DESCRIPTION	COMMENT
WLPR-001	WALL PROTECTION: bedhead wall panel, full height	[WLPR-001]
WLPR-006	WALL PROTECTION: corner guards	[WLPR-006] optional, to side walls if provided



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIDI-241	DISPENSER: alcohol-based hand rub, wall mounted	2	1	[FIDI-001]
FIHR-101	BRACKET: suction bottle, wall mounted	2	1	[FIHR-019]
FIHR-111	BRACKET: sharps bin, wall mounted	2	1	[FIHR-016]
FIHR-214	BRACKET: computer display screen, single, articulated, ceiling mounted	2	1	[FIHR-004]
FIRT-051	TRACK: curtain, privacy	1	1	[FIRT-032]
FQBS-101	CHAIR: visitor, clinical areas	3	1	[FQBS-030]
FQGE-101	CURTAIN: privacy screen	3	2	[FQGE-010]
FQTA-091	TABLE: overbed, mobile, height adjustable	3	1	[FQTA-013]
FQWS-003	BIN: sharps, clinical, medium	3	1	[FQCW-044]
ITCL-301	DISPLAY SCREEN: patient entertainment system	2	1	[ITBU-012]
LIFX-113	LIGHT: examination, single articulated arm, 1 light head, ceiling mounted	1	1	[LIFX-027] optional
MMBE-101	BED: patient, electric, with mattress	3	1	[MMBE-009]
MMGE-191	CANNISTER: suction bottle	3	1	[MMGE-100]
MMGE-381	MACHINE: dialysis	3	1	[MMGE-049]



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-106	GPO: single, ceiling mounted	1	1	[ELGP-101] to patient entertainment system
ELGP-131	GPO: single, emergency power, wall mounted	1	1	[ELGP-123] low level, to recliner
ELSW-001	SWITCH: light	1	1	[ELBO-015] optional, to exam light if provided
HYDR-021	DRAIN: floor waste, round	1	1	[HYDR-004] in case of spills, to be consolidated between multiple bays
HYDR-181	ACCESS PANEL: waterless trap	1	1	[HYDR-019]
HYGE-081	WALL BOX: renal dialysis, integral tundish, with 1 water supply connection and 1 drain connection	1	1	[MMGE-096]
<i>HYDR-104</i>	<i>TUNDISH: in wall, with viewing panel</i>	1	1	<i>Sub item to HYGE-081</i>
<i>HYDR-201</i>	<i>DIRECT CONNECTION: wastewater, general</i>	1	1	<i>Sub item to HYGE-081</i>
<i>HYTP-458</i>	<i>DIRECT CONNECTION: water, reverse osmosis (RO)</i>	1	1	<i>Sub item to HYGE-081</i>
ITCL-111	LIGHT: nurse call indicator, ceiling mounted	1	1	outside curtain
ITCL-191	BUTTON: nurse call, emergency, with cancel, wall mounted	1	1	[ITCL-004] + indicator button & light
ITIN-071	OUTLET: MATV, ceiling mounted	1	1	[ITIN-070] to patient entertainment system, may be replaced with data outlet depending on ICT policy
LIFX-161	LIGHT: reading, wall mounted	1	1	[LIFX-011]



Medical Services Panels and Pendants

CODE	DESCRIPTION	GROUP	QTY	COMMENT
Panel 1				
MMSP-051	MEDICAL SERVICES PANEL: wall mounted	①	1	[MMSP-026]
ELGP-246	GPO: double, emergency power, on services panel	①	3	[ELGP-222]
ELPR-073	RCD: residual current device, on services panel	①	1	[ELPR-006]
ITCL-133	BUTTON: nurse call, patient to staff call, with cancel, with handset connection point, on services panel	①	1	[ITCL-006] + indicator button & light
ITCL-183	BUTTON: nurse call, staff assist, with cancel, on services panel	①	1	[ITCL-008] + indicator button & light
ITCL-253	HANDSET: nurse call, patient to staff call, with light control, with patient entertainment system control, with speaker	①	1	[ITCL-028]
ITIN-025	OUTLET: data, double RJ45, on services panel	①	1	[ITIN-025]
MGAS-042	OUTLET: oxygen (O2), on services panel	①	1	[MGAS-042]
MGAS-062	OUTLET: suction, on services panel	①	1	[MGAS-062]
MGFP-041	FLOWMETER: oxygen	③	1	[MGFP-004]
MGFP-061	ADAPTER: suction	③	1	[MMGE-002]

For guidance on how to use the Room Data Sheet, please visit the [AusHFG website](#).