

Room Name | Patient Bay - Recovery, Stage 1

Room Number: PBTR-RS1

Last modified 01/03/2016

Briefed Area 9.00

Remarks

Occupancy 1 patient; 1 staff

Hours of Operation ☒ 24 Hours

Acoustics

Description or Special Requirements

A Patient Bed Bay used for the recovery of patients from anaesthetic, located within the Operating Unit or Day Procedures Unit. A clinical handwashing basin will be provided for each 4 Recovery Bed Bays. Recovery Bed Bays will require direct observation from the Staff Station. Cardiac Protected electrical area

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
3092	Wall protection	MDF	Laminate	Bed protection wall panel	
5010	Ceiling - Plasterboard	Plasterboard	Paint, washable	Flush set, suspended	
7001	Windows				Desirable
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1252	Blind - Venetian integral	1	1	to external window/s
FF-12900	Wire panel - for storage-bins	1	1	optional
FF-1465	Bracket - suction bottle	2	2	
FF-1470	Bracket - sharps	2	1	
FF-150	Air flowmeter	3	1	
FF-15100	Bracket - monitor	3	1	
FF-16250	Oxygen flowmeter	3	2	
FF-19700	Sharps bin	3	1	
FF-19800	Shelf - laminate	1	1	to bedhead, full length
FF-21755	Storage bins	3	2	to louvred panel, if provided
FF-21950	Suction adapter	3	2	
FF-22000	Suction bottle	3	2	
FF-4600	Curtain track - bed screen	1	2	
FF-5000	Curtain - bed screen	3	2	
FF-6152	Dispenser - disposable glove	2	1	

Room Name | Patient Bay - Recovery, Stage 1

Room Number: PBTR-RS1

Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-36055	Monitor - cardiac with vital signs	3	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	on bracket
FE-5854	Bed - ICU, electric + patient mattress	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-5857	Light - procedures small, ceiling	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Service Requirements

AusHFG code	Description	Comments
S-9030	Cardiac protected	
S-5000	Airconditioning	
S-6001	General: colour corrected	

Services

AusHFG code	Description	Group	Qty	Comments
S-9000	GPO: Single	1	4	Bedhead low level, for electric bed
S-9010	GPO: Emergency power, single (V)	1	4	monitor
S-9015	GPO: Cleaner	1	1	
S-9030	Cardiac protected	1	1	
S-9060	GPO: Special: for equipment	1	1	TV, ceiling
S-1006	Voice / Data outlet: double	1	1	1 outlet for telephone
S-1090	TV: MATV	1	1	
S-1120	Monitor connection facilities and cabling	1	1	optional
S-5000	Airconditioning	1	1	
S-6001	General: colour corrected	1	1	
S-6200	Light switches	1	1	
S-8000	Patient/ Staff call	1	1	+ indicator button & light
S-8005	Patient call handset	1	1	call button & light switch on the handset
S-8010	Staff/ Nurse assist call	1	1	+ indicator button & light
S-8080	Emergency call	1	1	+ indicator button & light
S-1951	Staff assist call	1	1	+ indicator button & light
S-7000	Oxygen (O2)	1	2	
S-7020	Medical Air (MA)	1	1	
S-7040	Suction	1	2	

Standard Components - Room Data Sheet

Room Name | Patient Bay - Recovery, Stage 1

Room Number: PBTR-RS1

AusHFG code	Description	Group	Qty	Comments
S-11000	Wall panel	2	1	patient services panels