

Room Name	Patient Bay - Resuscitation	Room Number: PBTR-R
Last modified	01/03/2016	
Briefed Area	25.00	
Remarks		
Occupancy	1 patient; 4 - 5 staff	
Hours of Operation	<input checked="" type="checkbox"/> 24 Hours	
Acoustics		
Description or Special Requirements	A Patient Bed Bay for assessment, resuscitation and treatment of patients with critical conditions, located within the Emergency Unit. The Bay may have partition side walls and a bench used for preparation and write-up. Resuscitation and diagnostic equipment should be located in close proximity which may include ventilator, cardiac pacemaking equipment and mobile X-ray machine. Cardiac Protected electrical area	

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
3060	Wall finish	Vinyl	Prefinished	Splashback	to basin & above bench
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900 AFFL	As required, equal to 'Acrovyn'
4031	Wall protection	Composite	Prefinished PVC	Corner guards to 1500 AFFL	As required, Equal to 'Acrovyn'
5010	Ceiling - Plasterboard	Plasterboard	Paint, washable	Flush set, suspended	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1050	Bench - laminate	1	1	open under part
FF-10700	IV hanger for ceiling track	1	1	optional, may be attached to pendant
FF-11200	IV track - ceiling mounted	1	1	optional
FF-12900	Wire panel - for storage-bins	1	2	for storage, above bench
FF-1470	Bracket - sharps	2	1	on trolley
FF-150	Air flowmeter	3	2	to services pendant
FF-16250	Oxygen flowmeter	3	3	to services pendant
FF-18800	Trolley - resuscitation, adult	3	1	
FF-19060	Safe - dangerous drugs, small	1	1	in cupboard
FF-1950	Chair - ergonomic, high	3	1	for staff use
FF-19700	Sharps bin	3	1	on trolley
FF-20000	Shelving unit - adjustable	1	3	over bench, storage
FF-21755	Storage bins	3	3	for storage on louvred panel

Room Name | Patient Bay - Resuscitation

Room Number: PBTR-R

AusHFG code	Description	Group	Qty	Comments
FF-21950	Suction adapter	3	3	to services pendant
FF-22000	Suction bottle	3	3	
FF-4375	Cupboard - medication, lockable	1	1	with drug safe
FF-4410	Cupboard - under bench	1	2	adjustable shelf
FF-4467	Cupboard - wall mounted	1	2	over bench, drug storage
FF-4600	Curtain track - bed screen	1	1	
FF-5000	Curtain - bed screen	3	1	
FF-5250	Curtain - privacy screen	3	2	
FF-6152	Dispenser - disposable glove	2	1	
FF-6154	Dispenser - paper/ hand towel	2	1	to basin
FF-6156	Dispenser - soap	2	1	to basin
FF-6158	Dispenser - soap antiseptic	2	1	to basin
FF-5824	Waste bin - general	3	1	
FF-5975	Waste bin - clinical	3	1	

Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-11400	Computer - PC & monitor	3	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	to bench, optional
FE-15500	Defibrillator	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	on resuscitation trolley
FE-15900	Diagnostic set - wall mounted	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-3100	Basin - scrub, Type A	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	refer to BHWS-A (sim)
FE-32650	Light - operating, single, 550 diam nominal	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-36050	Monitor - cardiac	3	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-3725	Bed - emergency, electric	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-43800	Refrigerator - under-bench, 120 Litre	3	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-47000	Services pendant - ceiling	1	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-54510	Telephone - handset, standard	3	1	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	to bench
FE-68800	Xray viewer - 3 screen	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	recessed

Room Name | Patient Bay - Resuscitation

Room Number: PBTR-R

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-9800	Clock - time elapse	1	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	beside analogue

Service Requirements

AusHFG code	Description	Comments
S-9030	Cardiac protected	
S-5000	Airconditioning	
S-6001	General: colour corrected	
S-6055	Special: task light, built in	under O/H cupboards

Services

AusHFG code	Description	Group	Qty	Comments
S-9000	GPO: Single	1	2	Bedhead low level, for electric bed
S-9010	GPO: Emergency power, single (V)	1	16	monitor
S-9015	GPO: Cleaner	1	1	
S-9030	Cardiac protected	1	1	
S-9011	GPO: Emergency power, double (H)	1	1	for refrigerator
S-9011	GPO: Emergency power, double (H)	1	2	for refrigerator
S-9060	GPO: Special: for equipment	1	3	TV, ceiling
S-1006	Voice / Data outlet: double	1	2	1 outlet for telephone
S-1120	Monitor connection facilities and cabling	1	1	optional
S-5000	Airconditioning	1	1	
S-6001	General: colour corrected	1	1	
S-6200	Light switches	1	1	
S-6055	Special: task light, built in	1	1	under O/H cupboards
S-8000	Patient/ Staff call	1	1	+ indicator button & light
S-8005	Patient call handset	1	1	call button & light switch on the handset
S-8010	Staff/ Nurse assist call	1	1	+ indicator button & light
S-8080	Emergency call	1	1	+ indicator button & light
S-1951	Staff assist call	1	1	+ indicator button & light
S-2072	Scavenge Outlet	1	1	and controls, on wall, optional
S-7000	Oxygen (O2)	1	3	
S-7010	Nitrous Oxide (N2O)	1	1	services panel
S-7020	Medical Air (MA)	1	2	

Standard Components - Room Data Sheet

Room Name | Patient Bay - Resuscitation

Room Number: PBTR-R

AusHFG code	Description	Group	Qty	Comments
S-7040	Suction	1	3	
S-7070	Scavenge	1	1	services panel