



Pharmacy - Dispensing Workstation

Room Code	PHA-DS
Briefed Area	4.00 m ²
Ceiling Height	2.7 m
Occupancy	1 staff
Hours of Operation	8am to 6pm, daily (may vary depending on service requirements)

Description | The Dispensing Workstation provides workspace to prepare, assemble and label patient medications for dispensing to inpatients and outpatients. The workstations can be configured to provide dispensing/assembly stations and a checking station as required.

Electrical | PROTECTION: body protected
 PROTECTION: cardiac protected

Lighting | LIGHTING: general
 LIGHTING: colour corrected
 LIGHTING: dimmable
 LIGHTING: indirect

Nurse Call and Duress | NURSE CALL SYSTEM: buttons / handset

HVAC | AIRCONDITIONING: general
 AIRCONDITIONING: HEPA filtered
 AIRCONDITIONING: positive pressure
 AIRCONDITIONING: negative pressure
 VENTILATION: exhaust
 VENTILATION: natural

Additional Considerations

- Dispensing workstations should be arranged to support effective workflows, reduce travel time and avoid error. These stations should be arranged such that extended reaches are avoided. Where dispensing workstations are arranged adjacent to each other, corridors in between them should be wide enough to provide unobstructed movement for staff and trolleys.
- Ready access to the bulk store and refrigerated storage is required.
- Printer and telephone facilities to be shared between multiple workstations. A Multifunction device is to be in close proximity to the dispensing area.
- Ensure adequate lighting over workspace - task lighting may be required.



Finishes

CODE	DESCRIPTION	COMMENT
FLVY-101	FLOOR FINISH: vinyl, seamless, standard slip resistance	[FLVY-007]
CLTI-022.02	CEILING: drop-in tiles, acoustic, prefinished, 600 x 1200	[CLTI-002]
CLCN-041	CORNICE: wall trim fixing, prefinished	[CLCN-009]



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FQBS-172	CHAIR: office, ergonomic, high	3	1	[FQBS-019]
FQWS-051	BIN: general waste, 20L	3	1	[FQCW-016] quantity and type of bins to be based on local waste management policies
FQWS-212	BIN: confidential document, secure, 30L	3	1	[FQCW-064] quantity and type of bins to be based on local waste management policies

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ITNE-101	COMPUTER: single display screen, central processing unit (CPU), keyboard and mouse, desktop	3	1	[ITNE-007] may be on desk mounted bracket
ITNE-171	DISPLAY SCREEN: computer	3	1	[ITNE-063] optional, depending on project ICT requirements; may be on desk mounted bracket
ITNE-221	INPUT DEVICE: bar code scanner	3	1	[ITNE-003]
ITNE-316	PRINTER: labels, small, desktop	3	1	[FQGE-093]
MMPH-081	WORKSTATION SYSTEM: pharmacy, shelving, with integral power and data, softwired	3	1	[FQDW-048 + FQDW-047] services spine may be shared between multiple workstations
MMPH-174.01	WORKSTATION: pharmacy, straight, adjustable height, 900H nom, 750D x 1800W	3	1	[FQDW-046]



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-201	GPO: double, wall mounted	1	1	[ELGP-208]
ELGP-231	GPO: double, emergency power, wall mounted	1	2	[ELGP-223] extent of emergency power to be determined based on service requirements
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	2	[ITIN-026]

For guidance on how to use the Room Data Sheet, please visit the [AushFG website](#).