



## Pharmacy - Preparation Room, Non-Aseptic

|                           |  |
|---------------------------|--|
| <b>Room Code</b>          | PHA-PR   |
| <b>Briefed Area</b>       | 12.00 m <sup>2</sup>   |
| <b>Ceiling Height</b>     | 2.7 m  |
| <b>Occupancy</b>          | 1-2 staff  |
| <b>Hours of Operation</b> | 8am to 6pm, daily (may vary depending on service requirements) |

**Description** | The Preparation Room provides a dedicated area for the extemporaneous preparation and compounding of non-aseptically prepared products and cleaning of equipment as required. The Preparation Room should be located in close proximity to the dispensing area.

|                              |                                      |                                     |                                    |                                |                                     |
|------------------------------|--------------------------------------|-------------------------------------|------------------------------------|--------------------------------|-------------------------------------|
| <b>Electrical</b>            | PROTECTION: body protected           | <input type="checkbox"/>            | <b>HVAC</b>                        | AIRCONDITIONING: general       | <input checked="" type="checkbox"/> |
|                              | PROTECTION: cardiac protected        | <input type="checkbox"/>            |                                    | AIRCONDITIONING: HEPA filtered | <input type="checkbox"/>            |
| <b>Lighting</b>              | LIGHTING: general                    | <input checked="" type="checkbox"/> | AIRCONDITIONING: positive pressure | <input type="checkbox"/>       |                                     |
|                              | LIGHTING: colour corrected           | <input type="checkbox"/>            | AIRCONDITIONING: negative pressure | <input type="checkbox"/>       |                                     |
|                              | LIGHTING: dimmable                   | <input type="checkbox"/>            | VENTILATION: exhaust               | <input type="checkbox"/>       |                                     |
|                              | LIGHTING: indirect                   | <input type="checkbox"/>            | VENTILATION: natural               | <input type="checkbox"/>       |                                     |
| <b>Nurse Call and Duress</b> | NURSE CALL SYSTEM: buttons / handset | <input type="checkbox"/>            |                                    |                                |                                     |

**Additional Considerations**

### Doors and Windows

| CODE         | DESCRIPTION   | COMMENT   |
|--------------|---|---|
| DOHI-043.01  | DOOR: hinged, 1 leaf, 900 clear opening, solid, wide vision panel | [DWGL-003]  |
| AFDPR-006.01 | DOOR PROTECTION: plate, to 900H                                   | [DWPR-005] to corridor side, extent dependent on movement of mobile equipment in adjacent area; to be coordinated with corridor wall protection |
| AFDPR-006.01 | DOOR PROTECTION: plate, to 900H                                   | [DWPR-005] to room side   |

### Finishes

| CODE        | DESCRIPTION   | COMMENT  |
|-------------|---|--|
| FLVY-101    | FLOOR FINISH: vinyl, seamless, standard slip resistance | [FLVY-007] floor finish must be minimum slip rating R10 / Pendulum P3 or agreed equivalent to extend under basin or inset section of non-slip vinyl required |
| FLSK-021    | SKIRTING: vinyl, integral with floor vinyl, covered     | [FLSK-010]   |
| WLFI-001    | WALL FINISH: paint                                      | [WLWA-004]   |
| WLFI-011.04 | WALL FINISH: vinyl, to 1500 AFFL                        | [WLWA-020]   |
| WLFI-101    | SPLASHBACK: vinyl                                       | [WLWA-010]   |

| CODE     | DESCRIPTION                           | COMMENT    |
|----------|---------------------------------------|------------|
| CLFS-011 | CEILING: flush set, suspended         | [CLFS-006] |
| CLFI-002 | CEILING FINISH: paint, clinical areas | [CLFS-006] |
| CLCN-031 | CORNICE: square set                   | [CLCN-008] |



## Joinery

| CODE     | DESCRIPTION                                 | GROUP | QTY | COMMENT  |
|----------|---|-------|-----|--|
| JOBE-031 | BENCH: 600D, laminate                       | ①     | 1   | [FIJO-020] may be height adjustable item depending on service requirements |
| JOBE-031 | BENCH: 600D, laminate                       | ①     | 2   | [FIJO-059]   |
| JOCU-103 | CUPBOARD: wall mounted, single door, glazed | ①     | 1   | [FIJO-159]   |
| JOCU-123 | CUPBOARD: wall mounted, double door, glazed | ①     | 3   | [FIJO-148]   |
| JOCU-201 | CUPBOARD: under bench, single door          | ①     | 1   | [FIJO-141]   |
| JOCU-221 | CUPBOARD: under bench, double door          | ①     | 3   | [FIJO-136]   |
| JOGE-001 | BULKHEAD: joinery                           | ①     | 2   | [FIJO-212]   |



## Fittings, Furniture and Equipment (FF&E)

| CODE        | DESCRIPTION  | GROUP | QTY | COMMENT   |
|-------------|--|-------|-----|---|
| FIDI-106    | DISPENSER: PPE, disposable gloves, wall mounted          | ②     | 1   | [FIDI-014]  |
| FIDI-231    | DISPENSER: paper towel, wall mounted                     | ②     | 1   | [FIDI-025] to basin   |
| FIDI-256    | DISPENSER: soap, wall mounted                            | ②     | 1   | [FIDI-030] to basin   |
| FIDI-261    | DISPENSER: soap, antimicrobial, wall mounted             | ②     | 1   | [FIDI-031] to basin   |
| FIHR-111    | BRACKET: sharps bin, wall mounted                        | ②     | 1   | [FIHR-016]  |
| FQWS-003    | BIN: sharps, clinical, medium                            | ③     | 1   | [FQCW-044]  |
| FQWS-051    | BIN: general waste, 20L                                  | ③     | 1   | [FQCW-016] to basin   |
| FQWS-053    | BIN: general waste, 50L                                  | ③     | 1   | [FQCW-019] quantity and type of bins to be based on local waste management policies |
| FQWS-273    | BIN: pharmaceutical waste, 50L                           | ③     | 1   | [FQCW-065] quantity and type of bins to be based on local waste management policies |
| HYBA-121    | BASIN: type B, handwashing                               | ①     | 1   | [HYBA-010]  |
| HYBA-303    | SINK: single bowl, with drainer                          | ①     | 1   | [HYBA-069]  |
| HYTP-067    | TAPWARE: basin, tap set, wall mounted, lever handles     | ①     | 1   | [HYTP-037] to basin   |
| HYTP-152    | TAPWARE: sink, mixer, fixture mounted, accessible        | ①     | 1   | [HYTP-040]  |
| MMGE-201    | SCALES: digital, benchtop                                | ③     | 2   | [MMGE-185]  |
| MMLA-172    | CABINET: fume hood, mobile                               | ③     | 1   | [MEEX-013]  |
| MMTR-004.02 | TROLLEY: stainless steel, 900W x 490D x 900H nom, 2 tier | ③     | 1   | [FQSM-016] optional   |



## Engineering Services

| CODE     | DESCRIPTION               | GROUP | QTY | COMMENT  |
|----------|---------------------------|-------|-----|--|
| ELGP-201 | GPO: double, wall mounted | ①     | 4   | [ELGP-208] provision of emergency power to be determined based on service requirements |

| CODE     | DESCRIPTION                      | GROUP | QTY | COMMENT   |
|----------|----------------------------------|-------|-----|---|
| ELSW-001 | SWITCH: light                    | ①     | 3   | [ELBO-015] 1 x general room lighting, 2 x task lights |
| LIFX-108 | LIGHT: task, integral to joinery | ①     | 2   | [LIFX-008] under wall mounted joinery                 |

For guidance on how to use the Room Data Sheet, please visit the [AushFG website](#).