



## Pharmacy - Returns Workstation

<b>Room Code</b>	PHA-RE
<b>Briefed Area</b>	6.00 m <sup>2</sup>
<b>Ceiling Height</b>	2.7 m
<b>Occupancy</b>	1 staff
<b>Hours of Operation</b>	8am to 6pm, daily (may vary depending on service requirements)

**Description** | The Returns Workstation provides workspace to sort and process medication returns from within the hospital that are to be returned to stock or sent for disposal.

**Electrical** | PROTECTION: body protected   
PROTECTION: cardiac protected

**Lighting** | LIGHTING: general   
LIGHTING: colour corrected   
LIGHTING: dimmable   
LIGHTING: indirect

**Nurse Call and Duress** | NURSE CALL SYSTEM: buttons / handset

**HVAC** | AIRCONDITIONING: general   
AIRCONDITIONING: HEPA filtered   
AIRCONDITIONING: positive pressure   
AIRCONDITIONING: negative pressure   
VENTILATION: exhaust   
VENTILATION: natural

### Additional Considerations

- Storage is required to accommodate the returns before they are processed.
- Ready access to refrigerated storage and disposal room is required from this area.
- Printer and telephone facilities to be shared between multiple workstations. A Multifunction device is to be in close proximity to the returns area.
- Ensure adequate lighting over workspace.



## Finishes

CODE	DESCRIPTION	COMMENT
FLVY-101	FLOOR FINISH: vinyl, seamless, standard slip resistance	[FLVY-007]
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010]
WLFI-001	WALL FINISH: paint	[WLWA-004]
CLTI-022.02	CEILING: drop-in tiles, acoustic, prefinished, 600 x 1200	[CLTI-002]
CLCN-041	CORNICE: wall trim fixing, prefinished	[CLCN-009]



## Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIBM-019	WHITEBOARD: fixed, magnetic	②	1	[FIBM-019] optional
FQBS-171	CHAIR: office, ergonomic	③	1	[FQBS-018]
FQDW-134.05	WORKSTATION: straight, adjustable height, 720H nom, 750D x 1800W	③	1	[FQDW-002]
FQSM-211	SHELVING UNIT: mobile, adjustable shelves, 600D x 400W x 2100H nominal	③	2	[FQSM-045]

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ITNE-101	COMPUTER: single display screen, central processing unit (CPU), keyboard and mouse, desktop	3	1	[ITNE-007] may be on wall or desk mounted bracket, an additional screen may be provided depending on project ICT requirements
ITNE-221	INPUT DEVICE: bar code scanner	3	1	[ITNE-003]



## Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-231	GPO: double, emergency power, wall mounted	1	2	[ELGP-223] extent of emergency power to be determined based on service requirements
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	[ITIN-026]

For guidance on how to use the Room Data Sheet, please visit the [AusHFG website](#).