



## Procedure Room

<b>Room Code</b>	PROC
<b>Briefed Area</b>	20.00 m <sup>2</sup>
<b>Ceiling Height</b>	3.0 m
<b>Occupancy</b>	1 patient; up to 4 staff
<b>Hours of Operation</b>	Up to 24 hours (dependent on unit operating hours)

**Description** | The Procedure Room provides a controlled environment and facilities for carrying out procedures that do not require the full facilities of the Operating Suite. This may include suturing of wounds, complex dressings, lumbar puncture, catheterisations. administration of local anaesthesia and use of medical gases in connection with the procedures being performed. General anaesthesia will not be administered in this room.

**Electrical** | PROTECTION: body protected   
PROTECTION: cardiac protected

**Lighting** | LIGHTING: general   
LIGHTING: colour corrected   
LIGHTING: dimmable   
LIGHTING: indirect

**Nurse Call and Duress** | NURSE CALL SYSTEM: buttons / handset

**HVAC** | AIRCONDITIONING: general   
AIRCONDITIONING: HEPA filtered   
AIRCONDITIONING: positive pressure   
AIRCONDITIONING: negative pressure   
VENTILATION: exhaust   
VENTILATION: natural

**Additional Considerations** |

- Lead shielding may be required depending on use of mobile imaging equipment. Treatment of bariatric patients including mobile, bariatric lifter access.
- The ceiling height has been nominally shown at 3000mm, however 2700mm is also acceptable and the height is to be determined based on ceiling mounted equipment and operational requirements.

## Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-114.01	DOOR: hinged, 1 1/2 leaves, 1400 clear opening, solid, standard vision panel	DWGL-033]
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to room side
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection
AFDPR-056.03	DOOR FRAME PROTECTION: full wrap, to 1200H	[DWPR-010] optional, provision and extent dependent on frame material/finish and movement of beds and mobile equipment in adjacent area

## Finishes

CODE	DESCRIPTION	COMMENT
FLVY-101	FLOOR FINISH: vinyl, seamless, standard slip resistance	[FLVY-007] floor finish must be minimum slip rating R10 / Pendulum P3 or agreed equivalent to extend under basin or inset section of non-slip vinyl required

CODE	DESCRIPTION	COMMENT
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, covered	[FLSK-010]
WLFI-001	WALL FINISH: paint	[WLWA-004]
WLFI-011.04	WALL FINISH: vinyl, to 1500 AFFL	[WLWA-020]
WLFI-101	SPLASHBACK: vinyl	[WLWA-007] to basin
CLFS-011	CEILING: flush set, suspended	[CLFS-006]
CLFI-002	CEILING FINISH: paint, clinical areas	[CLFS-006]
CLCN-031	CORNICE: square set	[CLCN-008]



## Joinery

CODE	DESCRIPTION	GROUP	QTY	COMMENT
JOBE-031	BENCH: 600D, laminate	①	1	[FIJO-059]
JOCU-221	CUPBOARD: under bench, double door	①	1	[FIJO-135]
JOGE-001	BULKHEAD: joinery	①	1	[FIJO-212] plasterboard bulkhead also acceptable
JOSH-101	SHELF UNIT: wall mounted, adjustable shelves	①	1	[FIJO-152]



## Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIDI-106	DISPENSER: PPE, disposable gloves, wall mounted	②	1	[FIDI-014]
FIDI-231	DISPENSER: paper towel, wall mounted	②	1	[FIDI-025] to basin
FIDI-241	DISPENSER: alcohol-based hand rub, wall mounted	②	1	[FIDI-001]
FIDI-256	DISPENSER: soap, wall mounted	②	1	[FIDI-030] to basin
FIDI-261	DISPENSER: soap, antimicrobial, wall mounted	②	1	[FIDI-031] to basin
FIHR-026	HOOK: coat, wall mounted	①	2	[FIHR-026] optional
FIHR-101	BRACKET: suction bottle, wall mounted	②	2	[FIHR-019] quantity to suit number of suction outlets
FIHR-111	BRACKET: sharps bin, wall mounted	②	1	[FIHR-016]
FIHR-411	BRACKET: patient monitor, articulated, wall mounted	②	1	[FIHR-011] optional, for cardiac/vital signs monitor
FIRT-051	TRACK: curtain, privacy	①	1	[FIRT-032]
FQBS-203	STOOL: clinical areas, mobile, high	③	1	[FQBS-052]
FQGE-101	CURTAIN: privacy screen	③	1	[FQGE-010]
FQWS-003	BIN: sharps, clinical, medium	③	1	[FQCW-043]
FQWS-051	BIN: general waste, 20L	③	1	[FQCW-016] to basin
FQWS-233	BIN: clinical waste, 50L	③	1	[FQCW-008] optional; type, size and quantity of bins to be determined based on service requirements and waste management policies
HYBA-101	BASIN: type A, handwashing	①	1	[HYBA-009]
HYTP-067	TAPWARE: basin, tap set, wall mounted, lever handles	①	1	[HYTP-037]
ITBU-441	CLOCK: analogue display, electric, wall mounted	①	1	[ITCL-014]
ITNE-076	TELEPHONE: handset, wall mounted	②	1	[ITNE-053]

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ITNE-111	COMPUTER: workstation on wheels (WOW), medical grade, all-in-one computer, keyboard and mouse, on cart	③	1	[ITNE-008+MMGE-164] computer may alternatively be on benchtop or wall mounted; allocation of WOWs across department to be rationalised
ITNE-311	PRINTER: desktop	③	1	[ITNE-023] optional
LIFX-121	LIGHT: procedure, minor, single articulated arm, 1 light head, ceiling mounted	①	1	[LIFX-013]
MMBE-156	TROLLEY: patient, examination	③	1	[MMBE-043]
MMGE-191	CANNISTER: suction bottle	③	2	[MMGE-100] quantity to suit number of suction outlets
MMGE-233	DIAGNOSTIC SET: otoscope and ophthalmoscope, wall mounted	②	1	[MMGE-031] optional, may be portable/mobile on stand
MMPM-021	MONITOR: patient, high acuity	③	1	[MMHA-008] optional
MMTR-071	TROLLEY: equipment, 490W x 490D x 900H nom	③	1	[MMGE-119]



## Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-101	GPO: single, wall mounted	①	1	[ELGP-109] low level, for patient trolley
ELGP-105	GPO: single, wall mounted, cleaner	①	1	[ELGP-110]
ELGP-106	GPO: single, ceiling mounted	①	1	[ELGP-101] to procedure light
ELGP-131	GPO: single, emergency power, wall mounted	①	1	[ELGP-123] optional, for cardiac/vital signs monitor
ELGP-201	GPO: double, wall mounted	①	1	[ELGP-208]
ELPR-071	RCD: residual current device, wall mounted	①	4	[ELPR-006]
ELSW-001	SWITCH: light	①	3	[ELBO-015] 1 x general room lighting, 1 x task light, 1 x examination light
HYDR-201	DIRECT CONNECTION: wastewater, general	①	1	to basin
HYTP-451	DIRECT CONNECTION: water, cold	①	1	to basin tapware
HYTP-453	DIRECT CONNECTION: water, warm	①	1	to basin tapware
ITCL-111	LIGHT: nurse call indicator, ceiling mounted	①	1	outside door
ITCL-191	BUTTON: nurse call, emergency, with cancel, wall mounted	①	1	[ITCL-004] + indicator button & light
ITCL-251	HANDSET: nurse call, patient to staff call	①	1	[ITCL-028] call button on the handset
ITIN-016	OUTLET: data, single RJ45, wall mounted	①	2	[ITIN-016] 1 to telephone, 1 - optional, for cardiac/vital signs monitor
ITIN-026	OUTLET: data, double RJ45, wall mounted	①	2	[ITIN-026]
ITSE-061	BUTTON: security, duress, fixed, wall mounted	①	1	[ITSE-006]
LIFX-108	LIGHT: task, integral to joinery	①	1	[LIFX-008]



## Medical Services Panels and Pendants

CODE	DESCRIPTION	GROUP	QTY	COMMENT
<b>Panel 1</b>				
MMSP-051	MEDICAL SERVICES PANEL: wall mounted	①	1	[MMSP-026]
ELGP-116	GPO: single, on services panel	①	3	[ELGP-105]
ELGP-146	GPO: single, emergency power, on services panel	①	3	[ELGP-122]

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ITCL-133	BUTTON: nurse call, patient to staff call, with cancel, with handset connection point, on services panel	①	1	[ITCL-006] + indicator button & light
ITCL-183	BUTTON: nurse call, staff assist, with cancel, on services panel	①	1	[ITCL-008] + indicator button & light
ITIN-025	OUTLET: data, double RJ45, on services panel	①	1	[ITIN-025]
MGAS-022	OUTLET: medical air, on services panel	①	1	[MGAS-022]
MGAS-032	OUTLET: nitrous oxide (N2O), on services panel	①	1	[MGAS-032] optional, dependent on service requirements
MGAS-042	OUTLET: oxygen (O2), on services panel	①	1	[MGAS-042] quantity dependent on service requirements
MGAS-042	OUTLET: oxygen (O2), on services panel	①	1	[MGAS-042] 1 is optional, quantity dependent on service requirements
MGAS-052	OUTLET: scavenge, on services panel	①	1	[MGAS-053] optional, dependent on service requirements, provide if nitrous oxide required
MGAS-062	OUTLET: suction, on services panel	①	1	[MGAS-062] 1 is optional, quantity dependent on service requirements
MGAS-062	OUTLET: suction, on services panel	①	1	[MGAS-062] quantity dependent on service requirements
MGFP-021	FLOWMETER: medical air	③	1	[MGFP-002]
MGFP-041	FLOWMETER: oxygen	③	1	[MGFP-004] 1 is optional, quantity to suit number of oxygen outlets
MGFP-041	FLOWMETER: oxygen	③	1	[MGFP-004] quantity to suit number of oxygen outlets
MGFP-061	ADAPTER: suction	③	1	[MMGE-002] quantity to suit number of suction outlets
MGFP-061	ADAPTER: suction	③	1	[MMGE-002] 1 is optional, quantity to suit number of suction outlets
MGFP-082	BLENDER: oxygen (O2) and nitrous oxide (N2O)	③	1	[MMMA-011] optional, may be mobile, on trolley or wall mounted

For guidance on how to use the Room Data Sheet, please visit the [AushFG website](#).