

## **Standard Components - Room Data Sheet**

Room Name | Seclusion Room Room Number: SECL

Last modified 01/03/2016

Briefed Area Remarks

15.00

Occupancy

1 patient; 1-2 staff intermittently

Hours of Operation 
✓ 24

Acoustics 
Sou

24 Hours

Description or Special Requirements

Sound attenuation level high, Acoustic privacy is required.

A Seclusion Room provides for the sole confinement of a distressed or agitated person requiring separation for short periods at any hour of the day or night on an involuntary basis. The Seclusion Room will be observable from the Staff Station. An external outlook is desirable. All glazing (including external windows) is to be Grade A safety glass to comply with AS/NZS 2208 and AS 1288, specifically, toughened laminated glass with a standard nominal thickness of 10.38mm, or equivalent approved. Door and joinery hardware should not provide ligature points. Acoustics: Sound attenuation level high; Acoustic privacy is required Additional Design Considerations: - An internal observation window is required - A second room egress door is required

#### **Room Fabrics**

AusHFG code	Description	Material	Finish	Specification	Comments	
1010	Floor finish	Vinyl	Cushioned	Seamless, coved		
3072	Wall finish	Vinyl	Cushioned	Wall vinyl full height		
5010	Ceiling - Plasterboard	Plasterboard	Paint, washable	Flush set, suspended	3000 mm height	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	Equal to 'Acrovyn'	
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to 'Acrovyn'	
9006	Door - 1100mm	Solid Core/ Safety glass	Paint	Single leaf, observation panel	1100mm clear opening, lockable from outside; anti-hang door hardware	
9001	Door - 1100mm	Solid Core	Paint	Single leaf	500mm clear outward opening, optional, additional; anti-hang door hardware	
7001	Windows				external windows double glazed Grade A safety glass with integral venetians	
7045	Observation	Safety glass	Powdercoat	Internal window	double glazed with integral venetians; Grade A safety glass	
7015	Observation	Safety glass	Clear	Through door/s	double glazed with integral venetians; Grade A safety glass	
6010	Cornice	Plasterboard	Paint	90mm to match ceiling finish		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		

### Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1252	Blind - Venetian integral	1		to windows & doors, controls outside room
FF-13350	Mattress - foam	3	1	foam, on floor

Fixtures, Equipment and associated Services







# **Standard Components - Room Data Sheet**

Room Name | Seclusion Room | Room Number: SECL

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Тар	Dns	Gas	Comments
FE-7300	Camera - CCTV security	1	1	V								in ceiling dome, vandal resistant

### **Service Requirements**

AusHFG code	Description	Comments
S-5000	Airconditioning	
S-6030	Special: downlights	over bed/ trolley
S-6060	Special: night lights	

### **Services**

AusHFG code	Description	Group	Qty	Comments
S-9060	GPO: Special: for equipment	1	1	TV, ceiling
S-5000	Airconditioning	1	1	
S-1087	Special: reading, vandal proof	1	1	may be ceiling recessed
S-6060	Special: night lights	1	1	



