



Shower - Accessible

Room Code	SHAC
Briefed Area	4.00 m ²
Ceiling Height	2.7 m
Occupancy	1 patient; 1-2 staff assisting as required
Hours of Operation	Up to 24 hours (dependent on unit operating hours)

Description | The Shower - Accessible provides an enclosed, lockable room with an accessible shower, hand washing basin and changing area for use by patients, visitors or staff with disabilities (with or without assistance).

Electrical | PROTECTION: body protected
PROTECTION: cardiac protected

Lighting | LIGHTING: general
LIGHTING: colour corrected
LIGHTING: dimmable
LIGHTING: indirect

Nurse Call and Duress | NURSE CALL SYSTEM: buttons / handset

HVAC | AIRCONDITIONING: general
AIRCONDITIONING: HEPA filtered
AIRCONDITIONING: positive pressure
AIRCONDITIONING: negative pressure
VENTILATION: exhaust
VENTILATION: natural

Additional Considerations

- The room layout and all fixtures, furniture and equipment (FF&E) are to comply with AS 1428.1 and NZ 4121.
- Signage with tactile Braille nominating 'All Gender Accessible Shower' required to room.
- If the Shower - Accessible is located in a patient care area for use by patients, the nurse call system should be included and emergency release door hardware should be installed to allow staff access in emergency situations. An operational model for responding to calls from staff/patients will be needed to support the inclusion of a nurse call system.
- Facilities for hand hygiene and PPE to be available nearby if this room is for patient use.
- If the Shower - Accessible is to be dedicated for use by staff, access control (e.g. a swipe card reader) may be required if this room is provided in a public area or patient care area.
- The entrance to the room is to be flush with the adjoining floor for access in commode chairs/wheelchairs or with other assistive devices.
- Mobile duress coverage is to be assessed and planned at a department level and coverage is to suit local security and WHS policies and operational service requirements.



Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-003.01	DOOR: hinged, 1 leaf, 900 clear opening, solid	[DWSC-003] with privacy latch, emergency release required if inward opening door
AFDPR-001.01	DOOR PROTECTION: kickplate, to 300H	[DWPR-001] to room side
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection
ITSE-261	READER: security, access control, proximity card, wall mounted	[ITSE-038] optional, may be provided if room is for staff use and located in a public / patient treatment area



Finishes

CODE	DESCRIPTION	COMMENT
FLVY-113	FLOOR FINISH: vinyl, seamless, non-slip, wet area	[FLVY-009] to be suitable for bare feet; tiles are also acceptable
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010] tiles acceptable if tiled floor is provided
WLFI-011.07	WALL FINISH: vinyl, full height	[WLWA-019] tiles are also acceptable
CLFS-013	CEILING: flush set, suspended, moisture resistant	[CLFS-009] moisture resistant drop-in ceiling tiles are also acceptable
CLFI-002	CEILING FINISH: paint, clinical areas	[CLFS-009]
CLCN-031	CORNICE: square set	[CLCN-008] wall trim fixing acceptable if drop-in ceiling tiles are provided



Joinery

CODE	DESCRIPTION	GROUP	QTY	COMMENT
JOSH-401	SHELF: wall mounted, laminate	1	1	[FIJO-194]



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIDI-281	HOLDER: soap/shampoo, wall mounted	1	1	[FIDI-049] soap dispenser is also acceptable, to shower
FIHR-026	HOOK: coat, wall mounted	1	2	[FIHR-026]
FIRT-061	TRACK: curtain, shower	1	1	[FIRT-033] optional, provision to be confirmed to suit local IPC policies and operational models for cleaning/replacement of curtains
FIRT-166	GRAB RAIL: shower, T-shaped, vertical and horizontal	1	1	[FIRT-045] with bracket for hand held accessible shower mounted on vertical rail
FQGE-102	CURTAIN: shower	3	1	[FQGE-011] optional, provision to be confirmed to suit local IPC policies and operational models for cleaning/replacement of curtains
HYSH-057	SHOWER: hand-held, connection on wall, bracket on vertical wall mounted rail, accessible	1	1	[HYTP-045]
HYTP-251	TAPWARE: shower, mixer	1	1	[HYTP-039]
MMGE-024	CHAIR: shower	3	1	[MMGE-024] wall mounted fold-down bench seat is also acceptable



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELSW-001	SWITCH: light	1	1	[ELBO-015] IPX4 rating required
HYDR-021	DRAIN: floor waste, round	1	1	[HYDR-004]
HYTP-451	DIRECT CONNECTION: water, cold	1	1	1 to shower head
HYTP-453	DIRECT CONNECTION: water, warm	1	1	1 to shower head
ITCL-111	LIGHT: nurse call indicator, ceiling mounted	1	1	outside door, placement to ensure visibility along paths of travel; optional, to be provided if room located in a patient treatment area for use by patients

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ITCL-122	BUTTON: nurse call, patient to staff call, with cancel, wall mounted, wet area	①	1	[ITCL-006] IPX4 rating required; optional, to be provided if room located in a patient treatment area for use by patients
ITCL-182	BUTTON: nurse call, staff assist, with cancel, wall mounted, wet area	①	1	[ITCL-008] IPX4 rating required; optional, to be provided if room located in a patient treatment area for use by patients
ITCL-192	BUTTON: nurse call, emergency, with cancel, wall mounted, wet area	①	1	[ITCL-004] IPX4 rating required; optional, to be provided if room located in a patient treatment area for use by patients

For guidance on how to use the Room Data Sheet, please visit the [AushFG website](#).