

**Room Name** | Shower - Accessible, 4m2

**Room Number:** SHD

**Last modified** 01/03/2016

**Briefed Area** 4.00

**Remarks**

**Occupancy** 1 patient; 1-2 staff assisting as required

**Hours of Operation** ☒ 24 Hours

**Acoustics**

Sound attenuation level high, Acoustic privacy is required.

**Description or Special Requirements**

The Shower - Accessible is a room containing a shower for use by people with disabilities, either independently or with nurse assistance. The Room is to comply with AS 1428. Acoustics: Sound attenuation level - high; Acoustic privacy required. Body Protected electrical area Additional Design Considerations: - Access is required for commode chairs/ wheelchairs - The floor must not have a raised hob additional text - The door will require escape hardware to allow staff access in an emergency

## Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1025	Floor finish	Vinyl, non slip	Studded	Seamless, coved	Default = vinyl; tiles also acceptable
3000	Wall finish	Paint	Acrylic, washable		
3070	Wall finish	Vinyl	Prefinished	Wall vinyl full height	to wet areas; Default = vinyl; tiles also acceptable
5023	Ceiling - Plasterboard	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200	
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame	Equal to Acrovyn
9001	Door - 1100mm	Solid Core	Paint	Single leaf	910mm clear; Outward opening; privacy latch; emergency release
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	Default = vinyl; tiles for tiled floor

## Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1002	Bench seat - fold up/down	1	1	reinforced for up to 150kg weight
FF-20650	Soap / shampoo holder	1	1	
FF-23700	Towel rail	1	1	
FF-3400	Coathook	1	2	1 at 1200H for wheelchair users
FF-4800	Curtain track - shower (90deg)	1	1	
FF-5300	Curtain - shower	3	1	
FF-6152	Dispenser - disposable glove	2	1	
FF-8450	Grab rail - Shower	1	1	L shaped, optional
FF-8450	Grab rail - Shower	1	1	T bar

## Fixtures, Equipment and associated Services

Room Name | Shower - Accessible, 4m2

Room Number: SHD

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-47400	Shower - hand-held	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
FE-40412	TAP - COLD		1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-40413	TAP - HOT		1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

## Service Requirements

AusHFG code	Description	Comments
S-5000	Airconditioning	
S-5019	Exhaust	to rangehood
S-6000	General fluorescent	

## Services

AusHFG code	Description	Group	Qty	Comments
S-4033	Floor waste	1	1	
S-5000	Airconditioning	1	1	
S-5019	Exhaust	1	1	to rangehood
S-6000	General fluorescent	1	1	
S-6200	Light switches	1	1	
S-8000	Patient/ Staff call	1	1	+ indicator button & light
S-8010	Staff/ Nurse assist call	1	1	+ indicator button & light
S-8080	Emergency call	1	1	+ indicator button & light
S-1951	Staff assist call	1	1	+ indicator button & light