

Room Name | Shower - Patient

Room Number: SHPT

Last modified	01/03/2016
Briefed Area	4.00
Remarks	
Occupancy	1 patient; 1-2 staff assisting as required
Hours of Operation	<input checked="" type="checkbox"/> 24 Hours
Acoustics	Sound attenuation level high, Acoustic privacy is required.
Description / Special Requirements	<p>The Patient Shower is a room containing a shower and a handbasin for patients to shower or wash, either independently or with nurse assistance. This room may be provided in an Emergency Department or other units where an additional shower is required. Ensuites are generally preferred in inpatient environments. Acoustics: Sound attenuation level - high; Acoustic privacy required. Body Protected electrical area. Additional Design Considerations:- Access is required for commode chairs- The floor must not have a raised hob- The door will require escape hardware to allow staff access in an emergency</p>

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
2526	Floor finish	Vinyl	Non-slip	Seamless coved	Suitable for barefeet. Tiles also acceptable.
3000	Wall finish	Paint	Acrylic, washable		
3070	Wall finish	Vinyl	Prefinished	Wall vinyl full height	to wet areas; tiles also acceptable
5023	Ceiling - Plasterboard	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200	
9001	Door - 1100mm	Solid Core	Paint	Single leaf	910mm clear; outward opening; privacy latch; emergency release
2530	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	
2529	Door protection	Composite	Prefinished PVC	To door frame	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	Or tiles for a tiled floor.

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-13700	Mirror	1	1	
FF-20650	Soap / shampoo holder	1	1	
FF-2300	Chair - shower	3	1	Or commode chair or combined shower/ commode chair, optional.
FF-23700	Towel rail	1	1	with grab rail strength/ fixings
FF-3400	Coathook	1	2	
FF-4800	Curtain track - shower (90deg)	1	1	Optional, depends on Infection Control Policy
FF-5300	Curtain - shower	3	1	Optional, depends on Infection Control Policy
FF-6154	Dispenser - paper/ hand towel	2	1	
FF-6156	Dispenser - soap	2	2	1 x basin. 1 x shower (optional).

Room Name | Shower - Patient

Room Number: SHPT

AusHFG code	Description	Group	Qty	Comments
FF-8450	Grab rail - Shower	1	1	Combined with hand held shower.
FF-5824	Waste bin - general	3	1	

Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-47400	Shower - hand-held	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Tapware: mixer, wall mounted, shower.
FE-5603	Basin - ensuite	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
FE-40406	Tapware - shower mixer	1	1	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Service Requirements

AusHFG code	Description	Comments
S-9040	Body protected	
S-5015	Ventilation	
S-5019	Exhaust	to rangehood
S-6000	General fluorescent	

Services

AusHFG code	Description	Group	Qty	Comments
S-9001	GPO: Double	1	1	
S-9040	Body protected	1	1	
S-4033	Floor waste	1	1	
S-5015	Ventilation	1	1	
S-5019	Exhaust	1	1	to rangehood
S-6000	General fluorescent	1	1	
S-1983	General fluorescecent downlights	1	1	
S-8000	Patient/ Staff call	1	1	+ indicator button & light
S-8080	Emergency call	1	1	+ indicator button & light
S-1951	Staff assist call	1	1	+ indicator button & light