



Shower - Patient

Room Code	SHPT
Briefed Area	4.00 m ²
Ceiling Height	2.7 m
Occupancy	1 patient; 1-2 staff assisting as required
Hours of Operation	Up to 24 hours (dependent on unit operating hours)

Description | The Shower - Patient provides an enclosed, lockable room with a shower, hand washing basin and changing area for use by patients (with or without assistance).

Electrical | PROTECTION: body protected
PROTECTION: cardiac protected

Lighting | LIGHTING: general
LIGHTING: colour corrected
LIGHTING: dimmable
LIGHTING: indirect

Nurse Call and Duress | NURSE CALL SYSTEM: buttons / handset

HVAC | AIRCONDITIONING: general
AIRCONDITIONING: HEPA filtered
AIRCONDITIONING: positive pressure
AIRCONDITIONING: negative pressure
VENTILATION: exhaust
VENTILATION: natural

Additional Considerations

- Signage with tactile Braille nominating 'All Gender Patient Shower' required to room.
- Emergency release door hardware should be installed to allow staff access in emergency situations.
- The entrance to the room is to be flush with the adjoining floor for access in commode chairs/wheelchairs or with other assistive devices.
- A shower curtain and track are noted as optional, and inclusion of the curtain and track, or track only (to support flexibility for future provision of curtains) is to be confirmed at project level to suit local work, health and safety (WHS), and IPC policies. Where curtains and tracks are provided, operational models for cleaning and maintenance must be considered.
- Mobile duress coverage is to be assessed and planned at a department level and coverage is to suit local security and WHS policies and operational service requirements.
- A power outlet to support grooming, such as shaving and drying hair, is shown as optional. Local policies around provision and maintenance of electrical outlets in wet areas are to be confirmed to inform inclusion of a power outlet within the ensuite. Where provided, the outlet is to be located to comply with Australian and New Zealand Standards regarding the minimum distance from any water sources (i.e. basin spout and shower).



Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-003.01	DOOR: hinged, 1 leaf, 900 clear opening, solid	[DWSC-003] with privacy latch, emergency release required if inward opening door
AFDPR-001.01	DOOR PROTECTION: kickplate, to 300H	[DWPR-001] to room side
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection



Finishes

CODE	DESCRIPTION	COMMENT
FLVY-114	FLOOR FINISH: vinyl, seamless, non-slip, wet area, barefoot	[FLVY-009] tiles are also acceptable
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010] tiles acceptable if tiled floor is provided
WLFI-011.07	WALL FINISH: vinyl, full height	[WLWA-019] tiles are also acceptable
CLFS-013	CEILING: flush set, suspended, moisture resistant	[CLFS-009] moisture resistant drop-in ceiling tiles are also acceptable
CLFI-002	CEILING FINISH: paint, clinical areas	[CLFS-009]
CLCN-031	CORNICE: square set	[CLCN-008] wall trim fixing acceptable if drop-in ceiling tiles are provided



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIBM-102	MIRROR: fixed, safety glass, frameless	①	1	[FIBM-006]
FIDI-231	DISPENSER: paper towel, wall mounted	②	1	[FIDI-025]
FIDI-256	DISPENSER: soap, wall mounted	②	1	[FIDI-030] to basin
FIDI-281	HOLDER: soap/shampoo, wall mounted	①	1	[FIDI-049] soap dispenser is also acceptable, to shower
FIHR-026	HOOK: coat, wall mounted	①	2	[FIHR-026]
FIRT-061	TRACK: curtain, shower	①	1	[FIRT-033] optional, provision to be confirmed to suit local IPC policies and operational models for cleaning/replacement of curtains
FIRT-166	GRAB RAIL: shower, T-shaped, vertical and horizontal	①	1	[FIRT-045] with bracket for hand held shower mounted on vertical rail
FIRT-206	RAIL: towel, wall mounted	①	1	[FIRT-016] with grab rail strength/fixings
FQGE-102	CURTAIN: shower	③	1	[FQGE-011] optional, provision to be confirmed to suit local IPC policies and operational models for cleaning/replacement of curtains
FQWS-051	BIN: general waste, 20L	③	1	[FQCW-016]
HYBA-141	BASIN: type C, handwashing	①	1	[HYBA-011] with detachable shroud to pipework; location of thermostatic mixing valve to be determined based on ability to share with nearby basins
HYSH-056	SHOWER: hand-held, connection on wall, bracket on vertical wall mounted rail	①	1	[HYTP-020]
HYTP-051	TAPWARE: basin, mixer, fixture mounted	①	1	[HYTP-036] selection of basin and tapware to be coordinated to ensure compatibility
HYTP-251	TAPWARE: shower, mixer	①	1	[HYTP-039]
MMGE-024	CHAIR: shower	③	1	[MMGE-024] or commode chair, optional



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-201	GPO: double, wall mounted	①	1	[ELGP-208] optional, to support grooming (i.e. shaving, hair drying, etc.); inclusion to be informed by local policies on the provision and maintenance of electrical outlets in wet areas

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELSW-001	SWITCH: light	①	1	[ELBO-015] IPX4 rating required
HYDR-021	DRAIN: floor waste, round	①	1	[HYDR-004]
HYDR-201	DIRECT CONNECTION: wastewater, general	①	1	to basin
HYTP-451	DIRECT CONNECTION: water, cold	①	2	1 to basin tapware, 1 to shower head
HYTP-453	DIRECT CONNECTION: water, warm	①	2	1 to basin tapware, 1 to shower head
ITCL-122	BUTTON: nurse call, patient to staff call, with cancel, wall mounted, wet area	①	1	[ITCL-008] IPX4 rating required
ITCL-182	BUTTON: nurse call, staff assist, with cancel, wall mounted, wet area	①	1	[ITCL-006] IPX4 rating required
ITCL-192	BUTTON: nurse call, emergency, with cancel, wall mounted, wet area	①	1	[ITCL-004] IPX4 rating required

For guidance on how to use the Room Data Sheet, please visit the [AusHFG website](#).