



## Shower - Staff

<b>Room Code</b>	SHST
<b>Briefed Area</b>	3.00 m <sup>2</sup>
<b>Ceiling Height</b>	2.7 m
<b>Occupancy</b>	1 staff intermittently
<b>Hours of Operation</b>	Up to 24 hours (dependent on unit operating hours)

**Description** | The Shower - Staff provides an enclosed, lockable room with a shower and changing area for use by staff.

<b>Electrical</b>	PROTECTION: body protected	<input type="checkbox"/>	<b>HVAC</b>	AIRCONDITIONING: general	<input type="checkbox"/>
	PROTECTION: cardiac protected	<input type="checkbox"/>		AIRCONDITIONING: HEPA filtered	<input type="checkbox"/>
<b>Lighting</b>	LIGHTING: general	<input checked="" type="checkbox"/>	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	
	LIGHTING: colour corrected	<input type="checkbox"/>	AIRCONDITIONING: negative pressure	<input type="checkbox"/>	
	LIGHTING: dimmable	<input type="checkbox"/>	VENTILATION: exhaust	<input checked="" type="checkbox"/>	
	LIGHTING: indirect	<input type="checkbox"/>	VENTILATION: natural	<input checked="" type="checkbox"/>	
<b>Nurse Call and Duress</b>	NURSE CALL SYSTEM: buttons / handset	<input type="checkbox"/>			

### Additional Considerations

- Access control (e.g. a swipe card reader) may be required if this room is provided in a public area or patient care area.
- The Shower - Staff may be allocated as gender specific or all gender.
- A shower curtain and track are noted as optional, and inclusion of the curtain and track, or track only (to support flexibility for future provision of curtains) is to be confirmed at project level to suit local work, health and safety (WHS), and IPC policies. Where curtains and tracks are provided, operational models for cleaning and maintenance must be considered.
- Mobile duress coverage is to be assessed and planned at a department level and coverage is to suit local security and WHS policies and operational service requirements.



## Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-002.01	DOOR: hinged, 1 leaf, 850 clear opening, solid	[DWSC-001] with privacy latch, emergency release required if inward opening door
AFDPR-001.01	DOOR PROTECTION: kickplate, to 300H	[DWPR-001] to room side
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection
ITSE-261	READER: security, access control, proximity card, wall mounted	[ITSE-038] optional, may be provided if room located in a public / patient treatment area



## Finishes

CODE	DESCRIPTION	COMMENT
FLVY-114	FLOOR FINISH: vinyl, seamless, non-slip, wet area, barefoot	[FLVY-009] tiles are also acceptable
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010] tiles acceptable if tiled floor is provided

CODE	DESCRIPTION	COMMENT
WLFI-011.07	WALL FINISH: vinyl, full height	[WLWA-019] tiles are also acceptable
CLFS-013	CEILING: flush set, suspended, moisture resistant	[CLFS-009] moisture resistant drop-in ceiling tiles are also acceptable
CLFI-002	CEILING FINISH: paint, clinical areas	[CLFS-009]
CLCN-031	CORNICE: square set	[CLCN-008] wall trim fixing acceptable if drop-in ceiling tiles are provided



## Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIBM-102	MIRROR: fixed, safety glass, frameless	①	1	[FIBM-006]
FIDI-256	DISPENSER: soap, wall mounted	②	1	[FIDI-030]
FIDI-281	HOLDER: soap/shampoo, wall mounted	①	1	[FIDI-049] optional
FIGE-023	BENCH SEAT: fixed, indoor, wet area, wall mounted	①	1	[FIGE-003]
FIHR-026	HOOK: coat, wall mounted	①	1	[FIHR-026]
FIRT-061	TRACK: curtain, shower	①	1	[FIRT-033] optional, provision to be confirmed to suit local IPC policies and operational models for cleaning/replacement of curtains
FIRT-206	RAIL: towel, wall mounted	①	1	[FIRT-016]
FQGE-102	CURTAIN: shower	③	1	[FQGE-011] optional, provision to be confirmed to suit local IPC policies and operational models for cleaning/replacement of curtains
HYSH-001	SHOWER: fixed rose, wall mounted	①	1	[HYTP-018]
HYTP-251	TAPWARE: shower, mixer	①	1	[HYTP-039]



## Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELSW-001	SWITCH: light	①	1	[ELBO-015]
HYDR-021	DRAIN: floor waste, round	①	1	[HYDR-004]

For guidance on how to use the Room Data Sheet, please visit the [AushFG website](#).