



Store - Accountable Drugs

Room Code	STAD
Briefed Area	7.50 m ²
Ceiling Height	2.7 m
Occupancy	1-2 staff intermittently
Hours of Operation	24 hours

Description | The Store Accountable Drugs is a strongroom located within the Pharmacy Unit for the storage of accountable (Schedule 8) drugs and medications and provides a secure caged area for assembling orders.

Electrical

PROTECTION: body protected	<input type="checkbox"/>
PROTECTION: cardiac protected	<input type="checkbox"/>

HVAC

AIRCONDITIONING: general	<input checked="" type="checkbox"/>
AIRCONDITIONING: HEPA filtered	<input type="checkbox"/>
AIRCONDITIONING: positive pressure	<input type="checkbox"/>
AIRCONDITIONING: negative pressure	<input type="checkbox"/>
VENTILATION: exhaust	<input type="checkbox"/>
VENTILATION: natural	<input type="checkbox"/>

Lighting

LIGHTING: general	<input checked="" type="checkbox"/>
LIGHTING: colour corrected	<input type="checkbox"/>
LIGHTING: dimmable	<input type="checkbox"/>
LIGHTING: indirect	<input type="checkbox"/>

Nurse Call and Duress

NURSE CALL SYSTEM: buttons / handset	<input type="checkbox"/>
--------------------------------------	--------------------------

Additional Considerations

- This room is to comply with jurisdictional legislation and public health facility policy, including any special provisions for refrigerated medicines.
- The strong room should be designed in collaboration with an expert security consultant with assessment of the risks for the particular site.
- The strong room should be independent of the rest of the building structure with no beams or columns passing through the ceiling, walls or floor.
- The ceiling walls and floor should be built utilising suitable construction methods, e.g. reinforced concrete or steel plate modular forms (the wall thickness shown in this Standard Component is indicative only).
- A gate door is to be provided for security when the main door is open. The security door should be torch and drill resistant, fitted with an appropriate locking mechanism incorporating duress features and an internal release mechanism in case persons are trapped within.
- The strongroom will require adequate ventilation and a torch and drill resistant breather tube must be fitted to comply with fire regulations.
- Security monitoring and detection equipment should be incorporated into the alarm system, to detect any attack on the structure.
- A telephone should be installed for staff safety

Doors and Windows

CODE	DESCRIPTION	COMMENT
DOSP-121	DOOR: hinged, 1 leaf, 900 clear opening, mesh grille, strong room	[DWGE-002] inner door; access and door release controls to be determined based on security strategy
ITSE-261	READER: security, access control, proximity card, wall mounted	[ITSE-038]
DOSP-101	DOOR: hinged, 1 leaf, 900 clear opening, solid, strong room	[DWGE-003] outer door; access and door release controls to be determined based on security strategy



Finishes

CODE	DESCRIPTION	COMMENT
FLVY-101	FLOOR FINISH: vinyl, seamless, standard slip resistance	[FLVY-007]
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010]
WLFI-001	WALL FINISH: paint	[WLWA-004]
WLFI-011.06	WALL FINISH: vinyl, to 2100 AFFL	[WLWA-023] extent dependent on type and height storage solution
CLFS-011	CEILING: flush set, suspended	[CLFS-006]
CLFI-002	CEILING FINISH: paint, clinical areas	[CLFS-006]
CLCN-031	CORNICE: square set	[CLCN-008]



Joinery

CODE	DESCRIPTION	GROUP	QTY	COMMENT
JOGE-001	BULKHEAD: joinery	①	1	[FIJO-212]
JOSH-101	SHELF UNIT: wall mounted, adjustable shelves	①	1	[FIJO-152]



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FQBS-172	CHAIR: office, ergonomic, high	③	1	[FQBS-019]
FQDW-131.03	WORKSTATION: straight, adjustable height, 720H nom, 600D x 1500W	③	1	[FQDW-051]
FQSM-063	PEDESTAL: mobile, 660H nominal, 3 equal drawers	③	1	[FQSM-007]
FQSM-202	SHELVING UNIT: mobile, adjustable shelves, 400D x 600W x 2100H nominal	③	3	[FQSM-048] type and quantity of storage options to be determined based on service requirements
ITNE-071	TELEPHONE: handset, desktop	③	1	[ITNE-049]
ITNE-101	COMPUTER: single display screen, central processing unit (CPU), keyboard and mouse, desktop	③	1	[ITNE-007] may be on wall or desk mounted bracket, an additional screen may be provided depending on project ICT requirements
ITNE-221	INPUT DEVICE: bar code scanner	③	1	[ITNE-003]
ITNE-316	PRINTER: labels, small, desktop	③	1	[FQGE-093]
ITSE-121	CAMERA: security, CCTV, indoor, dome, ceiling mounted	①	1	[ITSE-012+FIHR-002]
MMPH-024	FRIDGE: medication/vaccine, 1000L nom, double door	③	1	[MMGE-034] optional



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-201.01	GPO: double, wall mounted, horizontal	①	3	[ELGP-208] extent of emergency power to be determined based on service requirements
ELGP-231.01	GPO: double, emergency power, wall mounted, horizontal	①	1	[ELGP-223] optional, for refrigerator if provided
ELSW-001	SWITCH: light	①	2	[ELBO-015] 1 x general room lighting, 1 x task light

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ITIN-016	OUTLET: data, single RJ45, wall mounted	①	1	[ITIN-016] optional, temperature monitoring, for refrigerator if provided
ITIN-026	OUTLET: data, double RJ45, wall mounted	①	1	[ITIN-026]
ITSE-216	SENSOR: security, vibration detection, for alarm, wall mounted	①	1	[ITSE-003]
LIFX-108	LIGHT: task, integral to joinery	①	1	[LIFX-008] under wall mounted joinery
MEGE-015	PORT: ventilation, secure room	①	2	[MEGE-015]

For guidance on how to use the Room Data Sheet, please visit the [AusHFG website](#).