



## Store - Equipment, 14m<sup>2</sup>

<b>Room Code</b>	STEQ-14
<b>Briefed Area</b>	14.00 m <sup>2</sup>
<b>Ceiling Height</b>	2.7 m
<b>Occupancy</b>	1-2 staff intermittently
<b>Hours of Operation</b>	Up to 24 hours (dependent on unit operating hours)

**Description** | A secure room for the storage and recharging of mobile equipment when not in use.

<b>Electrical</b>	PROTECTION: body protected	<input type="checkbox"/>	<b>HVAC</b>	AIRCONDITIONING: general	<input checked="" type="checkbox"/>
	PROTECTION: cardiac protected	<input type="checkbox"/>		AIRCONDITIONING: HEPA filtered	<input type="checkbox"/>
<b>Lighting</b>	LIGHTING: general	<input checked="" type="checkbox"/>	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	
	LIGHTING: colour corrected	<input type="checkbox"/>	AIRCONDITIONING: negative pressure	<input type="checkbox"/>	
	LIGHTING: dimmable	<input type="checkbox"/>	VENTILATION: exhaust	<input type="checkbox"/>	
	LIGHTING: indirect	<input type="checkbox"/>	VENTILATION: natural	<input type="checkbox"/>	
<b>Nurse Call and Duress</b>	NURSE CALL SYSTEM: buttons / handset	<input type="checkbox"/>			

### Additional Considerations

- Clear space is required for parking mobile equipment including IV poles, wheelchairs, patient transfer equipment, trolleys and commode chairs.
- Hooks may be provided for hanging equipment and rails may be provided to mount equipment whilst recharging.
- Minimum and maximum shelving heights to suit local WHS and infection control policies, as well as fire safety requirements (e.g. the top of stored products is to be no nearer than 500mm to sprinkler deflectors).



## Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-104.01	DOOR: hinged, 1 1/2 leaves, 1400 clear opening, solid	[DWSC-021]
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to room side



## Finishes

CODE	DESCRIPTION	COMMENT
FLVY-101	FLOOR FINISH: vinyl, seamless, standard slip resistance	[FLVY-007]
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010]
WLFI-001	WALL FINISH: paint	[WLWA-004]
WLFI-011.04	WALL FINISH: vinyl, to 1500 AFFL	[WLWA-020] height dependent on type and height of mobile equipment, crash rails are also acceptable
CLTI-021.02	CEILING: drop-in tiles, prefinished, 600 x 1200	[CLTI-008]

CODE	DESCRIPTION	COMMENT
CLCN-041	CORNICE: wall trim fixing, prefinished	[CLCN-009]



## Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	[FIBM-019] optional
FIHR-030	HOOK: equipment, patient slide, wall mounted	1	4	[FIHR-030] optional, provision dependent on service requirements, to be rated for minimum 10kg per hook if provided
FIRT-231	RAIL: equipment charging, vertical, wall mounted	1	2	[FIRT-012] optional, provision dependent on service requirements
FQSN-204	SHELVING UNIT: floor standing, adjustable shelves, 400D x 900W x 2100H nominal	3	3	[FQSN-082] adjustable shelving; type and quantity of storage options to be determined based on service requirements



## Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-201	GPO: double, wall mounted	1	13	[ELGP-208] type, quantity and configuration of outlets dependent on operational and equipment requirements
ELSW-001	SWITCH: light	1	1	[ELBO-015]

For guidance on how to use the Room Data Sheet, please visit the [AusHFG website](#).