

Standard Components - Room Data Sheet

Room Name Store - Equipment, 20m2 **Room Number: STEQ-20**

Last modified 01/03/2016

Briefed Area Remarks 20.00

Occupancy

1 - 2 intermittently

Hours of Operation Acoustics 24 Hours

Description / Special Requirements

The Equipment Store is used for the storage of medical equipment when not in use and recharging of electrical items. Space is required for parking of mobile equipment including IV poles, wheelchairs, lifting equipment, trolleys, cradles and commode chairs for the Unit. Hooks will be required for hanging equipment.

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved	
3000	Wall finish	Paint	Acrylic, washable		
2537	Wall protection			Crash rail at 900 AFFL	
5030	Ceiling - Plasterboard	Plasterboard	Prefinished	Drop-in tiles, 600x1200	
9110	Door - 1400mm	Solid Core	Paint	1 1/2 leaf	1400mm clear opening; lockable
2530	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL	
2529	Door protection	Composite	Prefinished PVC	To door frame	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH	

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-13660	Metal shelving - 900x400x2100	3	5	
FF-24200	Wheelchair	3	0	
FF-6140	Diagnostic set - portable	3	0	
FF-7300	Rail - equipment	1	1	
FF-7400	Trolley - equipment	3	0	
FF-23560	Toilet frame	3	0	
FF-3500	Trolley collection	3	0	
FF-5863	Walking frame - pick up	3	0	
FF-24190	Walking frame - with wheels	3	0	
FF-7200	Hooks - equipment, on mounting plate	1	1	
FF-21020	Sphygmomanometer - portable	3	0	
FF-24405	Whiteboard - magnetic	2	1	
FF-3700	Chair - commode	3	0	







Standard Components - Room Data Sheet

Room Name | Store - Equipment, 20m2 | Room Number: STEQ-20

AusHFG code	Description		Qty	Comments	
FF-11000	IV pole - mobile	3	0		

Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Тар	Dns	Gas	Comments
FE-19300	ECG machine	3	0									
FE-28301	Pump - infusion, single	3	0									
FE-29300	Pump - patient feeding	3	0									
FE-39550	Pump - PCA	3	0									
FE-53850	Pump - syringe	3	0									
FE-19750	Scales - electronic, standing	3	0									
FE-4350	Scanner - bladder	3	0									
FE-51400	Spirometer	3	0									

Service Requirements

AusHFG code	Description	Comments
S-5000	Airconditioning	
S-6000	General fluorescent	

Services

AusHFG code	Description	Group	Qty	Comments
S-9001	GPO: Double	1	5	
S-5000	Airconditioning	1	1	
S-6000	General fluorescent	1	1	
S-6200	Light switches	1	1	



