



## Store - General

<b>Room Code</b>	STGN
<b>Briefed Area</b>	9.00 m <sup>2</sup>
<b>Ceiling Height</b>	2.7 m
<b>Occupancy</b>	1-2 staff intermittently
<b>Hours of Operation</b>	Up to 24 hours (dependent on unit operating hours)

**Description** | A secure room for the storage of general supplies used within the department.

<b>Electrical</b>	PROTECTION: body protected	<input type="checkbox"/>	<b>HVAC</b>	AIRCONDITIONING: general	<input checked="" type="checkbox"/>
	PROTECTION: cardiac protected	<input type="checkbox"/>		AIRCONDITIONING: HEPA filtered	<input type="checkbox"/>
<b>Lighting</b>	LIGHTING: general	<input checked="" type="checkbox"/>	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	
	LIGHTING: colour corrected	<input type="checkbox"/>	AIRCONDITIONING: negative pressure	<input type="checkbox"/>	
	LIGHTING: dimmable	<input type="checkbox"/>	VENTILATION: exhaust	<input type="checkbox"/>	
	LIGHTING: indirect	<input type="checkbox"/>	VENTILATION: natural	<input type="checkbox"/>	
<b>Nurse Call and Duress</b>	NURSE CALL SYSTEM: buttons / handset	<input type="checkbox"/>			

- Additional Considerations**
- Facilities to support restocking workflows, including the use of barcode systems, to be considered to suit operational requirements.
  - Minimum and maximum shelving heights to suit local WHS and infection control policies, as well as fire safety requirements (e.g. the top of stored products is to be no nearer than 500mm to sprinkler deflectors).



## Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-013.01	DOOR: hinged, 1 leaf, 900 clear opening, solid, standard vision panel	[DWGL-005]
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to room side
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection



## Finishes

CODE	DESCRIPTION	COMMENT
FLVY-101	FLOOR FINISH: vinyl, seamless, standard slip resistance	[FLVY-007]
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010]
WLFI-001	WALL FINISH: paint	[WLWA-004]
CLTI-021.02	CEILING: drop-in tiles, prefinished, 600 x 1200	[CLTI-008]
CLCN-041	CORNICE: wall trim fixing, prefinished	[CLCN-009]



## Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIBM-019	WHITEBOARD: fixed, magnetic	②	1	[FIBM-019] optional
FIHR-151	PANEL: storage baskets, wall mounted	②	3	[FIHR-033] optional
FQGE-112	BASKET: storage, for wall mounted panel, small	③	15	[FQSN-007] optional
FQSN-204	SHELVING UNIT: floor standing, adjustable shelves, 400D x 900W x 2100H nominal	③	6	[FQSN-082] adjustable shelving; type and quantity of storage options to be determined based on service requirements



## Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-201.01	GPO: double, wall mounted, horizontal	①	1	[ELGP-208]
ELSW-001	SWITCH: light	①	1	[ELBO-015]

For guidance on how to use the Room Data Sheet, please visit the [AusHFG website](#).