



Stress Testing

Room Code	STRT
Briefed Area	20.00 m ²
Ceiling Height	2.7 m
Occupancy	1 patient; 1-2 staff
Hours of Operation	Up to 24 hours (dependent on unit operating hours)

Description | Room for undertaking patient diagnostic stress testing procedures.

Electrical	PROTECTION: body protected	☒	HVAC	AIRCONDITIONING: general	☒
	PROTECTION: cardiac protected	☐		AIRCONDITIONING: HEPA filtered	☐
Lighting	LIGHTING: general	☐		AIRCONDITIONING: positive pressure	☐
	LIGHTING: colour corrected	☒		AIRCONDITIONING: negative pressure	☐
	LIGHTING: dimmable	☐		VENTILATION: exhaust	☐
	LIGHTING: indirect	☐		VENTILATION: natural	☐
Nurse Call and Duress	NURSE CALL SYSTEM: buttons / handset	☒			

Additional Considerations | • The Stress Testing room should be located close to patient toilet and change rooms.



Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-104.01	DOOR: hinged, 1 1/2 leaves, 1400 clear opening, solid	[DWSC-021]
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to room side
AFDPR-056.03	DOOR FRAME PROTECTION: full wrap, to 1200H	[DWPR-010] optional, provision and extent dependent on frame material/finish and movement of beds and mobile equipment in adjacent area
DOHI-003.01	DOOR: hinged, 1 leaf, 900 clear opening, solid	[DWSC-003] optional, to change room if provided
AFDPR-001.01	DOOR PROTECTION: kickplate, to 300H	[DWPR-005] to change room side
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to room side
AFDPR-056.03	DOOR FRAME PROTECTION: full wrap, to 1200H	[DWPR-010] optional, provision and extent dependent on frame material/finish and movement of beds and mobile equipment in adjacent area



Finishes

CODE	DESCRIPTION	COMMENT
FLVY-101	FLOOR FINISH: vinyl, seamless, standard slip resistance	[FLVY-007] floor finish must be minimum slip rating R10 / Pendulum P3 or agreed equivalent to extend under basin or inset section of non-slip vinyl required
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010]
WLFI-001	WALL FINISH: paint	[WLWA-004]
WLFI-011.03	WALL FINISH: vinyl, to 1200 AFFL	[WLWA-025]
CLFS-011	CEILING: flush set, suspended	[CLFS-006]
CLFI-002	CEILING FINISH: paint, clinical areas	[CLFS-006]
CLCN-031	CORNICE: square set	[CLCN-008]



Joinery

CODE	DESCRIPTION	GROUP	QTY	COMMENT
JOBE-031	BENCH: 600D, laminate	①	1	[FIJO-059]
JOCU-001	CUPBOARD: tall, single door	①	1	[FIJO-131]
JOGE-001	BULKHEAD: joinery	①	1	[FIJO-212]



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIBM-019	WHITEBOARD: fixed, magnetic	②	1	[FIBM-019]
FIDI-101	DISPENSER: PPE, disposable masks, wall mounted	②	1	[FIDI-021]
FIDI-106	DISPENSER: PPE, disposable gloves, wall mounted	②	1	[FIDI-014]
FIDI-111	DISPENSER: PPE, disposable gowns/aprons, wall mounted	②	1	[FIDI-019]
FIDI-231	DISPENSER: paper towel, wall mounted	②	1	[FIDI-025] to basin
FIDI-241	DISPENSER: alcohol-based hand rub, wall mounted	②	1	[FIDI-001]
FIDI-256	DISPENSER: soap, wall mounted	②	1	[FIDI-030] to basin
FIDI-261	DISPENSER: soap, antimicrobial, wall mounted	②	1	[FIDI-031] to basin
FIHR-026	HOOK: coat, wall mounted	①	2	[FIHR-026] optional
FIHR-101	BRACKET: suction bottle, wall mounted	②	2	[FIHR-019]
FIRT-051	TRACK: curtain, privacy	①	1	[FIRT-025]
FQBS-101	CHAIR: visitor, clinical areas	③	1	[FQBS-028]
FQBS-172	CHAIR: office, ergonomic, high	③	1	[FQBS-019]
FQBS-203	STOOL: clinical areas, mobile, high	③	2	[FQBS-052]
FQCL-211	LINEN CARRIER: dirty, single skip	③	1	[MMGE-048]
FQGE-101	CURTAIN: privacy screen	③	1	[FQGE-010] to entry door
FQSM-056	PEDESTAL: mobile, 840H nominal, 3 equal wire basket drawers	③	2	[FQSM-003]
FQWS-051	BIN: general waste, 20L	③	1	[FQCW-016]
FQWS-231	BIN: clinical waste, 20L	③	1	[FQCW-005]

CODE	DESCRIPTION	GROUP	QTY	COMMENT
HYBA-121	BASIN: type B, handwashing	①	1	[HYBA-010] refer to BHWS-B (similar)
HYTP-067	TAPWARE: basin, tap set, wall mounted, lever handles	①	1	[HYTP-037] to basin
ITBU-441	CLOCK: analogue display, electric, wall mounted	①	1	[ITCL-014]
ITNE-071	TELEPHONE: handset, desktop	③	1	[ITNE-049]
ITNE-102	COMPUTER: dual display screens, central processing unit (CPU), keyboard and mouse, desktop	③	1	[ITNE-071]
LIFX-113	LIGHT: examination, single articulated arm, 1 light head, ceiling mounted	①	1	[LIFX-027]
MMAH-071	EXERCISE MACHINE: treadmill	③	1	[MMAH-027]
MMBE-157	TROLLEY: patient, examination, echocardiography	③	1	[MMBE-069]
MMGE-191	CANNISTER: suction bottle	③	2	[MMGE-100]
MMGE-337	DEVICE: electrocardiography (ECG), with trolley	③	1	[MMGE-179]
MMHA-002	DEVICE: defibrillator	③	1	[MMHA-002]
MMHA-031	TROLLEY: resuscitation, adult	③	1	[MMHA-027]
MMPH-001	SAFE: dangerous drugs, wall mounted, small	①	1	[MMGE-088] optional, for pharmacological stress testing



Major Medical Equipment (MME)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
MIUS-051	IMAGING DEVICE: echocardiography	②	1	[MMMI-325]



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-101	GPO: single, wall mounted	①	1	[ELGP-109]
ELGP-105	GPO: single, wall mounted, cleaner	①	1	[ELGP-110]
ELGP-106	GPO: single, ceiling mounted	①	1	[ELGP-101]
ELGP-201	GPO: double, wall mounted	①	6	[ELGP-208]
ELGP-231	GPO: double, emergency power, wall mounted	①	1	[ELGP-223]
ELPR-071	RCD: residual current device, wall mounted	①	2	[ELPR-006]
ELSW-001	SWITCH: light	①	2	[ELBO-015] optional, to optional change room
ELSW-021	SWITCH: light, dimmer	①	1	[ELBO-012]
ITCL-181	BUTTON: nurse call, staff assist, with cancel, wall mounted	①	1	[ITCL-008] on services panel, + indicator button & light
ITCL-191	BUTTON: nurse call, emergency, with cancel, wall mounted	①	1	[ITCL-004] + indicator button & light
ITIN-026	OUTLET: data, double RJ45, wall mounted	①	5	[ITIN-026] 1 outlet for telephone



Medical Services Panels and Pendants

CODE	DESCRIPTION	GROUP	QTY	COMMENT
Panel 1				
MMSP-051	MEDICAL SERVICES PANEL: wall mounted	①	1	[MMSP-026]

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-146	GPO: single, emergency power, on services panel	①	4	[ELGP-122]
ELPR-083	RCD: residual current device, emergency power, on services panel	①	1	[ELPR-006]
MGAS-022	OUTLET: medical air, on services panel	①	1	[MGAS-022] optional
MGAS-042	OUTLET: oxygen (O2), on services panel	①	2	[MGAS-042]
MGAS-062	OUTLET: suction, on services panel	①	2	[MGAS-062]
MGFP-021	FLOWMETER: medical air	③	1	[MGFP-002] optional
MGFP-041	FLOWMETER: oxygen	③	2	[MGFP-004]
MGFP-061	ADAPTER: suction	③	2	[MMGE-002]

For guidance on how to use the Room Data Sheet, please visit the [AushFG website](#).