



Treatment Room - Hand Therapy / Splinting

Room Code	TRMT-HTS
Briefed Area	28.00 m ²
Ceiling Height	2.7 m
Occupancy	2 patients; 2-3 staff
Hours of Operation	7am to 6pm, daily (dependent on unit operating hours)

Description | The Treatment Room - Hand Therapy/Splinting provides a controlled environment, privacy and facilities for carrying out treatment and rehabilitation performed by an occupational therapist or physiotherapist with patients that suffer from conditions affecting the hands and upper limbs, such as wounds, scars, burns, fractures or amputations.

Electrical | PROTECTION: body protected ☒
PROTECTION: cardiac protected ☐

Lighting | LIGHTING: general ☐
LIGHTING: colour corrected ☒
LIGHTING: dimmable ☐
LIGHTING: indirect ☐

Nurse Call and Duress | NURSE CALL SYSTEM: buttons / handset ☒

HVAC | AIRCONDITIONING: general ☒
AIRCONDITIONING: HEPA filtered ☐
AIRCONDITIONING: positive pressure ☐
AIRCONDITIONING: negative pressure ☐
VENTILATION: exhaust ☐
VENTILATION: natural ☐

Additional Considerations

- A second door may be required for staff safety and security; the location of the second door will be dependent on the availability an appropriate area to egress.
- Depending on operational model, the hand therapy treatment room may be an open area adjoining a space with other allied health treatment bays. If open, floor boxes may be required for power to height adjustable tables.
- Printing facilities to be shared within the overall department.
- Refrigeration requirements for some materials in warmer climates may need to be considered.



Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-114.01	DOOR: hinged, 1 1/2 leaves, 1400 clear opening, solid, standard vision panel	[DWGL-033]
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to room side
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection
DOHI-013.01	DOOR: hinged, 1 leaf, 900 clear opening, solid, standard vision panel	[DWGL-005] optional, second door for egress
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to room side
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection



Finishes

CODE	DESCRIPTION	COMMENT
FLVY-101	FLOOR FINISH: vinyl, seamless, standard slip resistance	[FLVY-007] floor finish must be minimum slip rating R10 / Pendulum P3 or agreed equivalent to extend under basin or inset section of non-slip vinyl required
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010]
WLFI-001	WALL FINISH: paint	[WLWA-004]
WLFI-101	SPLASHBACK: vinyl	[WLWA-010] to bench
WLFI-101	SPLASHBACK: vinyl	[WLWA-007] to basin
CLTI-022.02	CEILING: drop-in tiles, acoustic, prefinished, 600 x 1200	[CLTI-002]
CLCN-041	CORNICE: wall trim fixing, prefinished	[CLCN-009]



Joinery

CODE	DESCRIPTION	GROUP	QTY	COMMENT
JOBE-031	BENCH: 600D, laminate	①	3	[FIJO-059]
JOCU-021	CUPBOARD: tall, double door	①	1	[FIJO-116]
JOCU-201	CUPBOARD: under bench, single door	①	2	[FIJO-140]
JOCU-221	CUPBOARD: under bench, double door	①	2	[FIJO-135]
JODW-031	DRAWER UNIT: under bench, 3 drawers, equal	①	1	[FIJO-104] for thermoplastic storage, width to be confirmed to suit size of material
JOGE-001	BULKHEAD: joinery	①	2	[FIJO-212] plasterboard bulkhead also acceptable
JOSH-101	SHELF UNIT: wall mounted, adjustable shelves	①	4	[FIJO-152]



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIBM-019	WHITEBOARD: fixed, magnetic	②	1	[FIBM-019]
FIDI-077	DISPENSER: velcro roll, wall mounted	②	1	[FIDI-053]
FIDI-106	DISPENSER: PPE, disposable gloves, wall mounted	②	1	[FIDI-014]
FIDI-231	DISPENSER: paper towel, wall mounted	②	1	[FIDI-025] to basin
FIDI-241	DISPENSER: alcohol-based hand rub, wall mounted	②	1	[FIDI-001]
FIDI-256	DISPENSER: soap, wall mounted	②	1	[FIDI-030] to basin
FIDI-261	DISPENSER: soap, antimicrobial, wall mounted	②	1	[FIDI-031] to basin
FIHR-411	BRACKET: patient monitor, articulated, wall mounted	②	2	[FIHR-067] to therapy tables, dependent on ICT strategy
FIRT-051	TRACK: curtain, privacy	①	2	[FIRT-047]
FQBS-101	CHAIR: visitor, clinical areas	③	6	[FQBS-030]
FQDW-131.02	WORKSTATION: straight, adjustable height, 720H nom, 600D x 1200W	③	2	[FQDW-049]
FQGE-101	CURTAIN: privacy screen	③	3	[FQGE-010]
FQGE-251	DEVICE: sewing machine, domestic	③	1	[FQGE-043]
FQWS-051	BIN: general waste, 20L	③	1	[FQCW-016] to basin

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FQWS-235	BIN: clinical waste, 80L	③	1	[FQCW-010] type, size and quantity of bins to be determined based on service requirements and waste management policies
HYBA-121	BASIN: type B, handwashing	①	1	[HYBA-010]
HYBA-303	SINK: single bowl, with drainer	①	1	[HYBA-069]
HYTP-067	TAPWARE: basin, tap set, wall mounted, lever handles	①	1	[HYTP-037] to basin
HYTP-152	TAPWARE: sink, mixer, fixture mounted, accessible	①	1	[HYTP-040]
ITNE-076	TELEPHONE: handset, wall mounted	②	1	[ITNE-053]
ITNE-121	COMPUTER: single display screen, all-in-one	③	2	[ITNE-066] to therapy tables, dependent on ICT strategy
LIFX-114	LIGHT: examination, single articulated arm, 1 light head, wall mounted	①	2	[LIFX-026] to therapy tables, ceiling mounted is also acceptable
MMAH-012	DEVICE: continuous passive motion (CPM), upper limb	③	1	[MMAH-012] optional
MMAH-261	TABLE: hand therapy, adjustable height	③	2	[FQTA-084]
MMAH-271	DEVICE: hand therapy, pan, splint moulding, water bath	③	1	[MMAH-021]
MMGE-151	LIGHT BOX: x-ray viewer, wall mounted	①	1	[MMGE-150] optional
MMLA-014	DEVICE: wax bath	③	1	[MMLA-014] optional



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-101	GPO: single, wall mounted	①	1	[ELGP-109] optional, to x-ray viewing box
ELGP-101	GPO: single, wall mounted	①	2	[ELGP-109]
ELGP-105	GPO: single, wall mounted, cleaner	①	1	[ELGP-110] as required for distribution across the unit in accordance with AS/NZS 3003
ELGP-201	GPO: double, wall mounted	①	9	[ELGP-208] extent of emergency power to be determined based on service requirements
ELPR-071	RCD: residual current device, wall mounted	①	2	[ELPR-006]
ELSW-001	SWITCH: light	①	3	[ELBO-015] 1 x general room lighting, 2 x examination lights
HYDR-151	TRAP: plaster	①	1	[HYDR-008] optional
ITIN-016	OUTLET: data, single RJ45, wall mounted	①	1	[ITIN-016] to telephone
ITIN-026	OUTLET: data, double RJ45, wall mounted	①	3	[ITIN-026]
ITSE-061	BUTTON: security, duress, fixed, wall mounted	①	2	[ITSE-006]

For guidance on how to use the Room Data Sheet, please visit the [AushFG website](#).