



Treatment Room - Podiatry

Room Code	TRMT-POD
Briefed Area	14.00 m ²
Ceiling Height	2.7 m
Occupancy	1 patient; 1 visitor / support person; 1 staff
Hours of Operation	7am to 6pm, daily (dependent on unit operating hours)

Description | The Treatment Room - Podiatry provides space and facilities for podiatry consultation, examination and treatment. The room may be used for measuring and fitting prosthetic appliances but not for fabrication.

Electrical | PROTECTION: body protected ☒
PROTECTION: cardiac protected ☐

Lighting | LIGHTING: general ☒
LIGHTING: colour corrected ☐
LIGHTING: dimmable ☐
LIGHTING: indirect ☐

Nurse Call and Duress | NURSE CALL SYSTEM: buttons / handset ☒

HVAC | AIRCONDITIONING: general ☒
AIRCONDITIONING: HEPA filtered ☐
AIRCONDITIONING: positive pressure ☐
AIRCONDITIONING: negative pressure ☐
VENTILATION: exhaust ☐
VENTILATION: natural ☐

Additional Considerations |

- Medication storage, clean-up facilities for instruments, sink and plaster trap facilities are to be provided nearby.
- An operational model for responding to calls from staff/patients will be needed to support the inclusion of a nurse call system and is to be determined based on service requirements.
- An external outlook is desirable.



Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-114.01	DOOR: hinged, 1 1/2 leaves, 1400 clear opening, solid, standard vision panel	[DWGL-033]
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to room side



Finishes

CODE	DESCRIPTION	COMMENT
FLVY-101	FLOOR FINISH: vinyl, seamless, standard slip resistance	[FLVY-007] floor finish must be minimum slip rating R10 / Pendulum P3 or agreed equivalent to extend under basin or inset section of non-slip vinyl required
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010]
WLFI-001	WALL FINISH: paint	[WLWA-004]
WLFI-011.04	WALL FINISH: vinyl, to 1500 AFFL	[WLWA-020]
WLFI-101	SPLASHBACK: vinyl	[WLWA-007]

CODE	DESCRIPTION	COMMENT
CLTI-022.02	CEILING: drop-in tiles, acoustic, prefinished, 600 x 1200	[CLTI-002]
CLCN-041	CORNICE: wall trim fixing, prefinished	[CLCN-009]



Joinery

CODE	DESCRIPTION	GROUP	QTY	COMMENT
JOBE-031	BENCH: 600D, laminate	①	1	[FIJO-059]
JOCU-021	CUPBOARD: tall, double door	①	1	[FIJO-117]
JOCU-221	CUPBOARD: under bench, double door	①	1	[FIJO-135]
JOGE-001	BULKHEAD: joinery	①	2	[FIJO-212] plasterboard bulkhead also acceptable
JOSH-101	SHELF UNIT: wall mounted, adjustable shelves	①	1	[FIJO-152]



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIDI-106	DISPENSER: PPE, disposable gloves, wall mounted	②	1	[FIDI-014]
FIDI-151	DISPENSER: PPE, combination, large, wall mounted	②	1	[FIDI-054]
FIDI-231	DISPENSER: paper towel, wall mounted	②	1	[FIDI-025] to basin
FIDI-241	DISPENSER: alcohol-based hand rub, wall mounted	②	1	[FIDI-001]
FIDI-256	DISPENSER: soap, wall mounted	②	1	[FIDI-030] to basin
FIDI-261	DISPENSER: soap, antimicrobial, wall mounted	②	1	[FIDI-031] to basin
FIHR-101	BRACKET: suction bottle, wall mounted	②	1	[FIHR-019]
FIHR-111	BRACKET: sharps bin, wall mounted	②	1	[FIHR-016]
FIRT-051	TRACK: curtain, privacy	①	1	[FIRT-047]
FQBS-101	CHAIR: visitor, clinical areas	③	2	[FQBS-028]
FQBS-202	STOOL: clinical areas, mobile	③	1	[FQBS-051]
FQGE-101	CURTAIN: privacy screen	③	1	[FQGE-010]
FQGE-121	CLOCK: analogue display, battery operated	③	1	[FQGE-005]
FQWS-003	BIN: sharps, clinical, medium	③	1	[FQCW-044]
FQWS-051	BIN: general waste, 20L	③	1	[FQCW-016] to basin
FQWS-233	BIN: clinical waste, 50L	③	1	[FQCW-008] optional; type, size and quantity of bins to be determined based on service requirements and waste management policies
HYBA-121	BASIN: type B, handwashing	①	1	[HYBA-010]
HYTP-067	TAPWARE: basin, tap set, wall mounted, lever handles	①	1	[HYTP-037] to basin
ITNE-076	TELEPHONE: handset, wall mounted	②	1	[ITNE-053]
ITNE-111	COMPUTER: workstation on wheels (WOW), medical grade, all-in-one computer, keyboard and mouse, on cart	③	1	[ITNE-008+MMGE-164] computer may alternatively be on benchtop or wall mounted
LIFX-121	LIGHT: procedure, minor, single articulated arm, 1 light head, ceiling mounted	①	1	[LIFX-013]
MMBE-176	CHAIR: patient, examination, electric	③	1	[MMAH-010]
MMGE-191	CANNISTER: suction bottle	③	1	[MMGE-100]

CODE	DESCRIPTION	GROUP	QTY	COMMENT
MMTR-094	TROLLEY: procedure, 900W x 490D x 900H nom	③	1	[MMGE-139]



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-105	GPO: single, wall mounted, cleaner	①	1	[ELGP-110] as required for distribution across the unit in accordance with AS/NZS 3003
ELGP-106	GPO: single, ceiling mounted	①	1	[ELGP-101]
ELGP-131	GPO: single, emergency power, wall mounted	①	1	[ELGP-123]
ELGP-201	GPO: double, wall mounted	①	3	[ELGP-208] extent of emergency power to be determined based on service requirements
ELPR-071	RCD: residual current device, wall mounted	①	3	[ELPR-006]
ELSW-001	SWITCH: light	①	3	[ELBO-015] 1 x general room lighting, 1 x task light, 1 x examination light
ITCL-191	BUTTON: nurse call, emergency, with cancel, wall mounted	①	1	[ITCL-004]
ITCL-251	HANDSET: nurse call, patient to staff call	①	1	[ITCL-028]
ITIN-016	OUTLET: data, single RJ45, wall mounted	①	1	[ITIN-016] to telephone
ITIN-026	OUTLET: data, double RJ45, wall mounted	①	1	[ITIN-026]
ITSE-061	BUTTON: security, duress, fixed, wall mounted	①	1	[ITSE-006]
LIFX-108	LIGHT: task, integral to joinery	①	1	[LIFX-008]



Medical Services Panels and Pendants

CODE	DESCRIPTION	GROUP	QTY	COMMENT
Panel 1				
MMSP-051	MEDICAL SERVICES PANEL: wall mounted	①	1	[MMSP-026]
ELGP-216	GPO: double, on services panel	①	2	[ELGP-205] extent of emergency power to be determined based on service requirements
ITIN-025	OUTLET: data, double RJ45, on services panel	①	1	[ITIN-025]
MGAS-042	OUTLET: oxygen (O2), on services panel	①	1	[MGAS-042]
MGAS-062	OUTLET: suction, on services panel	①	1	[MGAS-062]
MGFP-041	FLOWMETER: oxygen	③	1	[MGFP-004]
MGFP-061	ADAPTER: suction	③	1	[MMGE-002]

For guidance on how to use the Room Data Sheet, please visit the [AushFG website](#).