



Treatment Room

Room Code	TRMT
Briefed Area	14.00 m ²
Ceiling Height	2.7 m
Occupancy	1 patient; 1-2 staff
Hours of Operation	Up to 24 hours (dependent on unit operating hours)

Description | The Treatment Room provides a controlled environment, privacy and facilities for carrying out consultations, examinations, treatments and minor procedures.

Electrical | PROTECTION: body protected
PROTECTION: cardiac protected

Lighting | LIGHTING: general
LIGHTING: colour corrected
LIGHTING: dimmable
LIGHTING: indirect

Nurse Call and Duress | NURSE CALL SYSTEM: buttons / handset

HVAC | AIRCONDITIONING: general
AIRCONDITIONING: HEPA filtered
AIRCONDITIONING: positive pressure
AIRCONDITIONING: negative pressure
VENTILATION: exhaust
VENTILATION: natural

Additional Considerations



Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-114.01	DOOR: hinged, 1 1/2 leaves, 1400 clear opening, solid, standard vision panel	DWGL-033]
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to room side
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection
AFDPR-056.03	DOOR FRAME PROTECTION: full wrap, to 1200H	[DWPR-010] optional, provision and extent dependent on frame material/finish and movement of beds and mobile equipment in adjacent area



Finishes

CODE	DESCRIPTION	COMMENT
FLVY-101	FLOOR FINISH: vinyl, seamless, standard slip resistance	[FLVY-007] floor finish must be minimum slip rating R10 / Pendulum P3 or agreed equivalent to extend under basin or inset section of non-slip vinyl required
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, covered	[FLSK-010]
WLFI-001	WALL FINISH: paint	[WLWA-004]
WLFI-011.04	WALL FINISH: vinyl, to 1500 AFFL	[WLWA-020]

CODE	DESCRIPTION	COMMENT
WLFI-101	SPLASHBACK: vinyl	[WLWA-007] to basin
CLFS-011	CEILING: flush set, suspended	[CLFS-006]
CLFI-002	CEILING FINISH: paint, clinical areas	[CLFS-006]
CLCN-031	CORNICE: square set	[CLCN-008]



Joinery

CODE	DESCRIPTION	GROUP	QTY	COMMENT
JOBE-031	BENCH: 600D, laminate	①	1	[FIJO-059]
JOCU-221	CUPBOARD: under bench, double door	①	1	[FIJO-135]
JOGE-001	BULKHEAD: joinery	①	1	[FIJO-212] plasterboard bulkhead also acceptable
JOSH-101	SHELF UNIT: wall mounted, adjustable shelves	①	1	[FIJO-152]



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIDI-106	DISPENSER: PPE, disposable gloves, wall mounted	②	1	[FIDI-014]
FIDI-231	DISPENSER: paper towel, wall mounted	②	1	[FIDI-025] to basin
FIDI-241	DISPENSER: alcohol-based hand rub, wall mounted	②	1	[FIDI-001]
FIDI-256	DISPENSER: soap, wall mounted	②	1	[FIDI-030] to basin
FIDI-261	DISPENSER: soap, antimicrobial, wall mounted	②	1	[FIDI-031] to basin
FIHR-026	HOOK: coat, wall mounted	①	2	[FIHR-026] optional
FIHR-101	BRACKET: suction bottle, wall mounted	②	1	[FIHR-019]
FIHR-111	BRACKET: sharps bin, wall mounted	②	1	[FIHR-016]
FIRT-051	TRACK: curtain, privacy	①	1	[FIRT-032]
FQBS-203	STOOL: clinical areas, mobile, high	③	1	[FQBS-052]
FQGE-101	CURTAIN: privacy screen	③	1	[FQGE-010]
FQGE-121	CLOCK: analogue display, battery operated	③	1	[FQGE-005]
FQWS-003	BIN: sharps, clinical, medium	③	1	[FQCW-043]
FQWS-051	BIN: general waste, 20L	③	1	[FQCW-016] to basin
FQWS-233	BIN: clinical waste, 50L	③	1	[FQCW-008] optional; type, size and quantity of bins to be determined based on service requirements and waste management policies
HYBA-101	BASIN: type A, handwashing	①	1	[HYBA-009]
HYTP-067	TAPWARE: basin, tap set, wall mounted, lever handles	①	1	[HYTP-037]
ITNE-076	TELEPHONE: handset, wall mounted	②	1	[ITNE-053]
ITNE-111	COMPUTER: workstation on wheels (WOW), medical grade, all-in-one computer, keyboard and mouse, on cart	③	1	[ITNE-008+MMGE-164] computer may alternatively be on benchtop or wall mounted; allocation of WOWs across department to be rationalised
ITNE-311	PRINTER: desktop	③	1	[ITNE-023] optional
LIFX-113	LIGHT: examination, single articulated arm, 1 light head, ceiling mounted	①	1	[LIFX-027]

CODE	DESCRIPTION	GROUP	QTY	COMMENT
MGFP-061	ADAPTER: suction	3	1	[MMGE-002]
MMBE-156	TROLLEY: patient, examination	3	1	[MMBE-043]
MMGE-191	CANNISTER: suction bottle	3	1	[MMGE-100]
MMGE-233	DIAGNOSTIC SET: otoscope and ophthalmoscope, wall mounted	2	1	[MMGE-031] optional, may be portable/mobile on stand
MMTR-071	TROLLEY: equipment, 490W x 490D x 900H nom	3	1	[MMGE-119]



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-101.01	GPO: single, wall mounted, horizontal	1	1	[ELGP-109] low level, for patient trolley
ELGP-105	GPO: single, wall mounted, cleaner	1	1	[ELGP-110] as required for distribution across the unit in accordance with AS/NZS 3003
ELGP-106.01	GPO: single, ceiling mounted, horizontal	1	1	[ELGP-101] to exam light
ELGP-201.01	GPO: double, wall mounted, horizontal	1	2	[ELGP-208]
ELPR-071	RCD: residual current device, wall mounted	1	4	[ELPR-006]
ELSW-001	SWITCH: light	1	3	[ELBO-015] 1 x general room lighting, 1 x task light, 1 x examination light
HYDR-201	DIRECT CONNECTION: wastewater, general	1	1	to basin
HYTP-451	DIRECT CONNECTION: water, cold	1	1	to basin tapware
HYTP-453	DIRECT CONNECTION: water, warm	1	1	to basin tapware
ITCL-111	LIGHT: nurse call indicator, ceiling mounted	1	1	outside door
ITCL-191	BUTTON: nurse call, emergency, with cancel, wall mounted	1	1	[ITCL-004] indicator button and light
ITCL-251	HANDSET: nurse call, patient to staff call	1	1	[ITCL-028] on services panel, call button on the handset
ITIN-016	OUTLET: data, single RJ45, wall mounted	1	1	[ITIN-016] to telephone
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	2	[ITIN-026]
ITSE-061	BUTTON: security, duress, fixed, wall mounted	1	1	[ITSE-006]
LIFX-108	LIGHT: task, integral to joinery	1	1	[LIFX-008] under wall mounted joinery



Medical Services Panels and Pendants

CODE	DESCRIPTION	GROUP	QTY	COMMENT
Panel 1				
MMSP-051	MEDICAL SERVICES PANEL: wall mounted	1	1	[MMSP-026]
ELGP-116	GPO: single, on services panel	1	3	[ELGP-105]
ELGP-146	GPO: single, emergency power, on services panel	1	2	[ELGP-122]
ITCL-133	BUTTON: nurse call, patient to staff call, with cancel, with handset connection point, on services panel	1	1	[ITCL-006] indicator button and light
ITCL-183	BUTTON: nurse call, staff assist, with cancel, on services panel	1	1	[ITCL-008] indicator button and light
ITIN-025	OUTLET: data, double RJ45, on services panel	1	1	[ITIN-025]
MGAS-022	OUTLET: medical air, on services panel	1	1	[MGAS-022]
MGAS-042	OUTLET: oxygen (O2), on services panel	1	1	[MGAS-042]

CODE	DESCRIPTION	GROUP	QTY	COMMENT
MGAS-062	OUTLET: suction, on services panel	①	1	[MGAS-062]
MGFP-021	FLOWMETER: medical air	③	1	[MGFP-002]
MGFP-041	FLOWMETER: oxygen	③	1	[MGFP-004]

For guidance on how to use the Room Data Sheet, please visit the [AusHFG website](#).