



Waiting, 10m2

Room Code	WAIT-10
Briefed Area	10.00 m ²
Ceiling Height	2.7 m
Occupancy	up to 8 patients / visitors
Hours of Operation	Up to 24 hours (dependent on unit operating hours)

Description | The Waiting, 10m2 provides the space and amenities required for patients, visitors / support persons, and families to wait prior to attending an appointment and/or receiving clinical care in a department.

Electrical | PROTECTION: body protected
PROTECTION: cardiac protected

Lighting | LIGHTING: general
LIGHTING: colour corrected
LIGHTING: dimmable
LIGHTING: indirect

Nurse Call and Duress | NURSE CALL SYSTEM: buttons / handset

HVAC | AIRCONDITIONING: general
AIRCONDITIONING: HEPA filtered
AIRCONDITIONING: positive pressure
AIRCONDITIONING: negative pressure
VENTILATION: exhaust
VENTILATION: natural

Additional Considerations

- The size of waiting areas can vary depending on service requirements; add 1.2m2 per additional person and allow 1.5m2 for additional wheelchair spaces as required.
- Waiting areas may be shared between departments.
- Public amenities including baby change facilities should be located nearby.
- A range of occupants will need to be accommodated including adults, children, able-bodied persons and people with disabilities. In many instances bariatric capacity will also be required.
- Consider furniture options including weight rating of all chairs and providing built-in furniture or securing furniture where there may be safety/security concerns.
- Wall protection is recommended to protect wall linings and finishes from damage due to movement of loose furniture.
- Acoustic treatments may be considered as required to ensure the noise level in the space is comfortable both in the waiting area and adjacent reception areas.
- Check-in kiosks may be located nearby and services will need to be confirmed based on system requirements.
- Provision of a hearing augmentation system may be required where a built in amplification system is provided, if a TV monitor is installed.
- Mobile duress coverage is to be assessed and planned at a department level and coverage is to suit local security and WHS policies and operational service requirements.
- Hand hygiene facilities, such as alcohol-based hand rub, should be provided in line with local infection prevention and control (IPC) policies.
- An external outlook is desirable.



Doors and Windows

CODE	DESCRIPTION	COMMENT
WIFX-158.01	WINDOW: fixed, external, double glazed, sill at 1050H	[DWWH-005] access to natural light and external outlook is desirable
AHWCV-001	WINDOW COVERING: blind, roller, single	[DWWD-004]



Finishes

CODE	DESCRIPTION	COMMENT
FLVY-101	FLOOR FINISH: vinyl, seamless, standard slip resistance	[FLVY-003] carpet tiles are also acceptable
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010] feather edge vinyl or aluminium skirting are acceptable if carpet tiles provided
WLFI-001	WALL FINISH: paint	[WLWA-004]
WLFI-011.01	WALL FINISH: vinyl, to 900 AFFL	[WLWA-022] as required to suit loose furniture layout; crash rails are also acceptable
CLTI-022.02	CEILING: drop-in tiles, acoustic, prefinished, 600 x 1200	[CLTI-002]
CLCN-041	CORNICE: wall trim fixing, prefinished	[CLCN-009]
WLPR-006	WALL PROTECTION: corner guards	[WLPR-006] height to be coordinated with adjacent wall protection



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIBM-019	WHITEBOARD: fixed, magnetic	2	1	[FIBM-019] optional
FIDI-241	DISPENSER: alcohol-based hand rub, wall mounted	2	1	[FIDI-001] quantity and location to suit local IPC policies
FIHR-046	RACK: magazine/pamphlet, wall mounted	2	1	[FIHR-045] optional
FIHR-331	BRACKET: display screen, single, fixed, wall mounted	2	1	[FIHR-006]
FQBS-102	CHAIR: visitor, clinical areas, bariatric	3	1	[FQBS-027] quantity to be confirmed at project level depending on service requirements
FQBS-116	CHAIR: visitor, waiting areas	3	6	[FQBS-032]
FQGE-002	ARTWORK: wall mounted	3	1	[FQGE-002] optional
FQTA-201	TABLE: square, 450H, 500L	3	1	[FQTA-071]
FQWS-051	BIN: general waste, 20L	3	1	[FQCW-016]
ITAV-121	DISPLAY SCREEN: AV system	3	1	[ITBU-011]



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELGP-101	GPO: single, wall mounted	1	1	[ELGP-109] to display screen
ELGP-201	GPO: double, wall mounted	1	1	[ELGP-208]
ITIN-076	OUTLET: MATV, wall mounted	1	1	[ITIN-070] may be replaced with data outlet in accordance with local ICT policy

For guidance on how to use the Room Data Sheet, please visit the [AushFG website](#).