



Toilet - Accessible

Room Code	WCAC
Briefed Area	6.00 m ²
Ceiling Height	2.7 m
Occupancy	1 person intermittently
Hours of Operation	Up to 24 hours (dependent on unit operating hours)

Description | The Toilet - Patient provides an enclosed, lockable room with an accessible toilet and handwashing basin for use by patients, visitors or staff with disabilities (with or without assistance). A baby change table may also be located in this room.

Electrical | PROTECTION: body protected
PROTECTION: cardiac protected

Lighting | LIGHTING: general
LIGHTING: colour corrected
LIGHTING: dimmable
LIGHTING: indirect

Nurse Call and Duress | NURSE CALL SYSTEM: buttons / handset

HVAC | AIRCONDITIONING: general
AIRCONDITIONING: HEPA filtered
AIRCONDITIONING: positive pressure
AIRCONDITIONING: negative pressure
VENTILATION: exhaust
VENTILATION: natural

Additional Considerations

- The room layout and all fixtures, furniture and equipment (FF&E) are to comply with AS 1428.1 and NZ 4121.
- Signage with tactile Braille nominating 'All Gender Accessible Toilet' required to room, including noting if the room is a right-handed or left handed room (depending on layout).
- If the Toilet - Accessible is located in a patient care area for use by patients, the nurse call system should be included and emergency release door hardware should be installed to allow staff access in emergency situations. An operational model for responding to calls from staff/patients will be needed to support the inclusion of a nurse call system.
- If the Toilet - Accessible is to be dedicated for use by staff, access control (e.g. a swipe card reader) may be required if this room is provided in a public area or patient care area.
- The entrance to the room is to be flush with the adjoining floor for access in commode chairs/wheelchairs or with other assistive devices.
- Mobile duress coverage is to be assessed and planned at a department level and coverage is to suit local security and WHS policies and operational service requirements.



Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-003.01	DOOR: hinged, 1 leaf, 900 clear opening, solid	[DWSC-003] with privacy latch, emergency release required if inward opening door
AFDPR-001.01	DOOR PROTECTION: kickplate, to 300H	[DWPR-001] to room side
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection
ITSE-261	READER: security, access control, proximity card, wall mounted	[ITSE-038] optional, may be provided if room is for staff use and located in a public / patient treatment area



Finishes

CODE	DESCRIPTION	COMMENT
FLVY-113	FLOOR FINISH: vinyl, seamless, non-slip, wet area	[FLVY-009] tiles are also acceptable
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010] tiles acceptable if tiled floor is provided
WLFI-001	WALL FINISH: paint	[WLWA-004]
WLFI-101	SPLASHBACK: vinyl	[WLWA-007] to basin
CLTI-025.02	CEILING: drop-in tiles, moisture resistant, prefinished, 600 x 1200	[CLTI-014]
CLCN-041	CORNICE: wall trim fixing, prefinished	[CLCN-009]



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIBM-102	MIRROR: fixed, safety glass, frameless	1	1	[FIBM-006]
FIDI-231	DISPENSER: paper towel, wall mounted	2	1	[FIDI-025]
FIDI-256	DISPENSER: soap, wall mounted	2	1	[FIDI-030]
FIDI-301	DISPENSER: toilet paper, wall mounted	1	1	[FIDI-036]
FIHR-026	HOOK: coat, wall mounted	1	2	[FIHR-026]
FIRT-121	GRAB RAIL: toilet, straight, horizontal	1	1	[FIRT-007]
FIRT-125	GRAB RAIL: toilet, 90 degree	1	1	[FIRT-006]
FIRT-191	BACK REST: toilet, accessible	1	1	[FIGE-011]
FQGE-361	CHANGE TABLE: baby, wall mounted	1	1	[FQBS-035] optional
FQWS-051	BIN: general waste, 20L	3	1	[FQCW-016]
FQWS-331	BIN: sanitary waste	3	1	[FQCW-037]
HYBA-146	BASIN: type C, handwashing, accessible	1	1	[HYBA-005] with detachable shroud to pipework; location of thermostatic mixing valve to be determined based on ability to share with nearby basins
HYTP-003	FLUSH BUTTON: toilet suite, accessible	1	1	[HYWC-001]
HYTP-052	TAPWARE: basin, mixer, fixture mounted, accessible	1	1	[HYTP-035] selection of basin and tapware to be coordinated to ensure compatibility
HYWC-033	TOILET SUITE: patient, accessible	1	1	[HYWC-001]



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELSW-001	SWITCH: light	1	1	[ELBO-015]
HYDR-021	DRAIN: floor waste, round	1	1	[HYDR-004]
HYDR-081	DRAIN: clear out, round	1	1	[HYDR-009]
HYDR-201	DIRECT CONNECTION: wastewater, general	1	1	to basin
HYTP-451	DIRECT CONNECTION: water, cold	1	1	to basin tapware
HYTP-453	DIRECT CONNECTION: water, warm	1	1	to basin tapware
ITCL-111	LIGHT: nurse call indicator, ceiling mounted	1	1	outside door, placement to ensure visibility along paths of travel; optional, to be provided

CODE	DESCRIPTION	GROUP	QTY	COMMENT
				if room located in a patient treatment area for use by patients
ITCL-121	BUTTON: nurse call, patient to staff call, with cancel, wall mounted	①	1	[ITCL-006] optional, to be provided if room located in a patient treatment area for use by patients
ITCL-181	BUTTON: nurse call, staff assist, with cancel, wall mounted	①	1	[ITCL-008] optional, to be provided if room located in a patient treatment area for use by patients
ITCL-191	BUTTON: nurse call, emergency, with cancel, wall mounted	①	1	[ITCL-004] optional, to be provided if room located in a patient treatment area for use by patients

For guidance on how to use the Room Data Sheet, please visit the [AusHFG website](#).