



## Toilet - Patient

|                           |  |
|---------------------------|--|
| <b>Room Code</b>          | WCPT   |
| <b>Briefed Area</b>       | 4.00 m <sup>2</sup>                                |
| <b>Ceiling Height</b>     | 2.7 m  |
| <b>Occupancy</b>          | 1 patient; 1 staff assisting as required           |
| <b>Hours of Operation</b> | Up to 24 hours (dependent on unit operating hours) |

**Description** | The Toilet - Patient provides an enclosed, lockable room with a toilet and handwashing basin for use by patients (with or without assistance).

**Electrical** | PROTECTION: body protected   
PROTECTION: cardiac protected

**Lighting** | LIGHTING: general   
LIGHTING: colour corrected   
LIGHTING: dimmable   
LIGHTING: indirect

**Nurse Call and Duress** | NURSE CALL SYSTEM: buttons / handset

**HVAC** | AIRCONDITIONING: general   
AIRCONDITIONING: HEPA filtered   
AIRCONDITIONING: positive pressure   
AIRCONDITIONING: negative pressure   
VENTILATION: exhaust   
VENTILATION: natural

### Additional Considerations

- Signage with tactile Braille nominating 'All Gender Patient Toilet' required to room.
- Emergency release door hardware should be installed to allow staff access in emergency situations.
- The entrance to the room is to be flush with the adjoining floor for access in commode chairs/wheelchairs or with other assistive devices.
- Toilet lids and seats are to be robust and suitable for long term, high frequency use. It is recommended that the toilet lid/seat is coloured to achieve a minimum 30% luminance contrast between the lid/seat, and the toilet pan, the floor, and the adjacent walls to support patients with visual impairments.
- Mobile duress coverage is to be assessed and planned at a department level and coverage is to suit local security and WHS policies and operational service requirements.



## Doors and Windows

| CODE         | DESCRIPTION                                    | COMMENT  |
|--------------|--|--|
| DOHI-003.01  | DOOR: hinged, 1 leaf, 900 clear opening, solid | [DWSC-003] with privacy latch, emergency release required if inward opening door   |
| AFDPR-001.01 | DOOR PROTECTION: kickplate, to 300H            | [DWPR-001] to room side  |
| AFDPR-006.01 | DOOR PROTECTION: plate, to 900H                | [DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection |



## Finishes

| CODE     | DESCRIPTION   | COMMENT  |
|----------|---|--|
| FLVY-113 | FLOOR FINISH: vinyl, seamless, non-slip, wet area   | [FLVY-009] tiles are also acceptable                   |
| FLSK-021 | SKIRTING: vinyl, integral with floor vinyl, covered | [FLSK-010] tiles acceptable if tiled floor is provided |

| CODE        | DESCRIPTION   | COMMENT             |
|-------------|---|---------------------|
| WLFI-001    | WALL FINISH: paint  | [WLWA-004]          |
| WLFI-101    | SPLASHBACK: vinyl   | [WLWA-007] to basin |
| CLTI-025.02 | CEILING: drop-in tiles, moisture resistant, prefinished, 600 x 1200 | [CLTI-014]          |
| CLCN-041    | CORNICE: wall trim fixing, prefinished                              | [CLCN-009]          |



## Fittings, Furniture and Equipment (FF&E)

| CODE     | DESCRIPTION                            | GROUP | QTY | COMMENT  |
|----------|--|-------|-----|--|
| FIBM-102 | MIRROR: fixed, safety glass, frameless | ①     | 1   | [FIBM-006]   |
| FIDI-231 | DISPENSER: paper towel, wall mounted   | ②     | 1   | [FIDI-025]   |
| FIDI-256 | DISPENSER: soap, wall mounted          | ②     | 1   | [FIDI-030]   |
| FIDI-301 | DISPENSER: toilet paper, wall mounted  | ①     | 1   | [FIDI-036]   |
| FIHR-026 | HOOK: coat, wall mounted               | ①     | 1   | [FIHR-026]   |
| FIRT-125 | GRAB RAIL: toilet, 90 degree           | ①     | 1   | [FIRT-006]   |
| FIRT-136 | GRAB RAIL: toilet, drop down           | ①     | 1   | [FIRT-008] optional  |
| FQWS-051 | BIN: general waste, 20L                | ③     | 1   | [FQCW-016]   |
| FQWS-331 | BIN: sanitary waste                    | ③     | 1   | [FQCW-037]   |
| HYBA-141 | BASIN: type C, handwashing             | ①     | 1   | [HYBA-011] with detachable shroud to pipework; location of thermostatic mixing valve to be determined based on ability to share with nearby basins |
| HYTP-051 | TAPWARE: basin, mixer, fixture mounted | ①     | 1   | [HYTP-036] selection of basin and tapware to be coordinated to ensure compatibility  |
| HYWC-021 | TOILET SUITE: standard                 | ①     | 1   | [HYWC-008]   |



## Engineering Services

| CODE     | DESCRIPTION  | GROUP | QTY | COMMENT  |
|----------|--|-------|-----|--|
| ELSW-001 | SWITCH: light  | ①     | 1   | [ELBO-015]   |
| HYDR-021 | DRAIN: floor waste, round  | ①     | 1   | [HYDR-004]   |
| HYDR-081 | DRAIN: clear out, round  | ①     | 1   | [HYDR-009]   |
| HYDR-201 | DIRECT CONNECTION: wastewater, general                               | ①     | 1   | to basin   |
| HYTP-451 | DIRECT CONNECTION: water, cold                                       | ①     | 1   | to basin tapware   |
| HYTP-453 | DIRECT CONNECTION: water, warm                                       | ①     | 1   | to basin tapware   |
| ITCL-111 | LIGHT: nurse call indicator, ceiling mounted                         | ①     | 1   | outside door; placement to ensure visibility along paths of travel |
| ITCL-121 | BUTTON: nurse call, patient to staff call, with cancel, wall mounted | ①     | 1   | [ITCL-006]   |
| ITCL-181 | BUTTON: nurse call, staff assist, with cancel, wall mounted          | ①     | 1   | [ITCL-008]   |
| ITCL-191 | BUTTON: nurse call, emergency, with cancel, wall mounted             | ①     | 1   | [ITCL-004]   |

For guidance on how to use the Room Data Sheet, please visit the [AushFG website](https://www.aushfg.com.au).