



Toilet - Staff

Room Code	WCST
Briefed Area	3.00 m ²
Ceiling Height	2.7 m
Occupancy	1 staff intermittently
Hours of Operation	Up to 24 hours (dependent on unit operating hours)

Description | The Toilet - Staff provides an enclosed, lockable room with a toilet and handwashing basin for use by staff.

Electrical	PROTECTION: body protected	<input type="checkbox"/>	HVAC	AIRCONDITIONING: general	<input type="checkbox"/>
	PROTECTION: cardiac protected	<input type="checkbox"/>		AIRCONDITIONING: HEPA filtered	<input type="checkbox"/>
Lighting	LIGHTING: general	<input checked="" type="checkbox"/>	AIRCONDITIONING: positive pressure	<input type="checkbox"/>	
	LIGHTING: colour corrected	<input type="checkbox"/>	AIRCONDITIONING: negative pressure	<input type="checkbox"/>	
	LIGHTING: dimmable	<input type="checkbox"/>	VENTILATION: exhaust	<input checked="" type="checkbox"/>	
	LIGHTING: indirect	<input type="checkbox"/>	VENTILATION: natural	<input type="checkbox"/>	
Nurse Call and Duress	NURSE CALL SYSTEM: buttons / handset	<input type="checkbox"/>			

Additional Considerations

- Signage with tactile Braille nominating 'All Gender Staff Toilet' required to room.
- Access control (e.g. a swipe card reader) may be required if this room is provided in a public area or patient care area.
- Mobile duress coverage is to be assessed and planned at a department level and coverage is to suit local security and WHS policies and operational service requirements.



Doors and Windows

CODE	DESCRIPTION	COMMENT
DOHI-002.01	DOOR: hinged, 1 leaf, 850 clear opening, solid	[DWSC-001] with privacy latch, emergency release required if inward opening door
AFDPR-001.01	DOOR PROTECTION: kickplate, to 300H	[DWPR-001] to room side
AFDPR-006.01	DOOR PROTECTION: plate, to 900H	[DWPR-005] to corridor side, extent dependent on movement of beds and mobile equipment in adjacent area; to be coordinated with corridor wall protection
ITSE-261	READER: security, access control, proximity card, wall mounted	[ITSE-038] optional, may be provided if room located in a public / patient treatment area



Finishes

CODE	DESCRIPTION	COMMENT
FLVY-113	FLOOR FINISH: vinyl, seamless, non-slip, wet area	[FLVY-009] tiles are also acceptable
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved	[FLSK-010] tiles acceptable if tiled floor is provided
WLFI-001	WALL FINISH: paint	[WLWA-004]
WLFI-101	SPLASHBACK: vinyl	[WLWA-007] to basin
CLTI-025.02	CEILING: drop-in tiles, moisture resistant, prefinished, 600 x 1200	[CLTI-014]

CODE	DESCRIPTION	COMMENT
CLCN-041	CORNICE: wall trim fixing, prefinished	[CLCN-009]



Fittings, Furniture and Equipment (FF&E)

CODE	DESCRIPTION	GROUP	QTY	COMMENT
FIBM-102	MIRROR: fixed, safety glass, frameless	1	1	[FIBM-006]
FIDI-231	DISPENSER: paper towel, wall mounted	2	1	[FIDI-025]
FIDI-256	DISPENSER: soap, wall mounted	2	1	[FIDI-030]
FIDI-301	DISPENSER: toilet paper, wall mounted	1	1	[FIDI-036]
FIHR-026	HOOK: coat, wall mounted	1	1	[FIHR-026]
FQWS-051	BIN: general waste, 20L	3	1	[FQCW-016]
FQWS-331	BIN: sanitary waste	3	1	[FQCW-037]
HYBA-141	BASIN: type C, handwashing	1	1	[HYBA-011] with detachable shroud to pipework; location of thermostatic mixing valve to be determined based on ability to share with nearby basins
HYTP-051	TAPWARE: basin, mixer, fixture mounted	1	1	[HYTP-036] selection of basin and tapware to be coordinated to ensure compatibility
HYWC-021	TOILET SUITE: standard	1	1	[HYWC-008]



Engineering Services

CODE	DESCRIPTION	GROUP	QTY	COMMENT
ELSW-001	SWITCH: light	1	1	[ELBO-015]
HYDR-021	DRAIN: floor waste, round	1	1	[HYDR-004]
HYDR-081	DRAIN: clear out, round	1	1	[HYDR-009]
HYDR-201	DIRECT CONNECTION: wastewater, general	1	1	to basin
HYTP-451	DIRECT CONNECTION: water, cold	1	1	to basin tapware
HYTP-453	DIRECT CONNECTION: water, warm	1	1	to basin tapware

For guidance on how to use the Room Data Sheet, please visit the [AusHFG website](#).