

Room Name | X-ray Viewing and Reporting

Room Number: XRRR

Last modified 01/03/2016

Briefed Area 12.00

Remarks

Occupancy

Up to 4

Hours of Operation

☒ Available 24 Hours

Acoustics

Sound attenuation level medium, Acoustic privacy is required.

Description or Special Requirements

Room within a Clinical or Diagnostic Unit for reviewing and reporting of patient imaging film or computerised images and to write reports. Acoustics: Sound attenuation - medium; Acoustic privacy is required

Room Fabrics

AusHFG code	Description	Material	Finish	Specification	Comments
1149	Floor finish	Carpet	90/10 Wool/ Nylon	Broadloom, 48 oz.	vinyl also acceptable
3000	Wall finish	Paint	Acrylic, washable		
5060	Ceiling - Acoustic	Acoustic	Prefinished	Drop-in tiles, 600x1200	
8000	Door protection	Vinyl	Prefinished	Kickplate, 300mm high	
9002	Door - 910mm	Solid Core/ Glass	Paint	Single leaf, half glazed	910mm clear opening, glazing optional
7010	Observation	Glass	Clear	Through door/s	
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle	
2010	Skirting	Vinyl	Prefinished	Feather edged, 150 mmH	or floor vinyl coved skirting

Fittings and Furniture

AusHFG code	Description	Group	Qty	Comments
FF-1120	Bench - workstation	1	2	to 2 sides of room
FF-17255	Pedestal filing unit - mobile, 660mmH	3	2	under bench
FF-17310	Pigeon-hole unit	1	4	above bench, vertical slots for X-Rays
FF-17360	Pinboard - fabric covered	1	2	above bench
FF-2100	Chair - ergonomic, office	3	4	
FF-24400	Whiteboard	2	1	900x900, optional
FF-3350	Clock - battery operated	3	1	
FF-5824	Waste bin - general	3	2	

Fixtures, Equipment and associated Services

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments
FE-11415	Computer - PACS	3	2	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	for computerised images
FE-41100	Printer - networked	3	1	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-54510	Telephone - handset, standard	3	4	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	
FE-69210	Xray viewer - multiscreen	1	10	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	optional

Room Name | X-ray Viewing and Reporting

Room Number: XRRR

AusHFG code	Description	Grp	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Comments

Service Requirements

AusHFG code	Description	Comments
S-5000	Airconditioning	
S-6000	General fluorescent	
S-6005	Dimmable	for image viewing

Services

AusHFG code	Description	Group	Qty	Comments
S-9001	GPO: Double	1	9	
S-9060	GPO: Special: for equipment	1	2	TV, ceiling
S-1006	Voice / Data outlet: double	1	1	1 outlet for telephone
S-1006	Voice / Data outlet: double	1	4	1 outlet for telephone
S-5000	Airconditioning	1	1	
S-6000	General fluorescent	1	1	
S-6005	Dimmable	1	1	for image viewing
S-6200	Light switches	1	3	
S-6055	Special: task light, built in	1	2	under O/H cupboards