1 Bed Room - Nested Ensuite

CARDIAC PROTECTION | **BODY PROTECTION** | HEARING LOOP | RADIATION SHIELDING | MAGNETIC / RF SHIELDING | HEPA FILTRATION | POSITIVE PRESSURE | NEGATIVE PRESSURE

CODE	DESCRIPTION
AFDPR-006.01	DOOR PROTECTION: plate, to 900H
AHWCV-002	WINDOW COVERING: blind, roller, double
DOHI-003.01	DOOR: hinged, 1 leaf, 900 clear opening, solid
DOHI-114.01	DOOR: hinged, 1 1/2 leaves, 1400 clear opening, solid, standard vision panel
ELGP-101.01	GPO: single, wall mounted, horizontal
ELGP-105	GPO: single, wall mounted, cleaner
ELGP-146	GPO: single, emergency power, on services panel
ELGP-151	GPO: single, emergency power, on pendant services head
ELGP-201.01	GPO: double, wall mounted, horizontal
ELGP-206.01	GPO: double, ceiling mounted, horizontal
ELPR-073	RCD: residual current device, on services panel
ELPR-083	RCD: residual current device, emergency power, on services panel
ELSW-001	SWITCH: light
ELSW-002	SWITCH: light, 2-gang
FIBM-019	WHITEBOARD: fixed, magnetic
FIDI-106	DISPENSER: PPE, disposable gloves, wall mounted
FIDI-231	DISPENSER: paper towel, wall mounted
FIDI-241	DISPENSER: alcohol-based hand rub, wall mounted
FIDI-256	DISPENSER: soap, wall mounted
FIDI-261	DISPENSER: soap, antiseptic, wall mounted
FIDI-386	FRAME: document, A4, wall mounted
FIHR-029	HOOK: equipment
FIHR-101	BRACKET: suction bottle, wall mounted
FIHR-111	BRACKET: sharps bin, wall mounted
FIHR-353	BRACKET: patient entertainment system, fixed, ceiling mounted
FIRT-051.03	TRACK: curtain, privacy, U-shaped
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved
FLVY-101	FLOOR FINISH: vinyl, seamless, standard slip resistance
FQBS-101	CHAIR: visitor, clinical areas
FQGE-101	CURTAIN: privacy screen
FQSN-100	BEDSIDE TABLE: floor standing, patient locker
FQTA-091	TABLE: overbed, mobile, height adjustable
FQWS-003	BIN: sharps, clinical, medium
FQWS-051	BIN: general waste, 20L
HYBA-121	BASIN: type B, handwashing
HYTP-067	TAPWARE: basin, tap set, wall mounted, lever handles
ITCL-133	BUTTON: nurse call, patient to staff call, with cancel, with handset connection point, on services panel
ITCL-181	BUTTON: nurse call, staff assist, with cancel, wall mounted
ITCL-191	BUTTON: nurse call, emergency, with cancel, wall mounted
ITCL-253	HANDSET: nurse call, patient to staff call, with light control, with patient entertainment system control, with speaker
ITCL-301	DISPLAY SCREEN: patient entertainment system
ITIN-021	OUTLET: data, double RJ45, ceiling mounted
ITIN-025	OUTLET: data, double RJ45, on services panel
ITIN-026	OUTLET: data, double RJ45, wall mounted
ITIN-071	OUTLET: MATV, ceiling mounted
ITNE-071	TELEPHONE: handset, desktop
JOBH-021	BEDHEAD: full height
JOCU-413	WARDROBE: built-in, single door, fixed shelves, clothing rail
LIFX-151	LIGHT: night, wall mounted
LIFX-161	LIGHT: reading, wall mounted
MGAS-022	OUTLET: medical air, on services panel
MGAS-042	OUTLET: oxygen (O2), on services panel
MGAS-062	OUTLET: suction, on services panel
MGFP-021	FLOWMETER: medical air
MGFP-041	FLOWMETER: oxygen
MGFP-061	ADAPTER: suction
MMBE-101	BED: patient, electric, with mattress
MMBE-211.01	TRACK: patient lifter, fixed, ceiling mounted, straight
MMGE-019	CHAIR: patient
MMGE-191	CANNISTER: suction bottle
MMGE-436	KIT: emergency airway equipment, portable
MMSP-051	MEDICAL SERVICES PANEL: wall mounted
WIFX-155.01	WINDOW: fixed, external, double glazed, sill at 600H
WLFI-002	WALL FINISH: paint, clinical areas
WLFI-101	SPLASHBACK: vinyl



PLAN



3D VIEW

Copyright © 2026 Australasian Health Infrastructure Alliance (AHIA)

Scale

Plan + Elevations 1:50 @ A3 (0 0.5 1 1.5 2 2.5)

Details 1:25 @ A3 (0 0.25 0.5 0.75 1 1.25)

FOR GUIDANCE

Revision	Description	Date
3	Redocumented in new RLS format	18.11.2026
2	Updated following AHIA review	15.12.2025
1	First Issue	05.04.2018

Room Code 1BR-NE

Revision 3

Vizylab

1 Bed Room - Nested Ensuite

CARDIAC PROTECTION | **BODY PROTECTION** | HEARING LOOP | RADIATION SHIELDING | MAGNETIC / RF SHIELDING | HEPA FILTRATION | POSITIVE PRESSURE | NEGATIVE PRESSURE

CODE	DESCRIPTION
AFDPR-006.01	DOOR PROTECTION: plate, to 900H
AHWCV-002	WINDOW COVERING: blind, roller, double
DOHI-003.01	DOOR: hinged, 1 leaf, 900 clear opening, solid
DOHI-114.01	DOOR: hinged, 1 1/2 leaves, 1400 clear opening, solid, standard vision panel
ELGP-101.01	GPO: single, wall mounted, horizontal
ELGP-105	GPO: single, wall mounted, cleaner
ELGP-146	GPO: single, emergency power, on services panel
ELGP-151	GPO: single, emergency power, on pendant services head
ELGP-201.01	GPO: double, wall mounted, horizontal
ELGP-206.01	GPO: double, ceiling mounted, horizontal
ELPR-073	RCD: residual current device, on services panel
ELPR-083	RCD: residual current device, emergency power, on services panel
ELSW-001	SWITCH: light
ELSW-002	SWITCH: light, 2-gang
FIBM-019	WHITEBOARD: fixed, magnetic
FIDI-106	DISPENSER: PPE, disposable gloves, wall mounted
FIDI-231	DISPENSER: paper towel, wall mounted
FIDI-241	DISPENSER: alcohol-based hand rub, wall mounted
FIDI-256	DISPENSER: soap, wall mounted
FIDI-261	DISPENSER: soap, antiseptic, wall mounted
FIDI-386	FRAME: document, A4, wall mounted
FIHR-029	HOOK: equipment
FIHR-101	BRACKET: suction bottle, wall mounted
FIHR-111	BRACKET: sharps bin, wall mounted
FIHR-353	BRACKET: patient entertainment system, fixed, ceiling mounted
FIRT-051.03	TRACK: curtain, privacy, U-shaped
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved
FLVY-101	FLOOR FINISH: vinyl, seamless, standard slip resistance
FQBS-101	CHAIR: visitor, clinical areas
FQGE-101	CURTAIN: privacy screen
FQSN-100	BEDSIDE TABLE: floor standing, patient locker
FQTA-091	TABLE: overbed, mobile, height adjustable
FQWS-003	BIN: sharps, clinical, medium
FQWS-051	BIN: general waste, 20L
HYBA-121	BASIN: type B, handwashing
HYTP-067	TAPWARE: basin, tap set, wall mounted, lever handles
ITCL-133	BUTTON: nurse call, patient to staff call, with cancel, with handset connection point, on services panel
ITCL-181	BUTTON: nurse call, staff assist, with cancel, wall mounted
ITCL-191	BUTTON: nurse call, emergency, with cancel, wall mounted
ITCL-253	HANDSET: nurse call, patient to staff call, with light control, with patient entertainment system control, with speaker
ITCL-301	DISPLAY SCREEN: patient entertainment system
ITIN-021	OUTLET: data, double RJ45, ceiling mounted
ITIN-025	OUTLET: data, double RJ45, on services panel
ITIN-026	OUTLET: data, double RJ45, wall mounted
ITIN-071	OUTLET: MATV, ceiling mounted
ITNE-071	TELEPHONE: handset, desktop
JOBH-021	BEDHEAD: full height
JOCU-413	WARDROBE: built-in, single door, fixed shelves, clothing rail
LIFX-151	LIGHT: night, wall mounted
LIFX-161	LIGHT: reading, wall mounted
MGAS-022	OUTLET: medical air, on services panel
MGAS-042	OUTLET: oxygen (O2), on services panel
MGAS-062	OUTLET: suction, on services panel
MGFP-021	FLOWMETER: medical air
MGFP-041	FLOWMETER: oxygen
MGFP-061	ADAPTER: suction
MMBE-101	BED: patient, electric, with mattress
MMBE-211.01	TRACK: patient lifter, fixed, ceiling mounted, straight
MMGE-019	CHAIR: patient
MMGE-191	CANNISTER: suction bottle
MMGE-436	KIT: emergency airway equipment, portable
MMSP-051	MEDICAL SERVICES PANEL: wall mounted
WIFX-155.01	WINDOW: fixed, external, double glazed, sill at 600H
WLFI-002	WALL FINISH: paint, clinical areas
WLFI-101	SPLASHBACK: vinyl



ELEVATION 1

CONFIGURATION OF THE PATIENT ENTERTAINMENT SYSTEMS (TYPE, SIZE, MOUNTING AND LOCATION) IS TO BE CONFIRMED AT PROJECT LEVEL TO SUIT LOCAL ICT POLICIES AND OPERATIONAL MODELS.
SERVICES (POWER, DATA AND/OR AV CONNECTION) ARE TO BE CONFIRMED TO SUIT SELECTED SYSTEMS.
ENSURE APPROPRIATE STRUCTURAL SUPPORT IS PROVIDED



ELEVATION 2



ELEVATION 3

OPTIONAL. PROVISION OF A LIFTING TRACK IS TO BE CONFIRMED AT PROJECT LEVEL TO SUIT CLINICAL SERVICE REQUIREMENTS AND LOCAL WHS POLICIES FOR PATIENT HANDLING. CONFIGURATION, INSTALLATION (CEILING MOUNTED OR RECESSED), WEIGHT RATING/SAFE WORKING LOAD (SWL) REQUIREMENTS, AND EXTENT MUST ALSO BE CONSIDERED AND CONFIRMED BY PROJECT TEAMS. SELECTED EQUIPMENT IS TO MEET LOCAL IP&C POLICIES AND CLEANING REQUIREMENTS. REQUIREMENTS FOR CHARGING AND STORAGE OF PATIENT LIFTER MOTOR/CASSETTE IS TO BE CONFIRMED TO SUIT CLINICAL SERVICE REQUIREMENTS AND OPERATIONAL MODELS

CONFIGURATION OF A WARDROBE TO BE CONFIRMED TO SUIT OPERATIONAL MODELS FOR PATIENT PROPERTY STORAGE. TOP OF WARDROBE MAY BE DESIGNED FOR USE AS A SHELF, WITH A MAXIMUM HEIGHT OF 1500mm AFFL. IF HEIGHT OF WARDROBE IS RAISED, A BULKHEAD IS REQUIRED.



ELEVATION 4



MSP DETAIL (1 : 25 @ A3)

AustHFG Australasian Health Facility Guidelines
Copyright © 2026 Australasian Health Infrastructure Alliance (AHIA)

Scale

Plan + Elevations 1:50 @ A3 (0, 0.5, 1, 1.5, 2, 2.5)

Details 1:25 @ A3 (0, 0.25, 0.5, 0.75, 1, 1.25)

FOR GUIDANCE

Revision	Description	Date
3	Redocumented in new RLS format	18.11.2026
2	Updated following AHIA review	15.12.2025
1	First Issue	05.04.2018

Room Code 1BR-NE

Revision 3

Vizylab