
Patient Bay - Neonatal, Intensive Care / High Dependency

CARDIAC PROTECTION | BODY PROTECTION | HEARING LOOP | RADIATION SHIELDING | MAGNETIC / RF SHIELDING | HEPA FILTRATION | POSITIVE PRESSURE | NEGATIVE PRESSURE


CODE	DESCRIPTION
ELGP-105	GPO: single, wall mounted, cleaner
ELGP-136.01	GPO: single, emergency power, ceiling mounted, horizontal
ELGP-151	GPO: single, emergency power, on pendant services head
ELGP-181	GPO: single, UPS, on pendant services head
ELGP-231.01	GPO: double, emergency power, wall mounted, horizontal
ELPR-011	MONITOR: line isolation, wall mounted
ELPR-034	PANEL: UPS status indicator, on pendant services head
ELPR-073	RCD: residual current device, on services panel
ELSW-001	SWITCH: light
FIBM-019	WHITEBOARD: fixed, magnetic
FIDI-241	DISPENSER: alcohol-based hand rub, wall mounted
FIHR-104	BRACKET: suction bottle, pendant mounted
FIHR-115	BRACKET: sharps bin, trolley mounted
FIHR-215	BRACKET: computer display screen, single articulated, pendant mounted
FIHR-428	BRACKET: ventilator, continuous positive airway pressure (CPAP), on pendant services head
FLSK-021	SKIRTING: vinyl, integral with floor vinyl, coved
FLVY-101	FLOOR FINISH: vinyl, seamless, standard slip resistance
FQBS-101	CHAIR: visitor, clinical areas
FQBS-172	CHAIR: office, ergonomic, high
FQBS-284	RECLINER: visitor, clinical areas, lay flat, kangaroo care
FQCA-211	APPLIANCE: bottle warmer, benchtop, domestic
FQGE-101	CURTAIN: privacy screen
FQWS-003	BIN: sharps, clinical, medium
ITCL-121	BUTTON: nurse call, patient to staff call, with cancel, wall mounted
ITCL-125	BUTTON: nurse call, patient to staff call, with cancel, on pendant services head
ITCL-185	BUTTON: nurse call, staff assist, with cancel, on pendant services head
ITCL-251	HANDSET: nurse call, patient to staff call
ITCL-464	CAMERA: patient observation, neonatal, crib mounted
ITIN-014	OUTLET: data, single RJ45, on pendant services head
ITIN-016	OUTLET: data, single RJ45, wall mounted
ITIN-026	OUTLET: data, double RJ45, wall mounted
ITNE-076	TELEPHONE: handset, wall mounted
ITNE-111	COMPUTER: workstation on wheels (WOW), medical grade, all-in-one computer, keyboard and mouse, on cart
JOBE-001	BENCH: 450D, laminate
JOCU-221	CUPBOARD: under bench, double door
LIFX-122	LIGHT: procedure, minor, single articulated arm, 1 light head, wall mounted
LIFX-151	LIGHT: night, wall mounted
LIFX-161	LIGHT: reading, wall mounted
MGAS-021	OUTLET: medical air, on pendant services head
MGAS-041	OUTLET: oxygen (O2), on pendant services head
MGAS-061	OUTLET: suction, on pendant services head
MGFP-021	FLOWMETER: medical air
MGFP-041	FLOWMETER: oxygen
MGFP-061	ADAPTER: suction
MGFP-081	BLENDER: oxygen (O2) and medical air (MA)
MMGE-045	POLE: IV, mobile
MMGE-191	CANNISTER: suction bottle
MMGE-291	DEVICE: pump, infusion, single
MMGE-311	DEVICE: pump, breast milk
MMGE-349	DEVICE: amplitude-integrated electroencephalography (aEEG), with trolley
MMGE-371	DEVICE: patient, warming/cooling
MMHA-061	DEVICE: ventilator, neonatal
MMHA-064	DEVICE: ventilator, neonatal, CPAP
MMMA-016	INCUBATOR: infant, closed cot, humidicrib
MMMA-131	FRIDGE: milk, 15L nominal, single door, benchtop
MMPM-026	MONITOR: patient, high acuity, neonatal
MMSP-212	MEDICAL SERVICES PENDANT: double arm, vertical services head / vertical services head
MMTR-053	TROLLEY: airway/intubation, 750W x 490D x 900H nom
WLFI-002	WALL FINISH: paint, clinical areas
WLFI-011.03	WALL FINISH: vinyl, to 1200 AFFL
WLPR-006.03	WALL PROTECTION: corner guards, to 1200 AFFL

PROVISION OF EXTERNAL WINDOWS FOR NATURAL LIGHT AND EXTERNAL OUTLOOK IS DESIRABLE AND MAY BE PROVIDED TO INDIVIDUAL PATIENT BAYS OR SHARED BY A GROUP/POD OF BAYS. OVERALL DEPARTMENT LAYOUT WILL DETERMINE LOCATION OF EXTERNAL WINDOWS.




PLAN

THE PATIENT BAY MAY BE CONFIGURED WITH EITHER HALF HEIGHT WALLS OR FULL HEIGHT WALLS TO THE SIDES OF THE BAY.
HEIGHT OF WALLS AND PROVISION OF ANY GLAZING IS TO BE DETERMINED AT PROJECT LEVEL TO SUIT THE OVERALL DEPARTMENT LAYOUT AND REQUIREMENTS FOR PATIENT OBSERVATION.
LOCATION OF WALL MOUNTED ITEMS AND CONFIGURTION OF PRIVACY CURTAINS AND TRACKS ARE TO BE CONFIRMED TO SUIT WALL HEIGHTS.
WHERE HALF WALLS ARE PROVIDED, CURTAINS OF A SHORTER LENGTH MAY BE PROVIDED ABOVE TO ENSURE VISUAL PRIVACY CAN BE ACHIEVED WHEN REQUIRED.
CURTAINS AND CURTAIN TRACKS ARE OPTIONAL; UNITS MAY CHOOSE TO USE PORTABLE SCREENS IN LIEU OF CEILING MOUNTED PRIVACY CURTAINS




ELEVATION 1


MEDICAL SERVICE PANEL(S) MAY BE PROVIDED INSTEAD OF A PENDANT AND MUST BE CONFIRMED AT PROJECT LEVEL TO SUIT CLINICAL SERVICES REQUIREMENTS AND EQUIPMENT SELECTION.
WHERE MEDICAL SERVICES PANEL(S) ARE PROVIDED INSTEAD OF A PENDANT, THE CEILING HEIGHT IS TO BE 2700mm. CEILING HEIGHT OF 3000mm IS ONLY REQUIRED FOR PENDANT INSTALLATION AND ARM CLEARANCES



ELEVATION 2



3D VIEW



ELEVATION 3

PENDANT R SERVICES HEAD

CODE	DESCRIPTION	Count
ELGP-151	GPO: single, emergency power, on pendant services head	6
ELGP-181	GPO: single, UPS, on pendant services head	2
ELPR-034	PANEL: UPS status indicator, on pendant services head	1
ELPR-073	RCD: residual current device, on services panel	1
ELSW-001	SWITCH: light	1
FIHR-104	BRACKET: suction bottle, pendant mounted	2
FIHR-215	BRACKET: computer display screen, single articulated, pendant mounted	1
FIHR-428	BRACKET: ventilator, continuous positive airway pressure (CPAP), on pendant services head	1
ITCL-125	BUTTON: nurse call, patient to staff call, with cancel, on pendant services head	1
ITCL-185	BUTTON: nurse call, staff assist, with cancel, on pendant services head	1
ITIN-014	OUTLET: data, single RJ45, on pendant services head	3
MGAS-021	OUTLET: medical air, on pendant services head	2
MGAS-041	OUTLET: oxygen (O2), on pendant services head	2
MGAS-061	OUTLET: suction, on pendant services head	1
MGFP-021	FLOWMETER: medical air	2
MGFP-041	FLOWMETER: oxygen	2
MGFP-061	ADAPTER: suction	2
MGFP-081	BLENDER: oxygen (O2) and medical air (MA)	1
MMGE-191	CANNISTER: suction bottle	2
MMHA-061	DEVICE: ventilator, neonatal	1
MMHA-064	DEVICE: ventilator, neonatal, CPAP	1
MMPM-026	MONITOR: patient, high acuity, neonatal	1

PENDANT L SERVICES HEAD

CODE	DESCRIPTION	Count
ELGP-151	GPO: single, emergency power, on pendant services head	6
ELGP-181	GPO: single, UPS, on pendant services head	2
ELPR-034	PANEL: UPS status indicator, on pendant services head	1
ELPR-073	RCD: residual current device, on services panel	1
FIHR-104	BRACKET: suction bottle, pendant mounted	2
ITCL-125	BUTTON: nurse call, patient to staff call, with cancel, on pendant services head	1
ITIN-014	OUTLET: data, single RJ45, on pendant services head	3
MGAS-021	OUTLET: medical air, on pendant services head	2
MGAS-041	OUTLET: oxygen (O2), on pendant services head	2
MGAS-061	OUTLET: suction, on pendant services head	3
MGFP-021	FLOWMETER: medical air	2
MGFP-041	FLOWMETER: oxygen	2
MGFP-061	ADAPTER: suction	2
MMGE-191	CANNISTER: suction bottle	2
MMGE-291	DEVICE: pump, infusion, single	2

AusHFG Australasian Health Facility Guidelines
Copyright © 2026 Australasian Health Infrastructure Alliance (AHIA)

Scale
Plan + Elevations 1:50 @ A3 (0 0.5 1 1.5 2 2.5)
Details 1:25 @ A3 (0 0.25 0.5 0.75 1 1.25)

FOR GUIDANCE

Revision	Description	Date
6	Redocumented in new RLS format with panorama	18.11.2026
5	Updated following AHIA review	03.12.2025
4	Updated following AHIA review	13.05.2020
3	New Standard Component	20.03.2017

Room Code PTB-NEO-IC
Revision 6

Vizylab