Department Standard Components Room Tag: 3920

Room Name Shower - Accessible, 4m2 Room Code: SHD

Net Room Area Briefed 4.0 M2

No of Rooms

Subtotal of Briefed Area 4.00 M2

Hours of Operation 24 Hours

Occupancy 1 patie

Also covers these Rooms

1 patient; 1-2 staff assisting as required

Description/ Special Requirements The Shower - Accessible is a room containing a shower for use by people with disabilities, either independently or with nurse assistance. The Room is to comply with AS 1428.

Acoustics: Sound attenuation level - high; Acoustic privacy required.

Body Protected electrical area

Additional Design Considerations:

- Access is required for commode chairs/ wheelchairs
- The floor must not have a raised hob additional text
- The door will require escape hardware to allow staff access in an emergency

Amendment

05.04.05, - First Draft

10.03.09, - 2009 AUSHFG Review; name & description modified, default finishes noted, note to benchseat added

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5023	Ceiling	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to Acrovyn
9001	Doors	Solid Core	Paint	Single leaf		910mm clear; Outward opening; privacy latch; emergency release
1025	Floor finish	Vinyl, non slip	Studded	Seamless, coved		Default = vinyl; tiles also acceptable
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		Default = vinyl; tiles for tiled floor
3000	Wall finish	Paint	Acrylic, washable			
3070	Wall finish	Vinyl	Prefinished	Wall vinyl full height		to wet areas; Default = vinyl; tiles also acceptable

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
1002	Bench seat: fold up/down	Furniture/ Fitting	1	1	reinforced for up to 150kg weight
3400	Coathook	Metalwork	1	2	1 at 1200H for wheelchair users
4800	Curtain track: shower	Metalwork	1	1	

Australasian FG
Provided by HPI for AHIA & UNSW for: Issue No: 3 Print Date: 26 Mar 2009
Australasian HFG
Issue Date: 30 Mar 2009
Page 1 of 2

Department	Standard Components	Room Tag: 3920
Room Name	Shower - Accessible, 4m2	Room Code: SHD

ID	Description	Category	Group	Qty	Selection / Remarks
5300	Curtain: shower	Furniture/ Fitting	3	1	
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	
8450	Grab rail: Shower	Metalwork	1	1	T bar
8450	Grab rail: Shower	Metalwork	1	1	L shaped, optional
20650	Soap/ shampoo holder	Furniture/ Fitting	1	1	
23700	Towel rail	Metalwork	1	1	

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Тар	Dns	Gas	Selection / Remarks
47400	Shower: hand-held	1	1			yes		yes	yes	yes		

Services

ID	Description	Service Category	Qty	Selection / Remarks
5000	Airconditioning	HVAC		
5019	Exhaust	HVAC		
4033	Floor waste	Hydraulics	1	
6000	General fluorescent	Lighting		
8080	Emergency call	Nurse Call	1	+ indicator button & light
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light, water proof
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light, water proof