

Australasian HFG Standard Components

Milestone: Default

Room Data Sheets

Department	Standard Components	Room Tag: 3910
Room Name	Shower - Decontamination	Room Code: SHDEC
Area	8.0 M2	
No of Rooms	1	
Subtotal of Area	8.0 M2	
Hours of Operation	24 Hours	
Occupancy	1 - 2	
Also covers these Rooms		
Description/ Special Requirements	The Decontamination Shower is provided to shower patients who arrive in the Unit contaminated with toxic and/or infectious substances. The room will include a flexible water hose, floor drain and contaminated water trap. The shower should be accessible from the ambulance bay without entering any other part of the Unit. A Personal Protective Equipment Bay may be located in close proximity.	
Amendment	14.02.05, - First Draft	

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5023	Ceiling	Plasterboard	Prefinished	Water resistant, drop in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to Acrovyn
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to Acrovyn
9001	Doors	Solid Core	Paint	Single leaf		910mm clear; Outward opening; privacy latch; emergency release.
1025	Floor finish	Vinyl, non slip	Studded	Seamless, coved		tiles also acceptable
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		or tiles for tiled floor
3070	Wall finish	Vinyl	Prefinished	Wall vinyl full height		to wet areas; tiles also acceptable

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
6152	Dispenser: disposable glove	Furniture/ Fitting	2	1	

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
47605	Shower: decontamination	1	1	___	___	yes	___	yes	yes	yes	___	in lockable cabinet

Services

ID	Description	Service Category	Qty	Remarks
5019	Exhaust	HVAC		
5015	Ventilation	HVAC		
4030	Drainage	Hydraulics	1	to contaminated water trap
6001	General: colour corrected	Lighting		

Australasian HFG Standard Components

Milestone: Default

Room Data Sheets

Department
Room Name

Standard Components
Shower - Decontamination

Room Tag: 3910
Room Code: SHDEC

ID	Description	Service Category	Qty	Remarks
7020	Medical Air (MA)	Medical Gases	1	in lockable recess, optional
7000	Oxygen (O2)	Medical Gases	1	in lockable recess, optional
7040	Suction	Medical Gases	1	in lockable recess, optional
8080	Emergency call	Nurse Call	1	
11000	Wall panel	Services Panels	1	recessed, lockable cover, if gases required