Australasian Standard Project

Room Data Sheets

Department Standard Components

Store - Bulk, 20m2 Room Code: STBK-20

Room Tag: 4130

Area 20.0 M2

No of Rooms

Room Name

20.0 M2

Subtotal of Area

20.0 M2 24 Hours

Hours of Operation
Occupancy

Up to 3

Also covers these

Rooms

Description/ Special Requirements The Bulk Store is the primary storage area for all delivered supplies and stores prior to distribution to hospital Units when requisioned or on an imprest supply system. The area requires security and controlled access. The Bulk Store should be located with ready access to the loading dock area.

Amendment

14.03.05, - First Draft

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5030	Ceiling	Plasterboard	Prefinished	Drop-in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to 'Acrovyn'
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to 'Acrovyn'
9210	Doors	Solid Core	Paint	Double leaf		1800mm clear opening, lockable
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
13660	Metal shelving: 900x400x2100	Furniture/ Fitting	3	16	

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Тар	Dns	Gas	Selection
43550	Refrigerator: double door	3	1	yes								optional

Services

ID	Description	Service Category		Remarks
1006	Voice / Data outlet: double	Communications	1	1 for fridge temp alarm if required
1006 Voice / Data outlet: double		Communications	1	1 outlet for telephone
5000 Airconditioning		HVAC		
6000 General fluorescent		Lighting		
9001 GPO: Double		Power	1	
9011	GPO: Emergency power, double	Power	1	for refrigerator (optional)

Australasian K FG

Provided by HPI for :

Issue No: 1 Issue Date: 11 May 2006

Print Date:

11 May 2006 Page 1 of 1