Australasian Standard Project
Room Data Sheets

Department	Standard Components	**Room Tag:**	**4140**
Room Name	Store - Bulk, 40m2	**Room Code:**	**STBK-40**

Area	40.0 M2
No of Rooms	1
Subtotal of Area	40.0 M2
Hours of Operation	24 Hours
Occupancy	Up to 3
Also covers these Rooms	
Description/ Special Requirements	The Bulk Store is the primary storage area for all delivered supplies and stores prior to distribution to hospital Units when requisioned or on an imprest supply system. The area requires security and controlled access. The Bulk Store should be located with ready access to the loading dock area.
Amendment	14.03.05, - First Draft

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5030	Ceiling	Plasterboard	Prefinished	Drop-in tiles, 600x1200		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to Acrovyn
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to Acrovyn
9210	Doors	Solid Core	Paint	Double leaf		1800mm clear opening, lockable
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
4020	Wall protection	Composite	Prefinished PVC	Crash rail at 900 AFFL		Equal to Acrovyn, as required

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection
13660	Metal shelving: 900x400x2100	Furniture/ Fitting	3	25	

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Tap	Dns	Gas	Selection
43550	Refrigerator: double door	3	2	yes	___	___	___	___	___	___	___	optional

Services

ID	Description	Service Category	Qty	Remarks
1006	Voice / Data outlet: double	Communications	2	for fridge temp alarms if required
1006	Voice / Data outlet: double	Communications	1	1 outlet for telephone
5000	Airconditioning	HVAC		
6000	General fluorescent	Lighting		
9001	GPO: Double	Power	1	

Australasian HFG

Provided by HPI for :
HCAMC

Issue No: 1
Issue Date: 4 Aug 2005

Print Date: 4 Aug 2005
Page 1 of 2

This document is for advisory purpose only

	Department	Standard Components			Room Tag:	4140
	Room Name	Store - Bulk, 40m2			Room Code:	STBK-40

ID	Description	Service Category	Qty	Remarks
9011	GPO: Emergency power, double	Power	2	for refrigerators (optional)

Australasian HFG

Provided by HPI for :

HCAMC

Issue No: 1

Issue Date: 4 Aug 2005

Print Date: 4 Aug 2005

Page 2 of 2

This document is for advisory purpose only