Standard Components Room Tag: 4650 Department **Treatment Room Room Name** Room Code: TRMT

Net Room Area Briefed 14.0 M2

No of Rooms

Subtotal of Briefed Area 14.00 M2 **Hours of Operation**

> 1 patient; 1-2 staff Occupancy

24 Hours

Also covers these Rooms

Description/ **Special Requirements** The Treatment Room provides a controlled environment, privacy and facilities for carrying out consultations, examinations and minor procedures.

Acoustics: Sound attenuation level - high; Acoustic privacy is required.

Body Protected electrical area

12.12.03, - First Draft **Amendment**

28.01.05, - BOB User Review, Group 3 fittings modified

10.03.09, - 2009 AUSHFG Review; Description modified, joinery made

optional, FF modified

Room Fabric and outline specifications

ID	Fabric	Material	Finish	Specification	Selection	Remarks
5010	Ceiling	Plasterboard	Paint, washable	Flush set, suspended		
6030	Cornice	Aluminium	Powdercoat	24mm shadow angle		
8010	Door protection	Composite	Prefinished PVC	Protection plate to 900 AFFL		Equal to 'Acrovyn'
8040	Door protection	Composite	Prefinished PVC	To door frame		Equal to 'Acrovyn'
9125	Doors	Solid Core/ Glass	Paint	1 1/2 leaf, observation panel		1400mm clear opening; lockable
9004	Doors	Solid Core/ Glass	Paint	Single leaf, observation panel		910mm clear opening, to Clean Utility, optional
1000	Floor finish	Vinyl	Standard slip resistant	Seamless, coved		
2000	Skirting	Vinyl	Prefinished	Floor vinyl coved, 150 mmH		
3000	Wall finish	Paint	Acrylic, washable			
3052	Wall finish	Vinyl	Prefinished	Wall vinyl to 1500 AFFL		

Fittings and Furniture (FF)

ID	Description	Category	Group	Qty	Selection / Remarks
150	Air flowmeter	Furniture/ Fitting	3	1	to services panel
1050	Bench: laminate	Furniture/ Fitting	1	1	optional
1470	Bracket: sharps	Furniture/ Fitting	2	1	on trolley
1465	Bracket: suction bottle	Furniture/ Fitting	2	1	

Australasian FG Provided by HPI for AHIA & UNSW for : 27 Mar 2009 Issue No: 3 Print Date: Issue Date: 30 Mar 2009 Page 1 of 3

Department **Room Name**

Standard Components Treatment Room

Room Tag: 4650 Room Code: TRMT

3350		Category	Group	Qty	Selection / Remarks
0000	Clock: battery operated	Furniture/ Fitting	3	1	
1410	Cupboard: under bench	Furniture/ Fitting	1	1	adjustable shelf, optional
1470	Cupboard: wall mounted, lockable	Furniture/ Fitting	1	1	over bench, adjustable shelf, optional
1600	Curtain track: bed screen	Metalwork	1	1	to door opening
5000	Curtain: bed screen	Furniture/ Fitting	3	1	
3152	Dispenser: disposable glove	Furniture/ Fitting	2	1	3 compartments
3157	Dispenser: medicated hand gel	Furniture/ Fitting	2	1	
3154	Dispenser: paper/ hand towel	Furniture/ Fitting	2	1	to basin
3156	Dispenser: soap	Furniture/ Fitting	2	1	to basin
3158	Dispenser: soap antiseptic	Furniture/ Fitting	2	1	to basin
12900	Louvred panel: for storage-bins	Metalwork	1	2	over bench, optional
16250	Oxygen flowmeter	Furniture/ Fitting	3	2	to services panel
19700	Sharps bin	Furniture/ Fitting	3	1	on trolley
21755	Storage bins	Furniture/ Fitting	3	5	for louvred panels, optional
21950	Suction adapter	Furniture/ Fitting	3	1	to services panel
600	Trolley: dressing	Furniture/ Fitting	3	1	600x600x900mmH
24100	Waste bin: paper, 20 Litre	Furniture/ Fitting	3	1	to basin

Fixtures, Equipment and associated Services (FE)

ID	Description	Group	Qty	Ele	Data	CdW	HtW	WmW	Тар	Dns	Gas	Selection / Remarks
3100	Basin: scrub, Type A	1	1			yes		yes	yes	yes		refer to BHWS-A (sim)
3700	Bed: inpatient, electric	3		yes								spatial provision only
11415	Computer: PACS	3	1	yes	yes							optional
31700	Light: examination, ceiling	1	1	yes								
43800	Refrigerator: under-bench, 120 Litre	3	1	yes								optional
54510	Telephone: handset, standard	3	1		yes							to bench, optional
68700	Xray viewer: 2 screen	1	1	yes								optional

Services

ID	Description	Service Category	Qty	Selection / Remarks
1006	Voice / Data outlet: double	Communications	2	1 outlet on each panel for telephone
5000	Airconditioning	HVAC		
6001	General: colour corrected	Lighting		
6055	Special: task light, built in	Lighting		under O/H cupboards
7020	Medical Air (MA)	Medical Gases	1	
7000	Oxygen (O2)	Medical Gases	2	
7040	Suction	Medical Gases	1	
8080	Emergency call	Nurse Call	1	+ indicator button & light
8005	Patient call handset	Nurse Call	1	call button on the handset
8000	Patient/ Staff call	Nurse Call	1	+ indicator button & light
8010	Staff/ Nurse assist call	Nurse Call	1	+ indicator button & light
9040	Body protected	Power		
9015	GPO: Cleaner	Power	1	
9001	GPO: Double	Power	1	to bench
9010	GPO: Emergency power, single	Power	2	to patient services panel
9000	GPO: Single	Power	4	to patient services panel



Issue No: 3

Issue Date: 30 Mar 2009

Print Date:

27 Mar 2009 Page 2 of 3

Australasian Standard Project

Room Data Sheets

Department	Standard Components	Room Tag: 4650
Room Name	Treatment Room	Room Code: TRMT

ID	Description	Service Category C		Selection / Remarks
9000	GPO: Single	Power	2	XRV, fridge
9060	GPO: Special: for equipment	Power	1	exam light
11000	Wall panel	Services Panels	1	