

AX APPENDICES

AX.01 Schedule of Accommodation

A Generic Schedule of Accommodation for an Allied Health / Therapy Unit is outlined below for role delineation levels 4, 5 and 6 (refer to NSW Health, 2002, Guide to the Role Delineation of Health Services).

The reference to role delineation levels is used as a guide only. The size of the Allied Health/Therapy Unit will ultimately depend on the service mix, care settings and patient caseload to be accommodated.

The number of treatment spaces and other support spaces to be provided should be informed through an analysis of projected room utilisation, including the opportunity to share facilities between disciplines where appropriate.

The 'Room/ Space' column describes each room or space within the Unit. Some rooms are identified as 'Standard Components' (SC) or as having a corresponding room which can be derived from a SC. These rooms are described as 'Standard Components –Derived' (SC-D). The 'SD/SD-C' column identifies these rooms and relevant room codes and names are provided.

All other rooms are non-standard and will need to be briefed using relevant functional and operational information provided in this HPU.

In some cases, Room/ Spaces are described as 'Optional' or 'o'. Inclusion of this Room/ Space will be dependent on a range of factors such as operational policies or clinical services planning.

ENTRY / RECEPTION

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m ² Level 4	Qty x m ² Level 5	Qty x m ² Level 6	Remarks
RECL-10	Reception / Clerical, 10m ²	Yes	1 x 10	1 x 12	1 x 12	2 staff
STPS-8	Store - Photocopy / Stationery, 8m ²	Yes	1 x 8	1 x 8	1 x 8	
STFS-10	Store - Files, 10m ²	Yes	1 x 4	1 x 6	1 x 6	
WAIT-10	Waiting, 10m ²	Yes	1 x 12	1 x 21	1 x 32	Based on 1.2m ² per person, 1.5m ² for wheelchairs/ scooters. Modify to circumstances
BWD-1	Bay - Water Dispenser	Yes	1 x 1	1 x 1	1 x 1	
BWC	Bay - Wheelchair Park	Yes	1 x 4	1 x 4	1 x 4	
WCPU-3	Toilet - Public, 3m ²	Yes	0	1 x 4	1 x 4	Or access to same
WCAC	Toilet - Accessible, 6m ²	Yes	1 x 6	1 x 6	1 x 6	
	Discounted Circulation %		30%	30%	30%	

Australasian Health Facility Guidelines

ASSESSMENT / TREATMENT AREAS - Physiotherapy

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m2 Level 4	Qty x m2 Level 5	Qty x m2 Level 6	Remarks
GYAH-60	Gymnasium, 60m2	Yes	1 x 80	1 x 100	1 x 120	<i>Individual Treatment</i> Modify to suit range of equipment and number of patients to be accommodated. Approximately 7m2 per patient. See final appendix for gym equipment spatial requirements. Includes curtained treatment bays, mobile equipment, write-up bays and hand-wash basin (*See note above).
GYAH-60	Gymnasium, 60m2	Yes	0	1 x 50	1 x 80	<i>Group Classes</i> Modify to suit range of equipment and number of patients to be accommodated. Approximately 6m2 per patient for group classes. May include treadmills, bikes, arm ergometer, steps.
	Physiotherapy Treatment Cubicle - Standard		7.5	7.5	7.5	If not incorporated within gymnasium space. Number will depend on frequency of utilisation. Includes single plinth: 10m2 required for traction, double or bariatric sized plinths
STEQ-14	Store - Equipment, 14m2	Yes	1 x 14	1 x 20	1 x 20	Gym / exercise equipment. Spatial requirement will be project specific.
BMEQ-4	Bay - Mobile Equipment, 4m2	Yes	1 x 4	1 x 10	1 x 10	Parking for various items of electrotherapy equipment near Outpatient Area
BWD-1	Bay - Water Dispenser	Yes	1 x 1	1 x 1	1 x 1	Disabled access. In / near gymnasium if not in close proximity to waiting area water fountain.
PLST	Plaster Room	Yes	0	1 x 14	1 x 14	
	Outdoor Gait Assessment					Inclusion dependent on service profile.
	Discounted Circulation %		30%	32%	32%	

Note:

- two gymnasiums may be required, for example to separate orthopaedics/vascular patients from neurology; and
- gymnasiums located within community health services / level 2-3 services usually require a smaller space of approximately 60m2 (subject to number of patients and equipment being accommodated).

ASSESSMENT / TREATMENT AREAS - Occupational Therapy

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m2 Level 4	Qty x m2 Level 5	Qty x m2 Level 6	Remarks
	Occupational Therapy Room - Light - Adult		1 x 28	1 x 42	1 x 70	Approximately 7m2 per patient
	Occupational Therapy Room - Light - Paediatric		-	1 x 40	1 x 40	10m2 per patient
	Hand Therapy / Splinting Room		-	1 x 16	1 x 16	Potential for sharing with physiotherapy.
STEQ-14	Store - Equipment	Yes	1 x 10	1 x 14	1 x 14	Capacity dependent on equipment to be accommodated. May include assessment wheelchairs.
ADLB	ADL Bathroom	Yes	1 x 12	1 x 12	1 x 12	
	ADL Computer Room		1 x 12	1 x 12	1 x 12	2 patients.
ADLK-OP	ADL Kitchen - Open Bay	Yes	1 x 12	1 x 12	1 x 12	
ADLL	ADL Laundry	Yes	1 x 8	1 x 8	1 x 8	
	Occupational Therapy Room - Workshop		0	1 x 50	1 x 50	5 patients.
	Store - Occupational Therapy Workshop		0	1 x 20	1 x 20	If workshop provided subject to equipment being accommodated.
	Discounted Circulation %		30%	30%	30%	

Australasian Health Facility Guidelines

ASSESSMENT / TREATMENT AREAS - Speech Pathology

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m2 Level 4	Qty x m2 Level 5	Qty x m2 Level 6	Remarks
CONS	Consult Room	Yes	12	12	12	Number depends on service profile. 15m2 for child related services
STGN-8	Store - General, 8m2	Yes	1 x 8	1 x 8	1 x 8	
	Discounted Circulation		30%	32%	32%	

ASSESSMENT / TREATMENT AREAS - Other Allied Health

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m2 Level 4	Qty x m2 Level 5	Qty x m2 Level 6	Remarks
PODTR-14	Podiatry Treatment, 14m2	Yes	1 x 14	1 x 14	1 x 14	May be multipurpose.
AUDIO	Audiology Testing Room	Yes	1 x 14	1 x 14	1 x 14	
	Observation / Viewing Room		1 x 9	1 x 9	1 x 9	May be collocated with multidisciplinary therapy area. Technology may provide alternative solution.
CONS	Consult Room	Yes	12	12	12	Flexible use, number required will depend on frequency of utilisation, assuming efficiencies between disciplines. 15m2 for child related services.
INTF	Interview Room	Yes	12	12	12	Flexible use. Number required will depend on frequency of utilisation, assuming efficiencies between disciplines.
TRMT	Treatment Room	Yes	14	14	14	Respiratory and other conditions requiring privacy.
MEET-L-20	Meeting Room, 20m2	Yes	0	1 x 20	1 x 30	Counselling, education sessions. Spatial allocation will depend on the number of people to be accommodated.
	Discounted Circulation		30%	32%	32%	

Note: Major audiology services will need to be separately briefed and may have a number of rooms performing different functions.

SUPPORT AREAS

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m2 Level 4	Qty x m2 Level 5	Qty x m2 Level 6	Remarks
BLIN	Bay - Linen	Yes	1 x 2	2 x 2	2 x 2	
BRES	Bay - Resuscitation Trolley	Yes	Shared	1 x 1.5	1 x 1.5	
STGN-9	Store - General, 9m2	Yes	1 x 9	1 x 9	1 x 9	Consumables. Separate secure stores may be required by individual disciplines e.g. neuropsychology.
CLUP-7	Clean Up Room, 7m2	Yes	1 x 7	1 x 7	1 x 7	
DISP-8	Disposal Room, 8m2	Yes		1 x 8	1 x 8	No. to be determined through service planning
CLRM-5	Cleaner's Room, 5m2	Yes	1 x 5	1 x 5	1 x 5	
	Equipment Loan Pool		1 x 14	1 x 20	1 x 20	Size will depend on extent of service.
CLUP-7	Equipment Clean Up Room			1 x 7	1 x 7	For returned loan equipment.
	Discounted Circulation %		25%	25%	25%	

STAFF AREAS - OFFICES AND AMENITIES

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m2 Level 4	Qty x m2 Level 5	Qty x m2 Level 6	Remarks
OFF-S12	Office - Single Person, 12m2	Yes		1 x 12	1 x 12	Allied Health Director
OFF-S9	Office - Single Person, 9m2	Yes	9	9	9	Departmental heads
	Office - Workstation, 4.4m2		4.4	4.4	4.4	
	Office - Write-up		3	3	3	Staff or students
MEET-L-20	Meeting Room, 20m2	Yes	0	1 x 20	1 x 20	Depends on number of people to be accommodated. Potential to share with other departments.
PROP-2	Property Bay - Staff	Yes	1 x 2	2 x 2	2 x 2	
SHST	Shower - Staff, 3m2	Yes	1 x 3	1 x 3	1 x 3	
WCST	Toilet - Staff, 3m2	Yes	1 x 3	2 x 3	2 x 3	
	Discounted Circulation		20%	20%	20%	

Note that the spatial allocation for support areas (office, staff and patient amenities and storage) will require adjustment to suit local requirements.

OTHER AREAS - HYDROTHERAPY

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m2	Remarks
OFF-S9	Office - Single Person - 9m2	Yes	1 x 9	Workstation only may be provided for smaller areas
HYDP	Hydrotherapy Pool	Yes	1 x 240	90m2 pool plus surrounds. Assumes 12 patients (4m2 per additional patient). Includes open shower area and linen trolley/skips. A smaller pool (total 90m2 including pool surrounds) may be provided for smaller services.
STGN-9	Store - General, 9m2	Yes	1 x 16	Hydrotherapy aids and equipment (that may be wet or damp). Adjusted to suit storage requirements.
SHD	Shower - Accessible, 4m2	Yes	1 x 4	
WCAC	Toilet - Accessible, 6m2	Yes	1 x 6	
CHPT-12	Change Room - Patient (Male / Female)	Yes	2 x 24	Includes toilet, shower, change.
CHST-10	Change Room - Staff (Male / Female), 10m2	Yes	1 x 6	Includes staff lockers
	Plant Room		1 x 20	
	Discounted Circulation %		20%	

AX.02 Functional Relationships / Diagrams