

AX APPENDICES

AX.01 Schedule of Accommodation

A Schedule of Accommodation follows for one PET / CT camera.

The 'Room/ Space' column describes each room or space within the Unit. Some rooms are identified as 'Standard Components' (SC) or as having a corresponding room which can be derived from a SC. These rooms are described as 'Standard Components –Derived' (SC-D). The 'SD/SD-C' column identifies these rooms and relevant room codes and names are provided.

All other rooms are non-standard and will need to be briefed using relevant functional and operational information provided in this HPU.

In some cases, Room/ Spaces are described as 'Optional' or 'o'. Inclusion of this Room/ Space will be dependent on a range of factors such as operational policies or clinical services planning.

PET / CT SUITE

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m2 Level 2	Remarks
WAIT-10	Waiting, 10m2	Yes	1 x 12	Entry lobby / public waiting, may be shared
WCAC	Toilet - Accessible, 6m2	Yes	1 x 6	May be shared, public
RECL-10	Reception / Clerical, 10m2	Yes	1 x 10	1 staff; may be shared
OFF-2P	Office - 2 Person Shared, 6m2	Yes	1 x 12	Administrative functions. Quantity dependant on staffing establishment
STPS-8	Store - Photocopy / Stationery, 8m2	Yes	1 x 8	
PROP-2	Property Bay - Staff	Yes	1 x 2	
CHPT-D	Change Cubicle - Accessible, 4m2	Yes	1 x 4	Pre and post-scan; radiation shielded
WCAC	Toilet - Accessible, 6m2	Yes	1 x 6	Radiation shielded, patient.
SHD	Shower - Accessible, 4m2	Yes	1 x 4	For emergencies; radiation shielded
CONS	Consult Room	Yes	1 x 12	May also have office function
	Uptake Room		1 x 12	Refer Note 1 above
	Uptake / Induction Room		1 x 18	Radiation shielded
PBTR-H-9	Patient Bay - Holding, 9m2	Yes	3 x 9	May be shared with adjoining unit
SSTN-10	Staff Station, 10m2	Yes	1 x 8 (o)	May be shared
BBEV-OP	Bay - Beverage, Open Plan, 4m2	Yes	1 x 4	Include ice machine
BWC	Bay - Wheelchair Park	Yes	1 x 4	Increase to 10m2 area if to accommodate transport staff, trolley, handbasin
BLIN	Bay - Linen	Yes	1 x 2	
BRES	Bay - Resuscitation	Yes	1 x 1.5	
BHWS-B	Bay - Handwashing, Type B	Yes	1 x 1	In corridor
STSS-12	Store - Sterile Stock, 12m2	Yes	1 x 12	
DTUR-S	Dirty Utility - Sub, 8m2	Yes	1 x 8	May be shared
	Discharge Lounge		1 x 8	Radiation shielded. Collocate with Beverage Bay
	PET / CT Scanner		1 x 50	Sized to suit the equipment selected.
	Control Room		1 x 16	May need to be radiation shielded
	PET / CT Plant / Equipment Room		1 x 18	Includes server etc. Air-conditioned
STEQ-14	Store - Equipment, 14m2	Yes	1 x 14	General items
	Hot Laboratory		1 x 18	
XRRR	X-Ray Viewing & Reporting Room	Yes	1 x 18	3 workstations
OFF-S12	Office - Single Person, 12m2	Yes	1 x 12	Staff Specialist / Unit Director
OFF-S9	Office - Single Person, 9m2	Yes	2 x 9	Chief Technologist & Physicist
WCST	Toilet - Staff, 3m2	Yes	1 x 3	Within envelope of Unit
CLRM	Cleaner's Room, 5m2	Yes	1 x 5	May be shared with adjoining unit
	Discounted Circulation		32%	

Note: Radiation shielded. Number of rooms based on assessment of workload. NB: one room requires GA capability.

STAFF AREAS

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m2 Level 2	Remarks
SRM-15	Staff Room, 15m2	Yes	1 x 15	Includes Beverage Bay
MEET-12	Meeting Room, 12m2	Yes	1 x 12	
WCST	Toilet - Staff, 3m2	Yes	2 x 3	
SHST	Shower - Staff, 3m2	Yes	1 x 3	
	Discounted Circulation		25%	

The above may be shared with an adjoining unit.

CYCLOTRON AND RADIOPHARMACY

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m2 Level 2	Remarks
	Cyclotron		80	Nominal size only
	Radiopharmacy		150	Nominal only
	Staff & Technical Support		70	Nominal only
	Discounted Circulation		32%	