

AX APPENDICES

AX.01 Schedule of Accommodation

A Schedule of Accommodation follows.

The 'Room/ Space' column describes each room or space within the Unit. Some rooms are identified as 'Standard Components' (SC) or as having a corresponding room which can be derived from a SC. These rooms are described as 'Standard Components –Derived' (SC-D). The 'SD/SD-C' column identifies these rooms and relevant room codes and names are provided.

All other rooms are non-standard and will need to be briefed using relevant functional and operational information provided in this HPU.

In some cases, Room/ Spaces are described as 'Optional' or 'o'. Inclusion of this Room/ Space will be dependent on a range of factors such as operational policies or clinical services planning.

ENTRY / RECEPTION

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m2 2 Cameras	Qty x m2 6 Cameras	Remarks
	Entry Lobby		1 x 6	1 x 6	
WAIT-10	Waiting, 10m2	Yes	1 x 10	1 x 15	
RECL-10	Reception / Clerical, 10m2	Yes	1 x 10	1 x 15	1 and 2 staff
MEET-9	Meeting Room, 9m2	Yes	1 x 9	1 x 9	Private consultations, bookings etc
OFF-2P	Office - 2 Person, Shared, 12m2	Yes	1 x 12	1 x 15	2 & 3 staff
STPS-8	Store - Photocopy / Stationery, 8m2	Yes	1 x 8	1 x 8	
STFS-10	Store - Files, 10m2	Yes	1 x 8	1 x 8	
	Discounted Circulation		25%	30%	

PATIENT CARE AREA

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m2 2 Cameras	Qty x m2 6 Cameras	Remarks
	Waiting - Dosed	Yes	1 x 12	1 x 20	Outpatients
	Waiting - Undosed	Yes	1 x 6	1 x 9	
PLAP-10	Play Area - Paediatric, 10m2	Yes	1 x 10 (o)	1 x 10 (o)	
WCPT	Toilet - Patient, 4m2	Yes	2 x 4	2 x 4	1 male, 1 female
WCAC	Toilet - Accessible, 6m2	Yes	1 x 5	1 x 5	
SHPT	Shower - Patient, 4m2	Yes	1 x 4	1 x 4	For post-stress testing patient hygiene and incontinent patients
BBEV-OP	Bay - Beverage, Open Plan, 4m2	Yes	1 x 4	1 x 4	
BWC	Bay - Wheelchair Park	Yes	1 x 4	1 x 4	May also include a patient trolley
	Entry Lobby - Inpatient		1 x 6(o)	1 x 6	
PBTR-H-9	Patient Bay - Holding, 9m2	Yes	3 x 9	8 x 9	Curtained bays
BHWS-B	Bay - Handwashing, Type B	Yes	1 x 1	2 x 1	Part of Inpatient Holding Area
	Staff Station / Clean Utility		1 x 8	1 x 10	Part of Inpatient Holding Area
BLIN	Bay - Linen	Yes	1 x 2	1 x 2	Part of Inpatient Holding Area
STSS-12	Store - Sterile Stock, 12m2	Yes *	1 x 10	1 x 12	
DTUR-S	Dirty Utility - Sub, 8m2	Yes	1 x 8	1 x 8	
DISP-8	Disposal Room, 8m2	Yes	1 x 8	1 x 8	
	Discounted Circulation		32%	35%	

Australasian Health Facility Guidelines

TREATMENT AREAS

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m2 2 Cameras	Qty x m2 6 Cameras	Remarks
	SPECT Scanning Room (Includes Control Bay)		42	42	Rooms should be rectangular (e.g. 6x7m)
	SPECT / CT Scanning Room		48	48	Rooms should be rectangular (e.g. 6x8m)
	SPECT Control Room		10	10	
BMEQ-4	Bay - Mobile Equipment, 4m2	Yes	1 x 4	2 x 4	
BMEQ-4	Bay - Mobile Equipment, 4m2	Yes	1 x 2	1 x 2	Technegas machine & argon cylinder
STRT	Stress Test Room	Yes	1 x 16	1 x 16	Add 2m2 if includes resuscitation trolley
BRES	Bay - Resuscitation	Yes	1 x 1.5	1 x 1.5	Unless located in Stress Testing Room
CONS	Consult Room	Yes	2 x 12	4 x 12	For dose administration and examination. Radiation safety advice may be required.
TRMT	Treatment Room	Yes		1 x 14 (o)	Ideally adjacent to the Hot / Dispensing Lab
	Bone Density Measurement Room	Yes	1 x 12 (o)	1 x 12 (o)	Increase to 16m2 if trolley / bed access required
STEQ-14	Store - Equipment, 14m2	Yes	1 x 9	1 x 12	
	Computer Room		1 x 8	1 x 8	Computers, printer
XRRR	X-Ray Viewing & Reporting Room	Yes	1 x 10	1 x 25	2 & 5 workstations near scanning rooms
	Discounted Circulation		35%	35%	

HOT LABORATORY

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m2 2 Cameras	Qty x m2 6 Cameras	Remarks
	Entry Lobby - Isotope Delivery		1 x 4 (o)	1 x 4 (o)	delivered directly into unit. May be combined with Waste Holding Store
	Hot Lab / Therapy Dispensing		1 x 10	1 x 12	Fume hood, dose calibrator, balance, centrifuge etc
	Radioactive Waste Holding Store		1 x 4	1 x 6	
BES	Bay - Emergency Shower	Yes	1 x 2	1 x 2	Decontamination
	Discounted Circulation		15%	15%	

STAFF AREAS

AusHFG Room Code	Room / Space	SC / SC-D	Qty x m2 2 Cameras	Qty x m2 6 Cameras	Remarks
OFF-S12	Office - Single Person, 12m2	Y	1 x 12	1 x 12	Unit director
	Office - Workstation, 5.5m2		1 x 5.5 (o)	1 x 5.5	Secretary to Director
OFF-S9	Office - Single Person, 9m2	Y	9.0	9.0	Number depends on staff establishment. Staff Specialists.
	Office - Workstation, 5.5m2		5.5	5.5	Number depends on staff establishment. Registrars.
OFF-S9	Office - Single Person, 12m2	Y	1 x 9 (o)	1 x 12	Chief Physicist.
	Office - Workstation, 5.5m2		5.5 (o)	5.5	Number depends on staff establishment. Physicists.
	Office - Single Person, 9m2	Y	1 x 9 (o)	1 x 9	Chief Technologist, Radiopharmacist, NUM.
	Office - Workstation, 5.5m2		5.5	5.5	Number depends on staff establishment. Technologists.
	Office - Workstation, 5.5m2		5.5	5.5	Number depends on staff establishment. Medical Typists.
SRM-15	Staff Room	Y	1 x 15	1 x 25	Includes beverage bay
MEET-12	Meeting Room, 12m2	Y	1 x 12	2 x 12	
PROP-2	Property Bay - Staff	Y	1 x 2	2 x 2	Size depends on staff establishment
SHST	Shower - Staff, 3m2	Y	1 x 3	1 x 3	
WCST	Toilet - Staff, 3m2	Y	2 x 3	2 x 3	*Number will depend on staff establishment
CLRM-5	Cleaner's Room, 5m2	Y	1 x 5	1 x 5	*May be shared with adjoining unit
	Discounted Circulation		25%	30%	