

Room Name	1 Bed Room - CCU		Room Number 1BR-CCU
Revision	6		
Issue Date	31.01.2024		
BRIEFING			
Briefed Area	20.00 m ²		
Hours of Operation	24 Hours		
Occupancy	1 patient; 1-2 visitors, 1-4 staff intermittently		
Acoustics	Acoustic privacy is required		
Remarks			
Description / Special Requirements	<p>A 1 Bed Room - CCU will accommodate one patient and support the delivery of a range of clinical care, minor procedures and diagnostic tests, with clinical staff requiring access to both sides of the bed.</p> <p><u>Additional Considerations:</u></p> <ul style="list-style-type: none"> The 1 Bed Room - CCU may vary in configuration to suit different Ensuite options including inboard, outboard and stacked (also known as 'back-to-back' or 'nested') configurations. In each configuration, sufficient clearance is required for equipment and staff to access both sides of the bed. Glazed doors and observation windows may be provided for visibility of high acuity patients and monitoring equipment. The provision of observation windows and the use of interstitial blinds or privacy curtains is to be supported by operational models for observation as well as support for patient privacy. The configuration of the Medical Services Panel (MSP), including medical gases, power and data, will be dependent on service requirements. Data provision is to take into consideration the increasing demand and sophistication of information systems and the technological development of monitoring and diagnostic equipment. Natural light and outlook is essential and the patient will need to have an external outlook from either the chair or the bed, preferably both. 		
SERVICES			
Electrical	BODY PROTECTED	<input type="checkbox"/> CARDIAC PROTECTED	<input checked="" type="checkbox"/>
HVAC	AIRCONDITIONING	<input checked="" type="checkbox"/> AIRCONDITIONING: hepa filtered	<input type="checkbox"/>
	AIRCONDITIONING: positive pressure	<input type="checkbox"/> AIRCONDITIONING: negative pressure	<input type="checkbox"/>
	EXHAUST: room exhaust	<input type="checkbox"/> VENTILATION	<input type="checkbox"/>
Lighting	LIGHTING: colour corrected	<input checked="" type="checkbox"/> LIGHTING: dimmable	<input type="checkbox"/>
	LIGHTING: downlights	<input type="checkbox"/> LIGHTING: downlights, dimmable	<input type="checkbox"/>
	LIGHTING: fluorescent/LED, downlights	<input type="checkbox"/> LIGHTING: fluorescent/LED, flush with ceiling, tamper proof	<input type="checkbox"/>
	LIGHTING: fluorescent/LED, general	<input type="checkbox"/> LIGHTING: indirect	<input type="checkbox"/>
Security / Nurse Call	NURSE CALL SYSTEM	<input checked="" type="checkbox"/>	

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	ceiling tiles may also be acceptable dependent upon the acuity of patients to be accommodated and procedures to be performed within the room
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
DWGL-033	DOOR: 1400mm c/o, 1 1/2 leaf, observation panel, solid core/glass, paint	extent of glazing to suit service requirements
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	

Room Name | **1 Bed Room - CCU**
Room Number 1BR-CCU

AusHFG code	Description	Comment
DWOB-001	OBSERVATION: internal window	optional; extent of glazing to suit service requirements
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	to basin
WLPR-002	WALL PROTECTION: bed protection wall panel, composite, laminate finish	
DWWH-005	WINDOW	external, natural light and outlook essential

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	2	
HYBA-010	BASIN: handwash, Type B	1	1	
MMBE-010	BED: patient, electric with mattress	3	1	
FQCW-016	BIN: waste, general, 20L	3	1	to basin
FQCW-044	BIN: waste, sharps, wall mounted	3	1	optional, mobile sharps bin may be provided to be shared between multiple rooms
DWWD-004	BLIND: roller	3	1	to external window
FIHR-004	BRACKET: for display screen, ceiling mounted	1	1	to patient entertainment screen; configuration will be dependent on operational and ICT policies
FIHR-067	BRACKET: for monitor, wall mounted, articulated, adj height	2	1	
FIHR-016	BRACKET: for sharps bin	2	1	optional, mobile sharps bin may be provided to be shared between multiple rooms
FIHR-019	BRACKET: for suction bottle	2	2	
MMGE-019	CHAIR: patient	3	1	
FQBS-030	CHAIR: visitor, patient	3	1	
FIJO-209	CUPBOARD: tall, single door, adj shelves and clothes rail, recessed	1	1	type and extent of storage for patient property to suit operational policies
FQGE-010	CURTAIN: privacy screen	3	1	to door and observation window
FIDI-014	DISPENSER: disposable glove	2	1	to basin
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
ITBU-012	DISPLAY SCREEN: patient entertainment system	1	1	configuration will be dependent on operational and ICT policies
MGFP-002	FLOWMETER: medical air	3	1	
MGFP-004	FLOWMETER: oxygen	3	2	

Room Name | **1 Bed Room - CCU**
Room Number 1BR-CCU

AusHFG code	Description	Group	Qty	Comment
FQSN-051	LOCKER: 2 drawers, open under, lockable, mobile	3	1	type and extent of storage for patient property to suit operational policies
MMHA-005	MONITOR: patient, cardiac	3	1	telemetry provision to suit service requirements
MMGE-100	SUCTION BOTTLE	3	2	
FQTA-013	TABLE: overbed	3	1	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
ITNE-049	TELEPHONE: handset, desktop	3	1	optional, to patient locker; provision dependent on operational policies
PPPP-130	TRACK: curtain, privacy, S shaped, angled	1	1	to door and observation window

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	above services panel, with indicator button and light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	on services panel, with indicator button and light
ITCL-008	BUTTON: nurse call, staff assist	1	1	on services panel, with indicator button and light
ELBO-005	EQUIPOTENTIAL JUNCTION BOX	1	1	
ELGP-223	GPO: emergency power, double, wall mounted	1	1	to patient monitor
ELGP-122	GPO: emergency power, single, on services panel	1	9	type and quantity to suit service requirements
ELGP-101	GPO: single, ceiling mounted	1	1	to patient entertainment system
ELGP-109	GPO: single, wall mounted	1	1	to bedhead; low level for electric bed
ELGP-109	GPO: single, wall mounted	1	1	adjacent to patient chair
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	on services panel
LIFX-017	LIGHT: night light	1	1	switch to patient handset and wall near entry
LIFX-011	LIGHT: reading light	1	1	switch to patient handset and services panel
ITIN-025	OUTLET: data, double RJ45, on services panel	1	2	quantity to suit service requirements
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	to patient monitor
ITIN-070	OUTLET: MATV	1	1	to patient entertainment screen, may be replaced with data outlet in accordance with ICT policy
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	
MGAS-042	OUTLET: oxygen (O2), on services panel	1	2	
MGAS-062	OUTLET: suction, on services panel	1	2	
ELPR-006	RCD: residual current device	1	3	on services panel

Room Name | **1 Bed Room - CCU****Room Number 1BR-CCU**

AusHFG code	Description	Group	Qty	Comment
MMSP-026	SERVICES PANEL: wall mounted	1	1	
ELBO-015	SWITCH: light, single	1	3	1 to general room lighting, 1 to night lighting, 1 on services panel to reading light