

Room Name	Ambulance Triage	Room Number	AMBTR
Revision	3		
Issue Date	20.03.17		
BRIEFING			
Briefed Area	12.00 m ²		
Hours of Operation	24 Hours		
Occupancy	Up to 3		
Acoustics			
Remarks			
Description / Special Requirements	The Ambulance Triage is an area for receipt and assessment of patients arriving in the Unit by ambulance. The Ambulance Triage will be adjacent to the Ambulance entry which should include an Airlock.		
SERVICES			
General Requirements	BODY PROTECTED = Yes	CARDIAC PROTECTED = No	
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No	
Lighting	LIGHTING: colour corrected = Yes LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = No	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No	
Nurse Call	NURSE CALL SYSTEM = Yes		

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
DWSC-022	DOOR: 1400mm c/o, double leaf, solid core, paint	number and width and glazing to suit layout & ambulance requirements
DWSC-003	DOOR: 910mm c/o, single leaf, solid core, paint	secondary access to Emergency Department
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
DWOB-003	OBSERVATION: internal window, alum/glass, double glazed, integral venetian blind, powdercoat	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	to basin, tiles also acceptable
WLPR-002	WALL PROTECTION: bed protection wall panel, composite, laminate finish	
WLPR-012	WALL PROTECTION: corner guards, to 900 AFFL, prefinished PVC	Equal to Acrovyn, as required

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	2	

Room Name | Ambulance Triage
Room Number AMBTR

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	
FIJO-020	BENCH: 600D, open under, laminate finish	1	1	ambulance write up
FQCW-016	BIN: waste, general, 20L	3	1	
FIHR-019	BRACKET: for suction bottle	2	2	optional
FQGE-005	CLOCK: analogue, battery operated	3	1	
FIDI-014	DISPENSER: disposable glove	2	1	
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
MGFP-002	FLOWMETER: medical air	3	1	optional
MGFP-004	FLOWMETER: oxygen	3	2	optional
MMBE-025	GURNEY	3	2	
FIJO-194	SHELF: laminate	1	1	to head of trolleys
MMGE-100	SUCTION BOTTLE	3	2	optional
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
ITNE-053	TELEPHONE: handset, wall mount, handsfree	3	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	1	
ITCL-008	BUTTON: nurse call, staff assist	1	1	
ELGP-208	GPO: double, wall mounted	1	1	to write up bay
ELGP-209	GPO: double, wall mounted, RCD protected	1	1	
ELGP-123	GPO: emergency power, single, wall mounted	1	2	
ELGP-109	GPO: single, wall mounted	1	2	
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	2	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	to write up bay
MGAS-023	OUTLET: medical air (MA), wall mounted	1	1	optional
MGAS-043	OUTLET: oxygen (O2), wall mounted	1	2	optional
MGAS-063	OUTLET: suction, wall mounted	1	2	optional
ELBO-015	SWITCH: light, single	1	1	