

| Room Name                          | Angiography Procedure Room                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  |                                                                                                                                                            | Room Number ANPR |
|------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------|
| Revision                           | 3                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                           |                                                                                                                                                            |                  |
| Issue Date                         | 20.03.17                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    |                                                                                                                                                            |                  |
| BRIEFING                           |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             |                                                                                                                                                            |                  |
| Briefed Area                       | 42.00 m <sup>2</sup>                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |                                                                                                                                                            |                  |
| Hours of Operation                 | Available 24 Hours                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          |                                                                                                                                                            |                  |
| Occupancy                          | 1 patient, up to 6 staff                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                    |                                                                                                                                                            |                  |
| Acoustics                          | Acoustic privacy is required                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                |                                                                                                                                                            |                  |
| Remarks                            |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             |                                                                                                                                                            |                  |
| Description / Special Requirements | Procedure room where Angiography procedures and electrophysiology studies are undertaken in a controlled environment. A Control room will be located adjacent and may serve more than one procedure room. A clinical scrub area should be located immediately adjacent to the room staff entry. Additional Design Considerations: Radiation shielding as advised by Radiation Consultant. Unistrut Ceiling able to carry moving loads may be required. Cable ducts from Control Room and Computer/Equipment room may be required. 'X-Ray in Use' lights are required outside each entry door. Power to Angiography equipment should be on emergency supply. |                                                                                                                                                            |                  |
| SERVICES                           |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             |                                                                                                                                                            |                  |
| General Requirements               | BODY PROTECTED = No                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                         | CARDIAC PROTECTED = Yes                                                                                                                                    |                  |
| Air                                | AIRCONDITIONING = Yes<br>AIRCONDITIONING: positive pressure = No<br>EXHAUST: room exhaust = No                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              | AIRCONDITIONING: hepa filtered = No<br>AIRCONDITIONING: negative pressure = No<br>VENTILATION = No                                                         |                  |
| Lighting                           | LIGHTING: colour corrected = Yes<br>LIGHTING: downlights = No<br>LIGHTING: fluorescent, downlights = No<br>LIGHTING: fluorescent, general = No                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              | LIGHTING: dimmable = No<br>LIGHTING: downlights, dimmable = Yes<br>LIGHTING: fluorescent, flush with ceiling, tamper proof = No<br>LIGHTING: indirect = No |                  |
| Nurse Call                         | NURSE CALL SYSTEM = Yes                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                     |                                                                                                                                                            |                  |

**Room Fabrics**

| AusHFG code | Description                                                                                   | Comment             |
|-------------|-----------------------------------------------------------------------------------------------|---------------------|
| CLFS-006    | CEILING: plasterboard, flush set, suspended, paint, washable                                  | at 3000 mm AFFL     |
| CLCN-007    | CORNICE: plasterboard, flush coved between wall and ceiling, paint                            |                     |
| DWSC-026    | DOOR: 1600mm c/o, 1 1/2 leaf, solid core, lead shielding, paint                               | patient entry/ exit |
| DWGL-006    | DOOR: 910mm c/o, single leaf, observation panel, solid core/lead glass, lead shielding, paint | staff entry/ exit   |
| DWPR-006    | DOOR PROTECTION: protection plate, to 900 AFFL, PVC, prefinished                              | equal to Acrovyn    |
| DWPR-010    | DOOR PROTECTION: to door frame, PVC, prefinished                                              | equal to Acrovyn    |
| FLVY-007    | FLOOR FINISH: vinyl, seamless, coved, standard slip resistant                                 |                     |
| DWOB-009    | OBSERVATION: internal window, lead glass, clear                                               | to control room     |
| FLSK-010    | SKIRTING: vinyl, floor vinyl coved, 150H, prefinished                                         |                     |
| WLWA-004    | WALL FINISH: paint, acrylic, washable                                                         |                     |
| WLPR-019    | WALL PROTECTION: crash rail, at 900 AFFL, prefinished PVC                                     | equal to Acrovyn    |

**Fittings, Furniture and Equipment (FF&E) Items**

| AusHFG code | Description       | Group | Qty | Comment        |
|-------------|-------------------|-------|-----|----------------|
| MMGE-001    | ADAPTER: scavenge | 3     | 1   | services panel |

**Room Name** | **Angiography Procedure Room**
**Room Number ANPR**

| AusHFG code | Description                                                       | Group | Qty | Comment                                   |
|-------------|-------------------------------------------------------------------|-------|-----|-------------------------------------------|
| MMGE-002    | ADAPTER: suction                                                  | 3     | 2   |                                           |
| FIJO-083    | BENCH TOP: special depth, joinery under, laminate finish          | 1     | 1   | 540D                                      |
| FQCW-016    | BIN: waste, general, 20L                                          | 3     | 1   |                                           |
| FIHR-019    | BRACKET: for suction bottle                                       | 2     | 2   | below services panel                      |
| ITCL-014    | CLOCK: analogue, electric                                         | 1     | 1   |                                           |
| FIJO-106    | CUPBOARD: drawer unit, 4 equal                                    | 1     | 1   | under bench                               |
| FIJO-123    | CUPBOARD: tall, double sliding door, glazed, catheter hanging     | 1     | 1   | sliding glass doors, shelving to one side |
| FIJO-135    | CUPBOARD: underbench, double door, adj shelves                    | 1     | 1   |                                           |
| FIJO-140    | CUPBOARD: underbench, single door, adj shelves                    | 1     | 1   |                                           |
| MGFP-002    | FLOWMETER: medical air                                            | 3     | 1   | services panel                            |
| MGFP-004    | FLOWMETER: oxygen                                                 | 3     | 2   | services panel                            |
| MMSP-029    | LIGHT: operating, single, 550 diam nom.                           | 1     | 1   |                                           |
| MMHA-005    | MONITOR: patient, cardiac                                         | 3     | 3   | on ceiling support frame                  |
| MMGE-100    | SUCTION BOTTLE                                                    | 3     | 2   | on bracket                                |
| MMMI-028    | SYSTEM: imaging, angiography single plane ceiling                 | 1     | 1   | with imaging & cardiac monitors           |
| MMMI-024    | TABLE: operating, fixed, narrow, angiography single plane ceiling | 1     | 1   |                                           |

**Engineering Services**

| AusHFG code | Description                                     | Group | Qty | Comment                                           |
|-------------|-------------------------------------------------|-------|-----|---------------------------------------------------|
| ITCL-004    | BUTTON: nurse call, emergency                   | 1     | 1   | on Services Panel 3, indicator button & light,    |
| ITCL-009    | BUTTON: nurse call, staff / nurse assist        | 1     | 1   | on Services Panel 3, indicator button & light,    |
| ITCL-008    | BUTTON: nurse call, staff assist                | 1     | 1   | on Services Panel 3, indicator button & light,    |
| ELGP-206    | GPO: double, on services panel, RCD protected   | 1     | 1   | on Services Panel 3, 20 amp                       |
| ELGP-206    | GPO: double, on services panel, RCD protected   | 1     | 1   | on Services Panel 1, 20 amp                       |
| ELGP-222    | GPO: emergency power, double, on services panel | 1     | 1   | on Services Panel 3                               |
| ELGP-223    | GPO: emergency power, double, wall mounted      | 1     | 2   | 2 above bench                                     |
| ELGP-122    | GPO: emergency power, single, on services panel | 1     | 6   | on Services Panel 1                               |
| ELGP-105    | GPO: single, on services panel                  | 1     | 7   | on Services Panel 1                               |
| ELGP-105    | GPO: single, on services panel                  | 1     | 1   | on Services Panel 3, to angiography table, 20 amp |
| ELGP-110    | GPO: single, wall mounted, cleaner              | 1     | 1   |                                                   |
| ITSE-029    | INTERCOM: audio, wall mount                     | 1     | 1   | handsfree to control room                         |
| ITIN-025    | OUTLET: data, double RJ45, on services panel    | 1     | 2   | on Services Panel 1                               |
| ITIN-026    | OUTLET: data, double RJ45, wall mounted         | 1     | 1   | 1 outlet for telephone                            |
| MGAS-022    | OUTLET: medical air (MA), on services panel     | 1     | 1   | on Services Panel 2, to angiography table         |

**Room Name** | **Angiography Procedure Room**
**Room Number ANPR**

| AusHFG code | Description                                    | Group | Qty | Comment                                   |
|-------------|------------------------------------------------|-------|-----|-------------------------------------------|
| MGAS-032    | OUTLET: nitrous oxide (N2O), on services panel | 1     | 1   | on Services Panel 2, to angiography table |
| MGAS-042    | OUTLET: oxygen (O2), on services panel         | 1     | 2   | on Services Panel 2, to angiography table |
| MGAS-053    | OUTLET: scavenge, on services panel            | 1     | 1   | on Services Panel 2, to angiography table |
| MGAS-062    | OUTLET: suction, on services panel             | 1     | 2   | on Services Panel 2, to angiography table |
| MMSP-025    | SERVICES PANEL: special                        | 2     | 1   | Panel 2, to angiography table             |
| MMSP-026    | SERVICES PANEL: wall mounted                   | 2     | 2   | Panels 1 and 3                            |
| WLSH-004    | SHIELDING: lead lining                         | 1     | 1   | to walls and doors as specified           |
| ELBO-015    | SWITCH: light, single                          | 1     | 3   |                                           |