



Room Name	Assembly/ Preparation (Pharmacy), 20	m2 Room Number ASPR-20
Revision	3	
Issue Date	20.03.17	
BRIEFING		
Briefed Area	20.00 m <sup>2</sup>	
Hours of Operation	8am to 8pm, daily	
Occupancy	Up to 5	
Acoustics		
Remarks		
Description / Special Requirements		stations for pharmacists to prepare, assemble and label patier should be located close to the Pharmacy Bulk Store.
SERVICES		
General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = No
Air	AIRCONDITIONING = Yes	AIRCONDITIONING: hepa filtered = No
	AIRCONDITIONING: positive pressure = No	AIRCONDITIONING: negative pressure = No
	EXHAUST: room exhaust = No	VENTILATION = No
Lighting	LIGHTING: colour corrected = No	LIGHTING: dimmable = No
	LIGHTING: downlights = No	LIGHTING: downlights, dimmable = No
	LIGHTING: fluorescent, downlights = No	LIGHTING: fluorescent, flush with ceiling, tamper proof = No
	LIGHTING: fluorescent, general = Yes	LIGHTING: indirect = No

## **Room Fabrics**

AHHA and a selective at large

AusHFG code	Description	Comment
CLTI-002	CEILING: acoustic, drop-in tiles, 600 x 1200	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	to basin & sink bench

## Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	refer to BHWS-B (similar)
FIJO-199	BENCH: workstation, Pharmacy, freestanding (small)	1	1	@ 1000mmH, preparation workstations
FIJO-076	BENCH TOP: 900D, joinery under, laminate finish	1	1	with inset sink
FQCW-016	BIN: waste, general, 20L	3	1	
FQBS-019	CHAIR: office, ergonomic, high	3	5	
ITNE-007	COMPUTER: desktop, with display screen	3	2	flat screens
FIJO-135	CUPBOARD: underbench, double door, adj shelves	1	1	under sink, adjustable shelves

Ge

Page: 1 Print Date: 20/03/2017





**Room Name** 

Assembly/ Preparation (Pharmacy), 20m2

**Room Number ASPR-20** 

AusHFG code	Description	Group	Qty	Comment
FIJO-139	CUPBOARD: underbench, shelf unit, pharmacy shelves	3	1	under preparation bench
FIJO-152	CUPBOARD: wall mount, shelf unit, adj shelves	1	3	over sink bench
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	
FIBM-013	NOTICEBOARD: fixed, fabric covered	1	2	to upstand of preparation bench
ITNE-023	PRINTER: networked	3	2	labels
HYBA-069	SINK: single, with drainer, 930mmL	1	1	hot water
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to basin
HYTP-037	TAPWARE: mixer, elbow levers	1	1	to sink
ITNE-048	TELEPHONE: handset, cordless	3	1	mobile

## **Engineering Services**

AusHFG code	Description	Group	Qty	Comment
ELGP-208	GPO: double, wall mounted	1	12	2 per workstation, 2-printers
LIFX-008	LIGHT: task light, built in	1	3	under O/H shelving
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	5	workstations; 1 outlet per workstation for telephone
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	printers
ELBO-015	SWITCH: light, single	1	1	

