

Room Name	Bay - Emergency Shower	Room Number BES				
Revision	3					
Issue Date	20.03.17					
BRIEFING						
Briefed Area	1.00 m ²					
Hours of Operation	Available 24 Hours					
Occupancy	1					
Acoustics						
Remarks						
Description / Special Requirements	An unobstructed and accessible area with an emergency shower and eye wash equipment for staff who have been contaminated with toxic and/or corrosive substances.					
SERVICES						
General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = No				
Air	AIRCONDITIONING = No AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = Yes				
Lighting	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = No LIGHTING: indirect = No				
Nurse Call	NURSE CALL SYSTEM = No					

Room Fabrics

AusHFG code	Description	Comment
CLFS-009	CEILING: plasterboard, water resistant, flush set, suspended, paint, washable	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
FLVY-009	FLOOR FINISH: vinyl, seamless, coved, wet area, non-slip	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-019	WALL FINISH: vinyl, full height	
WLPR-011	WALL PROTECTION: corner guards, to 900 AFFL min.	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
HYTP-023	SHOWER: safety, eyewash combination		1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
HYDR-004	DRAIN: floor waste	1	1	

AHHA
australisele health infrastrucker eillenen.

Page: 1 Print Date: 20/03/2017