

Room Name	Bay - Handwashing, Type B	Room Number BHWS-B			
Revision	5				
Issue Date	20.03.17				
BRIEFING					
Briefed Area	1.00 m ²				
Hours of Operation	24 Hours				
Occupancy	1				
Acoustics					
Remarks					
Description / Special Requirements	An area off the corridor, which may be a recessed bay, with handwashing facilities for staff to cleanse their hands before and after every patient contact. Type B refers to a Medium Handbasin with elbow action lever taps - for procedural handwashing; taps may be basin mounted or wall mounted. A vanity unit is optional.				
SERVICES					
General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = No			
Air	AIRCONDITIONING = Yes AIRCONDITIONING: positive pressure = No EXHAUST: room exhaust = No	AIRCONDITIONING: hepa filtered = No AIRCONDITIONING: negative pressure = No VENTILATION = No			
Lighting	LIGHTING: colour corrected = No LIGHTING: downlights = No LIGHTING: fluorescent, downlights = No LIGHTING: fluorescent, general = Yes	LIGHTING: dimmable = No LIGHTING: downlights, dimmable = No LIGHTING: fluorescent, flush with ceiling, tamper proof = N LIGHTING: indirect = No			
Nurse Call	NURSE CALL SYSTEM = No				

Room Fabrics

AusHFG code	AusHFG code Description	
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
FLVY-006	FLOOR FINISH: vinyl, seamless, coved, non slip, textured	under basin
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-007	WALL FINISH: splashback	default = vinyl: tiles also acceptable
WLPR-013	WALL PROTECTION: corner guards, to 1500 AFFL, prefinished PVC	as required, equal to 'Acrovyn'

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	
FQCW-016	BIN: waste, general, 20L	3	1	
FIDI-014	DISPENSER: disposable glove	2	1	optional
FIDI-025	DISPENSER: paper/hand towel	2	1	
FIDI-030	DISPENSER: soap	2	1	
FIDI-031	DISPENSER: soap antiseptic	2	1	optional

AHHA
australision health infrastructure olikonoe
entropolisis IN BERKER IN BERKER INDUSTRI

Page: 1 Print Date: 20/03/2017



Room Data Sheet



Room Name

Bay - Handwashing, Type B

Room Number BHWS-B

AusHFG code	Description	Group	Qty	Comment
FIJO-181	JOINERY UNIT: vanity, single basin	1	1	optional
HYTP-037	TAPWARE: mixer, elbow levers	1	1	basin or wall mounted

Engineering Services

