

Room Name	Bay - Handwashing/ PPE	Room Number BHWS-PPE			
Revision	5				
Issue Date	20.03.17				
BRIEFING					
Briefed Area	1.50 m ²				
Hours of Operation	24 Hours				
Occupancy	1				
Acoustics	·				
Remarks					
Description / Special Requirements	An area off the corridor, which may be a recessed bay, with handwashing facilities for staff to cleanse their hands before and after every patient contact and for the storage of PPE equipment. The PPE bay will include a medium handbasin (Type B) with elbow action lever taps or handsfree (optional) for procedural handwashing; taps may be basin mounted or wall mounted.				
OFFINIOFO					
SERVICES	DODY PROTECTED N	OARRIAG PROTECTER AL			
General Requirements	BODY PROTECTED = No	CARDIAC PROTECTED = No			
Air	AIRCONDITIONING = Yes	AIRCONDITIONING: hepa filtered = No			
- 	AIRCONDITIONING: positive pressure = No	AIRCONDITIONING: negative pressure = No			
	EXHAUST: room exhaust = No	VENTILATION = No			
Lighting	LIGHTING: colour corrected = No	LIGHTING: dimmable = No			
Lighting	LIGHTING: downlights = No	LIGHTING: downlights, dimmable = No			
	LIGHTING: fluorescent, downlights = Yes	LIGHTING: fluorescent, flush with ceiling, tamper proof = No			
	<u>LIGH</u> TING: fluorescent, general = Yes	LIGHTING: indirect = No			
Nurse Call	NUPLE CALLOYOTEM = 1 b	RED			

Room Fabrics

AusHFG code	Description	Comment
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	Acoustic tiles acceptable.
CLCN-002	CORNICE: aluminium, 24mm shadow angle, powdercoat	
FLVY-009	FLOOR FINISH: vinyl, seamless, coved, wet area, non-slip	
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-007	WALL FINISH: splashback	
WLPR-013	WALL PROTECTION: corner guards, to 1500 AFFL, prefinished PVC	as required, equal to 'Acrovyn'
WLPR-010	WALL PROTECTION: corner guards, to 900 AFFL	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
HYBA-010	BASIN: handwash, Type B	1	1	
FQCW-016	BIN: waste, general, 20L	3	1	
FIJO-155	CUPBOARD: wall mount, shelf unit, fixed shelves	1	1	for gowns, masks etc, optional if wall mounted dispensers not provided
FIDI-001	DISPENSER: alcohol based hand rub	2	1	
FIDI-014	DISPENSER: disposable glove	2	1	

Page: 1 Print Date: 20/03/2017







Room Name

Bay - Handwashing/ PPE

Room Number BHWS-PPE

AusHFG code	Description	Group	Qty	Comment
FIDI-019	DISPENSER: gown/apron	2	1	
FIDI-021	DISPENSER: mask	3	1	optional, PPE
FIDI-022	DISPENSER: moisturiser	2	1	to hand basin. Depends on operational policy.
FIDI-025	DISPENSER: paper/hand towel	2	1	
FIDI-030	DISPENSER: soap	2	1	
FIDI-031	DISPENSER: soap antiseptic	2	1	optional
HYTP-037	TAPWARE: mixer, elbow levers	1	1	elbow action levers or handsfree optional

Engineering Services





Page: 2 Print Date: 20/03/2017