



Room Name	Birthing Room - LDR With Bath	Room Number BIRM-B			
Revision	1				
Issue Date	05.04.18				
BRIEFING					
Briefed Area	40.50 m ²				
Hours of Operation	24 Hours				
Occupancy	1 mother; 1-2 support persons; up to 4 staff				
Acoustics	Sound attenuation level high, Acoustic privacy	is required.			
Remarks					
Description / Special Requirements	The Birthing Room LDR (with birthing bath/ pool) provides for the entire process of delivery including mother's preparation, relaxation and analgesia during labour, delivery, infant resuscitation, post natal recovery and observation. The Birthing Room will include a scrub basin. Clinical items such as medical gases and services may be concealed but within easy reach. The room will have direct access to an Ensuite - Birthing. The room can be used for an extended stay where LDPR models are used. The birth bath/ pool is routinely used for water immersion during labour. It may also be used for water births but this will need to be supported by local policies. A ceiling mounted hoist has not been included as there are better and more timely ways to remove a mother from the bath should her condition deteriorate. Refer to HPU510 Maternity Unit for details. Note that the overall room area includes a 2m2 Equipment Store. Notes applied to floor ratings respond to current AS 4586 and associated HB198 requirements - compliance with current regulations and jurisdictional policy must be verified by project teams on each project. Negative pressure air conditioning is required for clearance of anaesthetic gases.				
SERVICES	PODV PROTECTED Ves	CARDIAC PROTECTED No			
General Requirements	BODY PROTECTED = Yes	CARDIAC PROTECTED = No			
Air	AIRCONDITIONING = No	AIRCONDITIONING: hepa filtered = No			
7.11	AIRCONDITIONING: positive pressure = No	AIRCONDITIONING: negative pressure = Yes			
	EXHAUST: room exhaust = No	VENTILATION = No			
Lighting	LIGHTING: colour corrected = Yes	LIGHTING: dimmable = No			
	LIGHTING: downlights = No	LIGHTING: downlights, dimmable = Yes			
	LIGHTING: fluorescent/LED, downlights = No	LIGHTING: fluorescent/LED, flush with ceiling, tamper proof = No			
	LIGHTING: fluorescent/LED, general = No	LIGHTING: indirect = No			
Nurse Call	NURSE CALL SYSTEM = Yes				

Room Fabrics

AusHFG code	Description	Comment
CLGE-001	CEILING: plasterboard, bulkhead, paint	above joinery items, joinery bulkhead can alternatively be provided
CLFS-006	CEILING: plasterboard, flush set, suspended, paint, washable	
CLCN-008	CORNICE: square set flush between wall and ceiling, paint	
DWSC-021	DOOR: 1400mm c/o, 1 1/2 leaf, solid core, paint	with latchset and hold open device
DWPR-005	DOOR PROTECTION: protection plate to 900 AFFL	
DWPR-010	DOOR PROTECTION: to door frame, PVC, prefinished	optional
FLVY-007	FLOOR FINISH: vinyl, seamless, coved, standard slip resistant	floor finish must be minimum slip rating R10; Pendulum P3 or agreed equivalent to extend under basin
FLVY-009	FLOOR FINISH: vinyl, seamless, coved, wet area, non-slip	to bath area
FLSK-010	SKIRTING: vinyl, floor vinyl coved, 150H, prefinished	

ALHA australosian health infrastructure allicence communicati Dalassiannica St deuter sealinn haustrat Page: 1 Print Date: 03/04/2018





Room Name

Birthing Room - LDR With Bath

Room Number BIRM-B

AusHFG code	Description	Comment
WLWA-004	WALL FINISH: paint, acrylic, washable	
WLWA-010	WALL FINISH: splashback, vinyl	to basin
WLPR-002	WALL PROTECTION: bed protection wall panel, composite, laminate finish	
WLPR-011	WALL PROTECTION: corner guards, to 900 AFFL min.	
DWWH-005	WINDOW	

Fittings, Furniture and Equipment (FF&E) Items

AusHFG code	Description	Group	Qty	Comment
MMGE-002	ADAPTER: suction	3	2	
HYBA-009	BASIN: handwash, Type A, scrub	1	1	refer to BWHS-A (similar)
FQBS-001	BASSINET	3	1	optional, if used for post-natal care
HYBA-023	BATH: birthing	1	1	integral water and drainage
MMBE-005	BED: patient, birthing, electric	3	1	
FQCW-006	BIN: waste, clinical, 240L	3	1	
FQCW-016	BIN: waste, general, 20L	3	1	to basin
FQCW-043	BIN: waste, sharps, on trolley	3	1	
FIHR-004	BRACKET: for display screen, ceiling mounted	1	1	
FIHR-016	BRACKET: for sharps bin	2	1	mounted to trolley
FIHR-019	BRACKET: for suction bottle	2	1	
FQBS-019	CHAIR: office, ergonomic, high	3	1	to bench
FQGE-005	CLOCK: analogue, battery operated	3	1	
ITNE-007	COMPUTER: desktop, with display screen	3	1	
FIJO-130	CUPBOARD: tall, single door, adj shelves and clothes rail	1	1	wardrobe
FIJO-162	CUPBOARD: tall, single door, to conceal services	1	1	
FIJO-160	CUPBOARD: wall mount, double door, fixed shelf over	1	1	for towels
FQGE-010	CURTAIN: privacy screen	3	1	optional, to door to equipment store
FQGE-010	CURTAIN: privacy screen	3	1	to door to room
DWWD-011	CURTAIN: window, drapes	3	1	set
FQDW-039	DESK: adj height, 800W x 600D x 1000H nom.	3	1	recommended adjustable range 900-1100mm high
FIDI-001	DISPENSER: alcohol based hand rub	2	1	to infant resuscitaire
FIDI-014	DISPENSER: disposable glove	2	1	to basin
FIDI-025	DISPENSER: paper/hand towel	2	1	to basin
FIDI-030	DISPENSER: soap	2	1	to basin
FIDI-031	DISPENSER: soap antiseptic	2	1	to basin
ITBU-012	DISPLAY SCREEN: patient entertainment system	1	1	
MGFP-002	FLOWMETER: medical air	3	2	
MGFP-004	FLOWMETER: oxygen	3	4	



Page: 2 Print Date: 03/04/2018





Room Name

Birthing Room - LDR With Bath

Room Number BIRM-B

AusHFG code	Description	Group	Qty	Comment
LIFX-027	LIGHT: examination, ceiling mounted	1	1	optional
LIPO-006	LIGHT: examination, mobile	3	1	
FQSN-051	LOCKER: 2 drawers, open under, lockable, mobile	3	1	
FQBS-041	LOUNGE: 2.5 seat	3	1	
MMMA-017	MANTLEPIECE: birthing, wall mounted	2	1	
MMMA-011	MIXER: oxygen and nitrous oxide	3	1	
MMGE-063	MONITOR: patient, foetal, CTG	3	1	mobile
MMMA-016	RESUSCITAIRE: infant, wall mounted	1	1	
FQBS-051	STOOL: mobile, adj height	3	1	for partner of birthing mother when at bath
MMGE-100	SUCTION BOTTLE	3	2	
FQTA-013	TABLE: overbed	3	1	
FQTA-053	TABLE: round, 600 diam, low height	3	1	
HYTP-037	TAPWARE: mixer, elbow levers	1	1	
ITNE-049	TELEPHONE: handset, desktop	3	1	
ITNE-053	TELEPHONE: handset, wall mount, handsfree	3	1	
FIRT-030	TRACK: curtain, flat pelmet	1	1	
FIRT-032	TRACK: curtain, privacy, L shaped	1	1	to door entry
FQSM-016	TROLLEY	3	1	

Engineering Services

AusHFG code	Description	Group	Qty	Comment
ITCL-004	BUTTON: nurse call, emergency	1	2	staff side and at infant resus, + indicator button & light
ITCL-006	BUTTON: nurse call, patient to staff	1	1	patient side, + indicator button & light
ITCL-008	BUTTON: nurse call, staff assist	1	2	staff side and to bath, + indicator button & light
HYDR-004	DRAIN: floor waste	1	1	
ELGP-205	GPO: double, on services panel	1	2	to services panel, infant resuscitaire
ELGP-208	GPO: double, wall mounted	1	1	low level, for electric bed
ELGP-208	GPO: double, wall mounted	1	3	
ELGP-122	GPO: emergency power, single, on services panel	1	2	to services panel, infant resuscitaire
ELGP-123	GPO: emergency power, single, wall mounted	1	4	staff side
ELGP-101	GPO: single, ceiling mounted	1	1	for ceiling mounted display screen (TV)
ELGP-109	GPO: single, wall mounted	1	4	patient side
ELGP-110	GPO: single, wall mounted, cleaner	1	1	
ITCL-028	HANDSET: nurse call, with patient to staff call button	1	1	patient side, with light switch
LIFX-017	LIGHT: night light	1	1	







Room Name

Birthing Room - LDR With Bath

Room Number BIRM-B

AusHFG code	Description	Group	Qty	Comment
LIFX-011	LIGHT: reading light	1	1	
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	above bench, 1 outlet for telephone
ITIN-026	OUTLET: data, double RJ45, wall mounted	1	1	patient side
ITIN-070	OUTLET: MATV	1	1	may be replaced with data outlet depending on entertainment system
MGAS-022	OUTLET: medical air (MA), on services panel	1	1	to services panel, infant resuscitaire
MGAS-023	OUTLET: medical air (MA), wall mounted	1	1	in cupboard
MGAS-033	OUTLET: nitrous oxide (N2O), wall mounted	1	2	in cupboard, to bath
MGAS-042	OUTLET: oxygen (O2), on services panel	1	1	to services panel, infant resuscitaire
MGAS-043	OUTLET: oxygen (O2), wall mounted	1	3	in cupboard (2), to bath (1)
MGAS-055	OUTLET: scavenge, wall mounted	1	1	in cupboard
MGAS-062	OUTLET: suction, on services panel	1	1	to services panel, infant resuscitaire
MGAS-063	OUTLET: suction, wall mounted	1	1	in cupboard
ELPR-006	RCD: residual current device	1	4	1 to staff side, 1 to patient side, 2 to infant resuscitaire
MMSP-026	SERVICES PANEL: wall mounted	1	1	to infant resuscitaire
ELBO-015	SWITCH: light, single	1	4	to ensuite, wall panel, door, store



Page: 4 Print Date: 03/04/2018